

BY COURIER

March 26, 2018

Ms. Kirsten Walli
Board Secretary
Ontario Energy Board
Suite 2700, 2300 Yonge Street
P.O. Box 2319
Toronto, ON M4P 1E4

Dear Ms. Walli:

Application for Review of NERC Reliability Standard TPL-007-2

The Independent Electricity System Operator (“the IESO”) and Hydro One Networks Inc. (“Hydro One”) wish to submit to the Ontario Energy Board (“the Board”) an application for review of North American Electric Reliability Corporation (“NERC”) Reliability Standard TPL-007-2 - Transmission System Planned Performance for Geomagnetic Disturbance Events as per Section 36.2 (3) of the Ontario *Electricity Act, 1998* (“the Act”).

The IESO and Hydro One also wish to submit to the Board a request to stay the operation of TPL-007-2 (“the Proposed Standard”) in Ontario as per section 36.2 (5) of the Act until a NERC process, referred to as a Standard Authorization Request process, to develop a variance to the Proposed Standard is complete or the United States’ Federal Energy Regulatory Commission issues a ruling on the Proposed Standard, whichever occurs later. Further information and rationale for the request can be found in the attached document. If you require any further information regarding this matter, please contact Mr. Paul Malozewski at 416-345-5005 or Ms. Tam Wagner at 416-969-6033.

Sincerely,

Ian Malpass
Director, Reliability Initiatives, Compliance and Support
Hydro One Networks Inc.

Tam Wagner
Senior Manager, Regulatory Affairs
Independent Electricity System Operator

cc. Laura Hussey – Director of International Relations – NERC
cc. Shama Elstein – Senior Counsel – NERC
cc. Lauren Perotti – Counsel – NERC
cc. Candice Castaneda – Counsel – NERC
cc. Robert Reinmuller – Director of System Planning – Hydro One
cc. David Short – Director of Power System Assessments – IESO

Application for Review of NERC Reliability Standard TPL-007-2

Overview

The Independent Electricity System Operator (“IESO”) and Hydro One Networks Inc. (“Hydro One”) are requesting that the Ontario Energy Board (“the Board”) review the North American Electric Reliability Corporation’s (“NERC”) Reliability Standard TPL-007-2 – Transmission System Planned Performance for Geomagnetic Disturbance Events (“the Proposed Standard”) and stay its operation in Ontario as per section 36.2 of the *Electricity Act, 1998* (“the Act”), pending the outcome of a Standard Authorization Request (“SAR”) submitted by both parties to NERC to seek a variance to the Proposed Standard. As further explained below, the basis for this request and for the SAR is that the Proposed Standard does not currently reflect the unique topology of the Canadian Shield and ongoing research and development is being undertaken to address the risk of Geomagnetic Disturbance (“GMD”) to the Bulk Electric System (“BES”)¹. If seeking a variance to the Proposed Standard through the SAR is unsuccessful, the IESO and Hydro One intend to file additional submissions to the Board in request of relief measures.

The Proposed Standard addresses directives in the United States’ Federal Energy Regulatory Commission (“FERC”) Order No. 830 ([Docket No. RM15-11-000](#)) to expand GMD-related measures for transmission system performance in the existing NERC Reliability Standard TPL-007-1 (Version 1 of the Proposed Standard) that applicable North American entities are required to take. The Proposed Standard was developed with industry in 2017, filed with FERC on January 22, 2018 and filed with the appropriate Canadian authorities, including the Board, on February 27, 2018. NERC’s filing with the Board is provided in Appendix B. Further review and approval by FERC is required in order for the Proposed Standard to be considered in effect.

The intent of the Proposed Standard is to mitigate reliability risks posed by GMD events on the BES by identifying system vulnerabilities based on established criteria and correcting them within a defined planning horizon. TPL-007-1 requires applicable entities to assess the potential GMD impact to their systems from a defined event referred to as a “benchmark GMD event.” The Proposed Standard (Version 2) adds new requirements to assess the potential implications of a supplemental GMD event on their equipment and systems. Overall, the Proposed Standard would require each applicable entity to conduct the following key activities: (1) collaborate to develop GMD study models; (2) establish steady state performance criteria; (3) perform defined benchmark and supplemental GMD vulnerability assessments to identify BES vulnerabilities; (4) develop and implement a corrective action plan (CAP) if required; and

¹ Defined as most transmission elements operated at 100 kV or higher and real power and reactive power resources connected at 100 kV or higher.

(5) develop and implement plans to collect data to enable further research and validation of GMD assessment models. Please refer to Appendix A for more information on the Proposed Standard's requirements.

The Proposed Standard establishes parameters to scale the benchmark and supplemental GMD events ("Scaling Factors"²) to account for local geomagnetic latitude and local earth conductivity. NERC registered entities in provinces with Canadian Shield – including Manitoba, Ontario, Quebec and Saskatchewan – believe that these Scaling Factors do not sufficiently take into account their unique topology. Ongoing research and development on this phenomenon is being conducted in Canada.

The IESO and Hydro One, with support from the Canadian Electricity Association and other affected provinces, submitted a SAR to NERC on February 27, 2018 requesting that the Proposed Standard be varied to "provide the flexibility for Canadian jurisdictions to leverage their expertise and to build on their research and on GMD impact assessment methodologies to define alternative benchmark GMD events and/or supplemental GMD events targeted to their unique topology". The SAR was authorized by NERC's Standards Committee on March 14, 2018 and is included in Appendix C. The SAR is currently subject to a public review and comment period. The IESO and Hydro One anticipate that a standard drafting team that includes subject matter experts from Canadian NERC registered entities will be formed to address the SAR.

With the above context in mind, the IESO and Hydro One are requesting that the Board review the Proposed Standard as per section 36.2(3) of the Act with the rationale that implementation of certain elements of the standard may be inconsistent with the following objectives of the Act:

- To ensure the adequacy, safety, sustainability and reliability of electricity supply in Ontario through responsible planning (s.1(a))
- To protect the interests of consumers with respect to prices (s.1(f))

Per s.36.2(6) of the Act, the IESO and Hydro One are also requesting the Board stay the operation of the Proposed Standard in Ontario for the following considerations:

- The impact on consumers;
 - The need to co-ordinate the implementation of the standard in Ontario with other jurisdictions;
- and

² NERC Reliability Standard TPL-007-2 – Attachment 1 – Page 26

- The need to co-ordinate the review of the standard in Ontario with regulatory bodies in other jurisdictions that have reviewed, are reviewing or may review the standard and that have the authority to refer the standard back to the standards authority for further consideration.

The IESO and Hydro One further request that the Board stay the operation of the Proposed Standard until the SAR process is complete or FERC issues a ruling on the Proposed Standard, whichever occurs later. The rationale for each of these considerations is explored in greater depth in the following sections.

Rationale for Application

1. Rationale for Request to Review the Proposed Standard

1.1 Reliability of Electricity Supply in Ontario through Responsible Planning

The Act requires the IESO to “engage in activities in support of the goal of ensuring adequate, reliable and secure electricity supply and resources in Ontario”. Hydro One plays an extensive and instrumental role in transmission planning in Ontario, as set out in the Board’s Transmission System Code.

The IESO and Hydro One – along with NERC registered entities from Manitoba, Quebec and Saskatchewan – believe that the Scaling Factors for the benchmark and supplemental GMD events as contemplated in the Proposed Standard do not accommodate the unique geographical and geological characteristics of the Canadian Shield, which are currently subject to research by Natural Resources Canada (NRCan) and NERC registered entities in affected Canadian provinces. As such, implementation of the Proposed Standard would require the IESO and Hydro One to engage in planning activities using data that is not sufficiently reflective of system conditions in Ontario.

It is worth noting that there are other NERC Reliability Standards³ currently enforced in Ontario that address the risk of GMD on reliable operation of the BES with respect to transmission system planning and performance.

1.2 Protecting the Interest of Consumers with Respect to Prices

Under the Proposed Standard, results of GMD vulnerability assessments could necessitate significant infrastructure investments to address Corrective Action Plans. If the analysis to support the vulnerability assessments uses data that is not reflective of Ontario’s unique topology, then this could yield unnecessary investments, harming Ontario consumers. These expenditures would be wasted if it

³ NERC Reliability Standards [TPL-007-1](#) and EOP-010-1

turns out, as the result of the SAR process or otherwise, that all or some of these expenditures were unnecessary.

2. Rationale for Request to Stay the Proposed Standard

2.1 Impact on consumers

Please refer to 1.2 above.

The IESO and Hydro One believe that it would be most prudent and responsible to stay the application of the Proposed Standard in Ontario until the SAR process is complete. The GMD-related planning activities of both organizations, and any associated implementation costs, would be better informed and justified if the outcome of the SAR results in the enabling of applicable registered Canadian entities to define and implement an alternative benchmark and/or supplemental GMD event that appropriately reflects their specific geographical and geological characteristics and leverages existing and ongoing Canadian research and development of processes to address GMD events.

Ontario consumers will be harmed if the IESO and Hydro One were, prior to the outcome of the SAR process, required to undertake expenditures on GMD events that may not be reflective of Ontario's unique topology. These expenditures would be wasted if it turns out, as the result of the SAR process or otherwise, that all or some of these expenditures were unnecessary. By contrast, there is no material harm to staying the operation of the Proposed Standard pending the outcome of the SAR process.

2.2 The need to co-ordinate the implementation of the standard in Ontario with other jurisdictions

As noted above, registered entities in other Canadian Shield provinces are supportive of defining and implementing alternative benchmark or supplemental GMD events that appropriately reflect their specific geographical and geological characteristics. They have been working with NRCan, using their own empirical data to develop these alternatives that will form the basis for seeking approval for any required investments from their respective regulatory authorities.

Hydro One and the IESO have stated in the SAR application that Hydro One would be pleased to provide to NERC technical publications to demonstrate the depth of its technical research and expertise in modeling and analyzing GMD impacts.

The IESO and Hydro One strongly believe that continued coordination and consistency with the above mentioned entities is essential in order to understand and address potential GMD impacts

specific to the unique characteristics of the Canadian Shield. Both organizations recommend staying the operation of the Proposed Standard in Ontario pending the outcome of the SAR process.

2.3 The need to co-ordinate the review of the standard in Ontario with regulatory bodies in other jurisdictions that have reviewed, are reviewing or may review the standard and that have the authority to review the standard back to the standards authority for further consideration

As noted above, NERC submitted a petition to FERC (Docket No. RM18-8-000) for approval of the Proposed Standard on January 22, 2018. Enforcement of the Proposed Standard in Ontario is dependent on its review and approval by FERC. The subsequent Ontario enforcement date is dependent on the Proposed Standard being declared in force in the United States, unless its operation is stayed in Ontario by the Board as per this request.

FERC's ruling is uncertain at this time; however, potential outcomes would be: (1) FERC approving the Proposed Standard without any further directives; (2) FERC approving the Proposed Standard and directing NERC to make further modifications; or (3) FERC not approving the Proposed Standard and directing NERC to make further modifications.

Appendix A: Detailed Requirements of Proposed Standard

The Proposed Standard requires the IESO (in collaboration with Hydro One) to perform a benchmark GMD vulnerability assessment and a supplemental GMD vulnerability assessment at least once every 60 calendar months⁴.

The benchmark GMD vulnerability assessment is performed based on a defined benchmark GMD event of 8 V/km. More specifically, the benchmark GMD event is composed of four elements: (1) a reference peak geoelectric field amplitude of 8 V/km derived from statistical analysis of historical magnetometer data; (2) scaling factors to account for local geomagnetic latitude; (3) scaling factors to account for local earth conductivity; and (4) a reference geomagnetic field time series or waveform to facilitate time-domain analysis of GMD impact on BES. The benchmark GMD event elements influence the severity of flow of geo-magnetically induced current (GIC) in the BES system model. The greater the GIC flow, the higher the likelihood of an outcome requiring the development and implementation of a CAP. NERC has developed the benchmark GMD event based on the most conservative approach (i.e., yielding a higher GMD benchmark level and associated higher mitigation costs) to represent a 1-in-100 year GMD event.

The supplemental GMD event is composed of similar elements as the benchmark GMD event except (1) the reference peak geoelectric field amplitude is 12 V/km (50% higher than the benchmark GMD event); and (2) the geomagnetic field time series or waveform includes a local enhancement in the waveform. The intent of performing a supplemental GMD vulnerability assessment is to account for localized impact of a severe GMD event on the BES.

These requirements are proposed notwithstanding that understanding of the GMD phenomena is evolving. It should also be noted that on October 19, 2017, FERC approved NERC GMD Task Force's Research Work Plan (Docket No. RM15-11-002). The EPRI GMD Supplemental Project was included as a specific item in the plan and it involves re-evaluating the latitude scaling and determining whether additional research and validation of models support modification of benchmark and supplemental GMD events.

The Proposed Standard requires Hydro One and other transmitters to develop and implement a CAP if the benchmark GMD vulnerability assessment identifies that Ontario's power system does not meet the performance requirements for steady state planning as described in Table 1 of the Proposed Standard.

⁴ NERC Reliability Standard TPL-007-2 – Requirements R4 and R8 – Page 4 and 9

The potential corrective actions can be divided into two categories: non-hardware and hardware mitigations. Updating GMD operating plans is an example of non-hardware mitigation and installing mitigating devices on the transformer neutral is an example of hardware mitigation. The proposed timelines will require Hydro One to complete the CAP within two years of development of the CAP for non-hardware mitigation actions; and within four years of development of the CAP for hardware mitigation actions.

Non-hardware mitigations are usually the first step in addressing GMD vulnerabilities. It is accomplished by developing operating plans that utilize existing system resources to address GMD events or allow for temporary outages, interruptions, or load losses to mitigate the impacts of a GMD event. Depending on the outcome of the benchmark GMD vulnerability assessment and its relevance to the IESO's grid operational policy, hardware mitigations may be required. Installation of hardware mitigations may require careful engineering studies, outage management and co-ordination with other market participants including generators.

Appendix B: Petition of NERC to the Board for Approval of TPL-007-2

NERCNORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

February 27, 2018

VIA ELECTRONIC FILING

Kirsten Walli, Board Secretary
Ontario Energy Board
P.O Box 2319
2300 Yonge Street
Toronto, Ontario, Canada
M4P 1E4

Re: *North American Electric Reliability Corporation*

Dear Ms. Walli:

The North American Electric Reliability Corporation hereby submits Petition of the North American Electric Reliability Corporation for Approval of Proposed Reliability Standard TPL-007-2. NERC requests, to the extent necessary, a waiver of any applicable filing requirements with respect to this filing.

Please contact the undersigned if you have any questions concerning this filing.

Respectfully submitted,

/s/ Shamai Elstein

Shamai Elstein
*Senior Counsel for the North American Electric
Reliability Corporation*

Enclosure

3353 Peachtree Road NE
Suite 600, North Tower
Atlanta, GA 30326
404-446-2560 | www.nerc.com

**ONTARIO ENERGY BOARD
OF THE PROVINCE OF ONTARIO**

**NORTH AMERICAN ELECTRIC)
RELIABILITY CORPORATION)**

**PETITION OF THE
NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION
FOR APPROVAL OF PROPOSED RELIABILITY STANDARD
TPL-007-2**

Charles Berardesco
Interim President and Chief Executive Officer
North American Electric Reliability
Corporation
1325 G Street, N.W., Suite 600
Washington, DC 20005
(202) 400-3000
(202) 644-8099 – facsimile
charles.berardesco@nerc.net

Shamai Elstein
Senior Counsel
Lauren A. Perotti
Counsel
Candice Castaneda
Counsel
North American Electric Reliability
Corporation
1325 G Street, N.W., Suite 600
Washington, DC 20005
(202) 400-3000
(202) 644-8099 – facsimile
shamai.elstein@nerc.net
lauren.perotti@nerc.net
candice.castaneda@nerc.net

*Counsel for the North American Electric
Reliability Corporation*

February 27, 2018

TABLE OF CONTENTS

I. EXECUTIVE SUMMARY	2
II. NOTICES AND COMMUNICATIONS	4
III. BACKGROUND	4
A. NERC Reliability Standards Development Procedure	4
B. Procedural History of Proposed Reliability Standard TPL-007-2	5
1. History of Reliability Standard TPL-007-1 and Order No. 830	5
2. Project 2013-03 Geomagnetic Disturbance Mitigation	7
IV. JUSTIFICATION FOR APPROVAL	8
A. The Supplemental GMD Event.....	9
B. New and Revised Requirements to Perform GMD Vulnerability Assessments Based on the Supplemental GMD Event.....	12
1. Proposed Requirement R8	12
2. Proposed Requirements R9 and R10	14
C. New Requirements for the Collection of GMD Data (R11 and R12).....	16
D. Revised Deadlines for Corrective Action Plans in Requirement R7	17
E. Enforceability of Proposed Reliability Standard TPL-007-2.....	22
V. EFFECTIVE DATE.....	23
VI. PROPOSED PROJECT TO DEVELOP A TPL-007-2 VARIANCE FOR CANADA.....	24
VII. UPDATE ON NERC’S ONGOING GMD RESEARCH WORK PLAN AND SECTION 1600 GMD DATA REQUEST ACTIVITIES	24
VIII. CONCLUSION.....	27

Exhibit A	Proposed Reliability Standard TPL-007-2 – Transmission System Planned Performance for Geomagnetic Disturbance Operations
Exhibit B	Implementation Plan for Proposed Reliability Standard TPL-007-2
Exhibit C	Analysis of Violation Risk Factors and Violation Severity Levels
Exhibit D	Summary of Development History and Complete Record of Development
Exhibit E	Reliability Standards Criteria for Proposed Reliability Standard TPL-007-2
Exhibit F	Standard Drafting Team Roster for Project 2013-03

TABLE OF CONTENTS

Exhibit G	Transformer Thermal Impact Assessment White Paper
Exhibit H	Screening Criterion for Transformer Thermal Impact Assessment White Paper
Exhibit I	Supplemental GMD Event Description White Paper
Exhibit J	Consideration of Directives

**ONTARIO ENERGY BOARD
OF THE PROVINCE OF ONTARIO**

**NORTH AMERICAN ELECTRIC)
RELIABILITY CORPORATION)**

**PETITION OF THE
NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION
FOR APPROVAL OF PROPOSED RELIABILITY STANDARD TPL-007-2**

The North American Electric Reliability Corporation (“NERC”) hereby requests approval of proposed Reliability Standard TPL-007-2 (*Transmission System Planned Performance for Geomagnetic Disturbance Events*) (Exhibit A), the associated implementation plan (Exhibit B), the Violation Risk Factors (“VRFs”) and Violation Severity Levels (“VSLs”) (Exhibit C), and the retirement of currently-effective Reliability Standard TPL-007-1. The NERC Board of Trustees (“Board”) adopted proposed Reliability Standard TPL-007-2 on November 9, 2017.

Proposed Reliability Standard TPL-007-2 requires owners and operators of the Bulk Power System (“BPS”) to conduct initial and on-going vulnerability assessments of the potential impact of defined geomagnetic disturbance (“GMD”) events on BPS equipment and the BPS as a whole. The modifications in the proposed standard address the Federal Energy Regulatory Commission’s (“FERC”) directives in Order No. 830.¹ The modifications also improve upon the currently-effective version of the standard by using the latest developments in GMD research to provide enhanced criteria and requirements to address reliability risks arising from GMDs, including the risks posed by severe, localized events.

The proposed Reliability Standard and related elements are just, reasonable, not unduly discriminatory or preferential, and in the public interest. The proposed standard shall be effective in accordance with the proposed implementation plan (Exhibit B). As described in further detail

¹ *Reliability Standard for Transmission System Planned Performance for Geomagnetic Disturbance Events*, Order No. 830, 156 FERC ¶ 61,215, P 1 (2016), *reh’g denied*, Order No. 830-A, 158 FERC ¶ 61,041 (2017).

herein, the proposed implementation plan is intended to integrate the new requirements in TPL-007-2 with the GMD Vulnerability Assessment² process that is currently being implemented through the currently-effective version of the standard.

This filing presents the technical basis and purpose of proposed Reliability Standard TPL-007-2 (Exhibits A – D and Exhibits G – J), a summary of the development history (Exhibit D), and a demonstration that the proposed Reliability Standard meets the Reliability Standards criteria.

I. EXECUTIVE SUMMARY

Proposed Reliability Standard TPL-007-2 adds enhancements to the currently-effective GMD planning standard, Reliability Standard TPL-007-1, to better address risks to reliability posed by GMDs and to implement FERC’s directives in Order No. 830. In Order No. 830, FERC approved Reliability Standard TPL-007-1 and directed NERC to modify the standard as follows:

- ∞ revise the benchmark GMD event used for GMD Vulnerability Assessments so that the reference peak geoelectric field amplitude component is not based solely on spatially-averaged data;³
- ∞ revise Requirement R6 to require entities to apply spatially averaged and non-spatially averaged peak geoelectric field values, or some equally efficient and effective alternative, when conducting transformer thermal impact assessments;⁴
- ∞ require entities to collect data from geomagnetically induced current (“GIC”) monitors and magnetometers as necessary to enable model validation and situational awareness;⁵ and
- ∞ require entities to develop any necessary Corrective Action Plans within one year from the completion of the GMD Vulnerability Assessment, include a two-year

² Unless otherwise designated, all capitalized terms shall have the meaning set forth in the *Glossary of Terms Used in NERC Reliability Standards*, available at http://www.nerc.com/files/Glossary_of_Terms.pdf.

³ See Order No. 830 at P 44.

⁴ *Id.* at P 65.

⁵ *Id.* at P 88.

deadline for the implementation of non-hardware mitigation, and include a four-year deadline to complete hardware mitigation.⁶

Proposed Reliability Standard TPL-007-2 reflects the latest in GMD understanding and provides a technically sound and flexible approach to addressing the items of concern noted by FERC in Order No. 830. The proposed standard addresses FERC's directives by:

- ∞ requiring entities to perform supplemental GMD Vulnerability Assessments based on the supplemental GMD event, a second defined event that accounts for localized peak effects of GMDs and which is based on individual station measurements (i.e. not spatially-averaged data);
- ∞ requiring entities to perform supplemental thermal impact assessments of applicable power transformers based on GIC information for the supplemental GMD event;
- ∞ requiring entities to implement process(es) to obtain GIC monitor and magnetometer data; and
- ∞ implementing the deadlines specified by FERC in Order No. 830 for the development and completion of any necessary Corrective Action Plans to address system performance issues resulting from the benchmark GMD event.

As discussed in detail below, these revisions would enhance reliability by expanding GMD Vulnerability Assessments to include severe, localized impacts and by implementing new deadlines and processes to maintain accountability in the development, completion, and revision of entity Corrective Action Plans developed to address identified vulnerabilities. Further, the proposed revisions would improve the availability of GMD monitoring data that may be used to inform GMD Vulnerability Assessments. Through its ongoing GMD work, including the GMD Research Work Plan⁷ and a forthcoming Request for Data or Information pursuant to Section

⁶ *Id.* at P 101-102.

⁷ Consistent with Order No. 830, NERC filed a preliminary work plan to conduct research on topics related to GMDs and their impacts on the reliability of the BPS (the "GMD Research Work Plan"). *See Geomagnetic Disturbance Research Work Plan of the North American Electric Reliability Corporation*, (June 5, 2017). In

1600 of the NERC Rules of Procedure (“Section 1600 GMD Data Request”),⁸ NERC expects to obtain useful inputs for continued evaluation of the technical basis that underpins the proposed standard.

For these reasons and as discussed more fully in this filing, the proposed standard is just, reasonable, not unduly discriminatory or preferential, and in the public interest.

II. NOTICES AND COMMUNICATIONS

Notices and communications with respect to this filing may be addressed to:

Shamai Elstein
Senior Counsel
Lauren Perotti
Counsel
Candice Castaneda
Counsel
North American Electric Reliability
Corporation
1325 G Street, N.W., Suite 600
Washington, DC 20005
(202) 400-3000
(202) 644-8099 – facsimile
shamai.elstein@nerc.net
lauren.perotti@nerc.net
candice.castaneda@nerc.net

Howard Gugel
Senior Director of Standards
North American Electric Reliability
Corporation
3353 Peachtree Road, N.E.
Suite 600, North Tower
Atlanta, GA 30326
(404) 446-2560
Howard.Gugel@nerc.net

III. BACKGROUND

A. NERC Reliability Standards Development Procedure

The proposed Reliability Standard was developed in an open and fair manner and in accordance with the Reliability Standard development process. NERC develops Reliability

accordance with FERC’s October 19, 2017 *Order on GMD Research Work Plan*, NERC will file a final or otherwise updated GMD Research Work Plan on or before April 2018.

⁸ NERC Rules of Procedure Section 1600. The NERC Rules of Procedure are available at <http://www.nerc.com/AboutNERC/Pages/Rules-of-Procedure.aspx>.

Standards in accordance with Section 300 (Reliability Standards Development) of its Rules of Procedure and the NERC Standard Processes Manual.⁹

NERC's proposed rules provide for reasonable notice and opportunity for public comment, due process, openness, and a balance of interests in developing Reliability Standards, and thus satisfy certain of the criteria for approving Reliability Standards. The development process is open to any person or entity with a legitimate interest in the reliability of the BPS. NERC considers the comments of all stakeholders, and stakeholders must approve, and the NERC Board of Trustees must adopt, a Reliability Standard before the Reliability Standard is submitted to the applicable governmental authorities.

B. Procedural History of Proposed Reliability Standard TPL-007-2

This section summarizes the development history of proposed Reliability Standard TPL-007-2.

1. History of Reliability Standard TPL-007-1 and Order No. 830

On March 3, 2015, NERC filed a petition requesting approval of Reliability Standard TPL-007-1, the second-stage GMD Reliability Standard contemplated by FERC in Order No. 779.¹⁰ Reliability Standard TPL-007-1 requires applicable entities to conduct initial and ongoing assessments of the potential impact of a 1-in-100 year benchmark GMD event on BPS equipment and the BPS as a whole. FERC approved Reliability Standard TPL-007-1 in Order No. 830,

⁹ The ROP is available at <http://www.nerc.com/AboutNERC/Pages/Rules-of-Procedure.aspx>. The NERC *Standard Processes Manual* is available at http://www.nerc.com/comm/SC/Documents/Appendix_3A_StandardsProcessesManual.pdf.

¹⁰ *Petition of the North American Electric Reliability Corporation for Approval of Reliability Standard TPL-007-1 Transmission System Planned Performance for Geomagnetic Disturbance Events*, 0 (March 3, 2015); *Reliability Standards for Geomagnetic Disturbances*, Order No. 779, 78 Fed. Reg. 30,747 (May 23, 2013), 143 FERC ¶ 61,147, *reh'g denied*, 144 FERC ¶ 61,113 (2013) (directing the development of Reliability Standards to address GMDs in two stages).

issued on September 22, 2016, stating that the standard “constitutes an important step in addressing the risks posed by GMD events to the Bulk-Power System.”¹¹ FERC also directed four revisions to the standard to address areas of concern noted in the order and underlying proceeding.

First, noting its concerns with the reliance on spatially averaged data in the TPL-007-1 benchmark GMD event definition, FERC directed NERC to “develop revisions to the benchmark GMD event definition so that the reference peak geoelectric field amplitude component is not based solely on spatially-averaged data.”¹² FERC also directed NERC to revise Requirement R6 “to require registered entities to apply spatially averaged and non-spatially averaged peak geoelectric field values, or some equally and efficient alternative, when conducting thermal impact assessments.”¹³

Next, FERC directed NERC to revise TPL-007-1 to require entities “to collect GIC monitoring and magnetometer data as necessary to enable model validation and situational awareness, including from any devices that must be added to meet this need.”¹⁴ FERC stated that “additional collection and disclosure of GIC monitoring and magnetometer data is necessary to improve our collective understanding of the threats posed by GMD events.”¹⁵ Lastly, FERC directed NERC to modify TPL-007-1 requirements for Corrective Action Plans to include: (i) a one-year deadline for the development of any necessary Corrective Action Plans; (ii) a two-year

¹¹ Order No. 830 at P 1.

¹² Order No. 830 at P 44.

¹³ *Id.* at P 65.

¹⁴ *Id.* at P 88.

¹⁵ *Id.*

deadline for the implementation of non-hardware mitigation; and (iii) a four-year deadline for the implementation of hardware mitigation.¹⁶

In addition to these standard modification directives, FERC also directed NERC to undertake certain activities to improve understanding of GMDs and their potential impacts on power systems. First, FERC directed NERC to submit a work plan describing how NERC would research specific GMD-related topics identified by FERC and other topics at NERC's discretion.¹⁷ Second, FERC directed NERC to collect GIC and magnetometer data pursuant to Section 1600 of the NERC Rules of Procedure, including existing data for the period beginning May 2013 and new data going forward, and to make that information available to support ongoing GMD research and analysis.¹⁸

This filing describes how proposed Reliability Standard TPL-007-2 addresses the standard modification directives described above. NERC continues its efforts to address FERC's work plan and data collection directives and provides a status update on those efforts in Section VI, below. NERC anticipates that the results of these efforts will inform future reviews of the proposed Reliability Standard.

2. Project 2013-03 Geomagnetic Disturbance Mitigation

Shortly after the issuance of Order No. 830, NERC initiated a new phase of Project 2013-03 to address FERC's directives to modify Reliability Standard TPL-007-1. As with prior phases of the project, the standard drafting team for this phase consisted of individuals with extensive planning, engineering, and scientific knowledge and experience. To provide technical support for proposed Reliability Standard TPL-007-2, the standard drafting team developed new and updated

¹⁶ *Id.* at PP 101-102.

¹⁷ *See generally id.* at P 77.

¹⁸ Order No. 830 at PP 89, 93.

supporting materials, including the Supplemental GMD Event Description White Paper (Exhibit I), Screening Criterion for Transformer Thermal Impact Assessment White Paper (Exhibit H), and Transformer Thermal Impact Assessment White Paper (Exhibit G).

Proposed Reliability Standard TPL-007-2 was posted for initial ballot from June 28, 2017 to August 11, 2017 and for final ballot from October 20, 2017 to October 30, 2017. The NERC Board of Trustees adopted the proposed standard on November 9, 2017. The complete development history of proposed Reliability Standard TPL-007-2 is attached as Exhibit D.

IV. JUSTIFICATION FOR APPROVAL

As discussed below and in Exhibit E, proposed Reliability Standard TPL-007-2 satisfies the Reliability Standards criteria and is just, reasonable, not unduly discriminatory or preferential, and in the public interest. The proposed Reliability Standard contains significant benefits for the BPS and addresses FERC's directives from Order No. 830.

The purpose of proposed Reliability Standard TPL-007-2, which remains unchanged from currently-effective Reliability Standard TPL-007-1, is to “[e]stablish requirements for Transmission system planned performance during geomagnetic disturbance (GMD) events.” The applicability of the proposed standard also remains unchanged from TPL-007-1: the proposed standard would continue to apply to: (1) Planning Coordinators and Transmission Planners whose planning areas have a Facility that includes a power transformer with a high side, wye-grounded winding with terminal voltage greater than 200 kV¹⁹; and (2) Transmission Owners and Generator Owners that own a Facility that includes such equipment.

Currently-effective Reliability Standard TPL-007-1 requires entities to conduct initial and on-going assessments of the potential impact of the defined benchmark GMD event on BPS

¹⁹ A power transformer with a “high side wye-grounded winding” refers to a power transformer with windings on the high voltage side that are connected in a wye configuration and have a grounded neutral connection.

equipment and the BPS as a whole. Proposed Reliability Standard TPL-007-2 builds upon these Requirements and adds new Requirements for entities to assess their vulnerabilities to a second defined event, the supplemental GMD event. This supplemental GMD event is designed to account for the localized peak effects of severe GMD events on systems and equipment. The proposed standard also contains new Requirements for the collection of GIC and magnetometer data. Lastly, the proposed standard revises Requirement R7 to include deadlines for the development and completion of any necessary Corrective Action Plans. Each of these revisions and how they address FERC's directives from Order No. 830 is discussed below.

A. The Supplemental GMD Event

Proposed Reliability Standard TPL-007-2 contains new Requirements for entities to assess their vulnerabilities to a second defined GMD event, the supplemental GMD event. As described in the Supplemental GMD Event Description White Paper (Exhibit I), geomagnetic fields during severe GMD events can be spatially non-uniform with higher and lower strengths across a geographic region. The supplemental GMD event, which was derived using individual station measurements rather than spatially averaged measurements, includes localized enhancement of field strength above the average value. As such, the proposed standard addresses FERC's directive in Order No. 830 to revise the GMD standard to account for the effects of localized peaks that could potentially affect reliable operations.²⁰

²⁰ See Order No. 830 at P 44 ("The Commission...directs NERC to develop revisions to the benchmark GMD event definition so that the reference peak geoelectric field amplitude component is not based solely on spatially-averaged data."). See also Order No. 830 at P 47 ("Without pre-judging how NERC proposes to address the Commission's directive, NERC's response to this directive should satisfy the NOPR's concern that reliance on spatially-averaged data alone does not address localized peaks that could potentially affect the reliable operation of the Bulk-Power System.")

The benchmark GMD event and the supplemental GMD event are similar in structure but the supplemental GMD event contains several differences to account for localized impacts. Like the benchmark GMD event, the supplemental GMD event defines the geomagnetic and geoelectric field values used to compute GIC flows for use in a GMD Vulnerability Assessment. The benchmark GMD event is composed of the following components:

- ∞ a reference peak geoelectric field amplitude of 8 V/km derived from statistical analysis of historical magnetometer data;
- ∞ scaling factors to account for local geomagnetic latitude;
- ∞ scaling factors to account for local earth conductivity; and
- ∞ a reference geomagnetic field time series or waveform to facilitate time-domain analysis of GMD impact on equipment.

The supplemental GMD event has the same components, except that the reference peak geoelectric field amplitude is 12 V/km over a localized area (compared to 8 V/km) and the geomagnetic field time series or waveform includes a local enhancement.²¹ These distinguishing characteristics of the supplemental GMD event are intended to represent conditions associated with localized enhancement of the geomagnetic field during a severe GMD event for use in assessing GMD impacts.

In developing the supplemental GMD event, the standard drafting team used data and information so that the peak geoelectric field does not rely on spatial averaging of geomagnetic field data. Like the value in the approved benchmark GMD event, the supplemental GMD event peak geoelectric field is a 1-in-100 year extreme value determined using statistical analysis of historical geomagnetic field data. The fundamental difference in the supplemental GMD event

²¹ See proposed Reliability Standard TPL-007-2 Attachment 1. See also Supplemental GMD Event Description White Paper (Exhibit I). The addition of a local enhancement to the supplemental GMD event waveform also causes some small changes in earth conductivity scaling factors, as explained in the white paper. These earth conductivity scaling factors for the supplemental GMD event are included in proposed TPL-007-2 Attachment 1.

amplitude is that it is based on geomagnetic field observations taken at individual observation stations (i.e., localized measurements), instead of the spatially averaged geoelectric fields used in the benchmark GMD event. The result of the extreme value analysis shows that the supplemental GMD event peak of 12 V/km is above the upper limit of the 95 percent confidence interval for a 100-year return interval, while the same confidence interval with spatially-averaged data (i.e., the benchmark GMD event) is 8 V/km. Thus, GMD Vulnerability Assessments based on the 12 V/km peak geoelectric field of the proposed supplemental GMD event are considering extreme localized conditions associated with a 1-in-100 year severe GMD event.

Similar to the benchmark GMD event, the supplemental GMD event includes a waveform for assessing transformer thermal impacts from a severe GMD event. Both the benchmark and supplemental GMD event waveforms are based on 10-second sampling interval magnetic field data from the Ottawa observatory recorded during the March 13-14, 1989 GMD event. The supplemental GMD event waveform is more severe than the benchmark GMD event waveform because it includes a five-minute duration enhanced peak up to 12 V/km for the reference earth model and 60 degree geomagnetic latitude. This synthetic enhancement represents the observed localized, rapid magnetic field variation periods associated with ionospheric sources during some severe GMD events. Such GMD conditions could result in increased transformer heating for short durations during a severe GMD event due to increased GIC flows.

The supplemental GMD event provides a technically justified method of assessing vulnerabilities to the localized peak effects of severe GMD events, thereby addressing FERC's Order No. 830 directive. Together, the approved benchmark GMD event and the proposed supplemental GMD event provide a high threshold for assessing GMD impacts.

B. New and Revised Requirements to Perform GMD Vulnerability Assessments Based on the Supplemental GMD Event

Proposed TPL-007-2 adds new Requirements R8, R9, and R10 to require responsible entities to assess the potential implications of the supplemental GMD event described above on their equipment and systems in accordance with FERC's directives in Order No. 830.²² The proposed Requirements are structured and worded similarly to approved Requirements R4 through R6, which require entities to assess the impact of the benchmark GMD event. With the addition of these new Requirements, NERC proposes minor revisions to Requirements R4 through R6 to clarify that those existing Requirements pertain to assessments based on the benchmark GMD event. NERC also proposes revisions to Requirements R1 through R3 to include appropriate references to the supplemental GMD event. These minor revisions are shown in Exhibit A (redline).

1. Proposed Requirement R8

Proposed Requirement R8 would require responsible entities to complete a supplemental GMD Vulnerability Assessment of the Near-Term Transmission Planning Horizon at least once every five years. The proposed Requirement reads as follows:

- R8.** Each responsible entity, as determined in Requirement R1, shall complete a supplemental GMD Vulnerability Assessment of the Near-Term Transmission Planning Horizon at least once every 60 calendar months. This supplemental GMD Vulnerability Assessment shall use a study or studies based on models identified in Requirement R2, document assumptions, and document summarized results of the steady state analysis.
- 8.1.** The study or studies shall include the following conditions:
 - 8.1.1.** System On-Peak Load for at least one year within the Near-Term Transmission Planning Horizon; and
 - 8.1.2.** System Off-Peak Load for at least one year within the Near-Term Transmission Planning Horizon.
 - 8.2.** The study or studies shall be conducted based on the supplemental GMD event described in Attachment 1 to determine whether the System meets the

²² See Order No. 830 at P 44 (benchmark GMD event definition) and P 65 (transformer thermal impact assessments).

performance requirements for the steady state planning supplemental GMD event contained in Table 1.

- 8.3.** If the analysis concludes there is Cascading caused by the supplemental GMD event described in Attachment 1, an evaluation of possible actions designed to reduce the likelihood or mitigate the consequences and adverse impacts of the event(s) shall be conducted.
- 8.4.** The supplemental GMD Vulnerability Assessment shall be provided: (i) to the responsible entity's Reliability Coordinator, adjacent Planning Coordinators, adjacent Transmission Planners within 90 calendar days of completion, and (ii) to any functional entity that submits a written request and has a reliability-related need within 90 calendar days of receipt of such request or within 90 calendar days of completion of the supplemental GMD Vulnerability Assessment, whichever is later.
 - 8.4.1.** If a recipient of the supplemental GMD Vulnerability Assessment provides documented comments on the results, the responsible entity shall provide a documented response to that recipient within 90 calendar days of receipt of those comments.

Proposed Requirement R8 mirrors Requirement R4, which requires entities to complete a GMD Vulnerability Assessment based on the benchmark GMD event, but with one key difference. Proposed Requirement R8 contains an additional Part, Part 8.3, which provides that if analysis concludes there would be Cascading caused by the supplemental GMD event, the responsible entity must then evaluate possible actions to reduce the likelihood or mitigate consequences and adverse impacts of the event. As discussed more fully in Section IV.D below, the standard drafting team determined that requiring such an evaluation of possible actions, as opposed to a formal Corrective Action Plan, would provide a more prudent approach in light of the limitations of currently-available tools for modeling localized GMD effects.

New language is reflected in proposed Requirement R8 Part 8.4 to clarify the timeframe for providing completed supplemental GMD Vulnerability Assessments to the Reliability Coordinator, neighboring Planning Coordinators and Transmission Planners, and to the other functional entities with a reliability-related need that submit a request. To provide for

consistency across similar Requirements, conforming revisions are proposed in TPL-007-2 Requirement R4 Part 4.3 pertaining to benchmark GMD Vulnerability Assessments.

2. Proposed Requirements R9 and R10

Proposed Requirements R9 and R10 pertain to supplemental transformer thermal impact assessments. As these Requirements are based on the supplemental GMD event described above, they address FERC's directive to revise the standard to require entities to apply non spatially-averaged peak geoelectric field values when conducting thermal impact assessments.²³

Proposed Requirement R9 would require responsible entities to provide GIC flow information based on the supplemental GMD event to owners of applicable BES power transformers in the planning area. The proposed Requirement mirrors existing Requirement R5 pertaining to GIC flow information for the benchmark GMD event. Proposed Requirement R9 reads as follows:

- R9.** Each responsible entity, as determined in Requirement R1, shall provide GIC flow information to be used for the supplemental thermal impact assessment of transformers specified in Requirement R10 to each Transmission Owner and Generator Owner that owns an applicable Bulk Electric System (BES) power transformer in the planning area. The GIC flow information shall include:
- 9.1.** The maximum effective GIC value for the worst case geoelectric field orientation for the supplemental GMD event described in Attachment 1. This value shall be provided to the Transmission Owner or Generator Owner that owns each applicable BES power transformer in the planning area.
 - 9.2.** The effective GIC time series, GIC(t), calculated using the supplemental GMD event described in Attachment 1 in response to a written request from the Transmission Owner or Generator Owner that owns an applicable BES power transformer in the planning area. GIC(t) shall be provided within 90 calendar days of receipt of the written request and after determination of the maximum effective GIC value in Part 9.1.

²³ Order No. 830 at P 65.

Proposed Requirement R10 would require each Transmission Owner and Generator Owner to conduct a supplemental thermal impact assessment for solely and jointly owned applicable BES power transformers where the maximum effective GIC value resulting from Requirement R9 is above a specific threshold. The proposed Requirement reads as follows:

- R10.** Each Transmission Owner and Generator Owner shall conduct a supplemental thermal impact assessment for its solely and jointly owned applicable BES power transformers where the maximum effective GIC value provided in Requirement R9, Part 9.1, is 85 A per phase or greater. The supplemental thermal impact assessment shall:
- 10.1.** Be based on the effective GIC flow information provided in Requirement R9;
 - 10.2.** Document assumptions used in the analysis;
 - 10.3.** Describe suggested actions and supporting analysis to mitigate the impact of GICs, if any; and
 - 10.4.** Be performed and provided to the responsible entities, as determined in Requirement R1, within 24 calendar months of receiving GIC flow information specified in Requirement R9, Part 9.1.

Proposed Requirement R10 mirrors existing Requirement R6 pertaining to transformer thermal impact assessments based on the benchmark GMD event. However, for the supplemental thermal impact assessment, the threshold is a maximum effective GIC value of 85 A per phase or greater (compared to the benchmark threshold of 75 A per phase or greater). As described in greater detail in the Screening Criterion for Transformer Thermal Impact Assessment White Paper (Exhibit H), the threshold value is determined using the same methods employed for the benchmark thermal impact assessments and provides that assessments be performed on all applicable power transformers that could potentially exceed emergency loading temperature guidelines.²⁴

²⁴ See generally Exhibit H and Institute of Electrical and Electronic Engineers (IEEE) Standard C57.91-2011 – Guide for Loading Mineral-Oil-Immersed Transformers and Step-Voltage Regulators.

C. New Requirements for the Collection of GMD Data (R11 and R12)

In Order No. 830, FERC directed NERC to “develop revisions to Reliability Standard TPL-007-1 to require responsible entities to collect GIC monitoring and magnetometer data as necessary to enable model validation and situational awareness, including from any devices that must be added to meet this need.”²⁵ Consistent with this directive, proposed TPL-007-2 contains two new Requirements, Requirements R11 and R12, that would require responsible entities to implement a process to obtain GIC monitor and geomagnetic field data for their planning area or system model area. The Requirements apply to Planning Coordinators and Transmission Planners, as determined in Requirement R1, because these entities are responsible for maintaining GIC System models (Requirement R2). Entities may use the data for validating GIC system models as well as for awareness of local geomagnetic conditions and measured GIC levels.

Proposed Requirement R11 would require responsible entities to implement a process to obtain GIC monitor data as follows:

R11. Each responsible entity, as determined in Requirement R1, shall implement a process to obtain GIC monitor data from at least one GIC monitor located in the Planning Coordinator’s planning area or other part of the system included in the Planning Coordinator’s GIC System model.

Consistent with FERC’s guidance,²⁶ collection criteria are included in the Supplemental Material section of the proposed standard to promote consistency and provide entities with flexibility to tailor procedures to their planning area. The guidance for GIC data collection addresses monitor locations, monitor specifications, sampling interval, collection periods, data format, and data retention.

²⁵ Order No. 830 at P 88.

²⁶ *See id.* at P 91 (regarding criteria for NERC to consider in developing a requirement for the collection of GIC monitoring data).

Proposed Requirement R12 would require responsible entities to implement a process to obtain geomagnetic field data as follows:

R12. Each responsible entity, as determined in Requirement R1, shall implement a process to obtain geomagnetic field data for its Planning Coordinator's planning area.

By requiring responsible entities to obtain geomagnetic field data for their planning areas, the proposed Requirement would ensure that data is obtained from diverse geographic areas of the North American BPS. Entities are advised to obtain data from the nearest accessible magnetometer. Sources of magnetometer data include government observatories, installed equipment owned or operated by the entity, and third party sources, including research institutions and universities. Entities that choose to install their own magnetometers are referred to the *INTERMAGNET Technical Reference Manual* for equipment specifications and data format protocols.

Proposed Reliability Standard TPL-007-2 supports future data collection across the North American BPS by requiring planning entities to implement processes for obtaining GMD data for each planning area. NERC, pursuant to the pending Section 1600 GMD Data Request,²⁷ will collect GMD data from entities and make that data available to support ongoing research and analysis of GMD risk. The proposed standard, together with the pending Section 1600 GMD Data Request, would thus satisfy FERC's data collection directives in Order No. 830 and provide data to help address the potential reliability risks posed by GMDs.

D. Revised Deadlines for Corrective Action Plans in Requirement R7

NERC proposes to revise Requirement R7 to include the FERC-directed deadlines for the development and completion of any required Corrective Action Plans to address system

²⁷ See Section VI *infra*.

performance issues for the benchmark GMD event. In Order No. 830, FERC directed NERC to modify the TPL-007 standard to include the following deadlines:

- ∞ one year from the completion of the GMD Vulnerability Assessment to complete the development of a Corrective Action Plan;
- ∞ two years after the development of the Corrective Action Plan to complete the implementation of non-hardware mitigation; and
- ∞ four years after the development of the Corrective Action Plan to complete hardware mitigation.²⁸

Proposed TPL-007-2 Requirement R7 revises the existing standard to incorporate these directives as follows:

- R7.** Each responsible entity, as determined in Requirement R1, that concludes, through the benchmark GMD Vulnerability Assessment conducted in Requirement R4, that their System does not meet the performance requirements ~~of~~ for the steady state planning benchmark GMD event contained in Table 1, shall develop a Corrective Action Plan (CAP) addressing how the performance requirements will be met. The ~~Corrective Action Plan~~ CAP shall:
- 7.1.** List System deficiencies and the associated actions needed to achieve required System performance. Examples of such actions include:
 - ∞ Installation, modification, retirement, or removal of Transmission and generation Facilities and any associated equipment.
 - ∞ Installation, modification, or removal of Protection Systems or ~~Special Protection Systems~~ Remedial Action Schemes.
 - ∞ Use of Operating Procedures, specifying how long they will be needed as part of the ~~Corrective Action Plan~~ CAP.
 - ∞ Use of Demand-Side Management, new technologies, or other initiatives.
 - 7.2.** Be ~~reviewed in subsequent~~ developed within one year of completion of the benchmark GMD Vulnerability Assessments until it is determined that the System meets the performance requirements contained in Table 1.
 - 7.3.** Include a timetable, subject to revision by the responsible entity in Part 7.4, for implementing the selected actions from Part 7.1. The timetable shall:
 - 7.3.1.** Specify implementation of non-hardware mitigation, if any, within two years of development of the CAP; and
 - 7.3.2.** Specify implementation of hardware mitigation, if any, within four years of development of the CAP.

²⁸

Order No. 830 at PP 101-102.

- 7.4. Be revised if situations beyond the control of the responsible entity determined in Requirement R1 prevent implementation of the CAP within the timetable for implementation provided in Part 7.3. The revised CAP shall document the following, and be updated at least once every 12 calendar months until implemented:
- 7.4.1. Circumstances causing the delay for fully or partially implementing the selected actions in Part 7.1;
- 7.4.2. Description of the original CAP, and any previous changes to the CAP, with the associated timetable(s) for implementing the selected actions in Part 7.1; and
- 7.4.3. Revisions to the selected actions in Part 7.1, if any, including utilization of Operating Procedures if applicable, and the updated timetable for implementing the selected actions.
- ~~7.3.7.5.~~ Be provided within 90 calendar days of completion: (i) to the responsible entity's Reliability Coordinator, adjacent Planning Coordinator(s), adjacent Transmission Planner(s), and functional entities referenced in the ~~Corrective Action Plan~~ CAP within 90 calendar days of development or revision, and (ii) to any functional entity that submits a written request and has a reliability-related need within 90 calendar days of receipt of such request or within 90 calendar days of development or revision, whichever is later.
- ~~7.3.17.5.1.~~ If a recipient of the ~~Corrective Action Plan~~ CAP provides documented comments on the results, the responsible entity shall provide a documented response to that recipient within 90 calendar days of receipt of those comments.

Revised Requirement R7 Part 7.2 would require responsible entities to develop a Corrective Action Plan within one year of the benchmark GMD Vulnerability Assessment, if the entity concludes that its System does not meet the performance requirements for the steady state planning benchmark GMD event. Under new Requirement R7 Part 7.3, the Corrective Action Plan shall include a timeline that specifies the completion of non-hardware and hardware mitigation within two and four years of development of the Corrective Action Plan, respectively.

In accordance with FERC's directive, the proposed standard requires entities to take prompt action to address any vulnerabilities they identify in their systems. The proposed standard recognizes, however, that there may be circumstances outside of an entity's control that could prevent the completion of a mitigation activity by the specified timetable. Such events could

include, for example: delays due to the regulatory or legal processes, such as permitting; delays from stakeholder processes required by tariffs; delays resulting from equipment lead times; or delays resulting from the inability to acquire necessary right-of-way. In such circumstances, an entity may maintain compliance with the standard by revising its Corrective Action Plan in accordance with Requirement R7 Part 7.4.

Under Part 7.4, the entity shall revise its Corrective Action Plan if events beyond its control prevent implementation of the Corrective Action Plan within the original timetable. In the revised Corrective Action Plan, the responsible entity must provide justification for its revised timetable by documenting: (1) the circumstances causing the delay; (2) description of the original Corrective Action Plan and any changes; and (3) revisions to selected actions, including the use of any operating procedures if applicable, along with an updated timetable for completion. The revised Corrective Action Plan shall be updated at least annually. The responsible entity must then provide its revised Corrective Action Plan to recipients of the original Corrective Action Plan (i.e., Reliability Coordinator, adjacent Planning Coordinator(s), adjacent Transmission Planner(s), functional entities referenced in the Corrective Action Plan, and any functional entity that submits a written request and has a reliability related need for the information.) Thus, Requirement R7 would implement the FERC-directed deadlines for Corrective Action Plans and mitigation, along with a process to maintain accountability and communication with affected entities when circumstances beyond a responsible entity's control affect the entity's ability to complete implementation within the original deadlines.

This approach is consistent with other Reliability Standards. For example, Reliability Standard FAC-003-4 Requirement R7 provides that an entity may modify its annual vegetation work plan in light of circumstances beyond the entity's control, such as a natural disaster or other

circumstance. (FAC-003-4 Requirement R7 also specifies other acceptable reasons for modifying an annual work plan, including permitting delays.) Reliability Standard PRC-004-5(i) Requirement R5 states that a responsible entity that owns a Protection System component that caused a Misoperation shall either develop a Corrective Action Plan or explain in a declaration why corrective actions are beyond the entity's control or would not improve reliability. In light of the potential planning, siting, budgeting approval, and regulatory uncertainties associated with transmission projects that are outside of an entity's control, it is appropriate to include such a flexible approach to GMD Corrective Action Plan deadlines in proposed TPL-007-2.

As noted above, proposed Requirement R7 continues to apply only where an entity has identified system performance issues through the benchmark GMD Vulnerability Assessment. Mitigation considerations for vulnerabilities identified through the supplemental GMD Vulnerability Assessment are addressed in proposed Requirement R8 Part 8.3. Under this Part, if a responsible entity concludes that there would be Cascading caused by the supplemental GMD event, the entity shall conduct an analysis of possible actions to reduce the likelihood or mitigate the impacts of the event.

The standard drafting team determined that requiring formal Corrective Action Plans based on assessments of the supplemental GMD event would not be appropriate at this time. As discussed in the Supplemental GMD Event Description white paper, the supplemental GMD event is based on a small number of observed localized enhanced geoelectric field events that provide only general insight into the geographic size of localized events during severe solar storms. Additionally, currently available modeling tools do not provide entities with capabilities to model localized enhancements within a severe GMD event realistically. As a result, entities may need to employ conservative approaches when performing the supplemental GMD

Vulnerability Assessment, such as applying the localized peak geoelectric field over an entire planning area. For these reasons, requiring mandatory mitigation may not provide effective reliability benefit or use resources optimally. The approach used in the proposed standard for the supplemental GMD event provides entities with flexibility to consider and select mitigation actions based on their circumstances and is similar to the approach used in Reliability Standard TPL-001-4 Requirement R3 Part 3.5 for extreme events.

E. Enforceability of Proposed Reliability Standard TPL-007-2

Proposed Reliability Standard TPL-007-2 includes Measures in support of each Requirement to ensure that Requirements are enforced in a clear, consistent, non-preferential manner, without prejudice to any party. The proposed standard also includes VRFs and VSLs for each Requirement, which are used to help determine appropriate sanctions if an applicable entity violates a Requirement. VRFs assess the impact to reliability of violating a specific Requirement, while VSLs provide guidance on the way that NERC will enforce Requirements.

The proposed standard includes the same VRFs and VSLs for Requirements R1 through R7. Proposed Requirement R8 would apply a High VRF; proposed Requirements R9 and R10 would apply a Medium VRF; and Requirements R11 and R12 would apply a Lower VRF. Proposed Requirements R8 through R10 would also apply a graduated scale of Lower to Severe VSLs (depending on the extent of the violation), while proposed Requirements R11 and R12 would only apply a Severe VSL in recognition of the binary nature of compliance with the data obligations.

These VRFs and VSLs comport with NERC and FERC guidelines. The High VRF proposed for Requirement R8 is consistent with both Reliability Standard TPL-001-4 (requiring an annual planning assessment) and Reliability Standard TPL-007-1 Requirement R4. Further

failure to complete a supplemental GMD Vulnerability Assessment could, under certain conditions, place the BES at unacceptable risk. The Medium VRF proposed for Requirements R9 and R10 is similarly consistent with TPL-007-1 Requirements R5 and R6, which require responsible entities to provide GIC data to Transmission Owners and Generator Owners for assessments. In addition, failure to provide GIC flow information or conduct a supplemental transformer impact assessment is unlikely to lead to BES instability, separation, or cascading. The Lower VRF proposed for Requirements R11 and R12 is also consistent with other standards, such as the data collection related obligations in Reliability Standards MOD-032-1 Requirement R1 and IRO-010-2 Requirement R1. Finally, a Lower VRF for both Requirement R11 and R12 would also be appropriate, as an entity's failure to follow its process to obtain GIC monitor or geomagnetic field data would not be expected to adversely affect the electrical state or capability of the BES, or the ability to effectively monitor, control, or restore the BES. Please see Exhibit C for more detailed analysis of the proposed VRFs and VSLs.

V. EFFECTIVE DATE

NERC's proposed implementation plan is attached to this filing as Exhibit B. Under this plan, where approval by an applicable governmental authority is required, the standard shall become effective on the first day of the first calendar quarter that is three (3) months after the effective date of the applicable governmental authority's order approving the standard, or as otherwise provided for by the applicable governmental authority. Where approval by an applicable governmental authority is not required, the standard shall become effective on the first day of the first calendar quarter that is three (3) months after the date the standard is adopted by the NERC Board of Trustees, or as otherwise provided for in that jurisdiction. Reliability Standard TPL-007-1 is to be retired immediately prior to the effective date of TPL-007-2.

The proposed TPL-007-2 implementation plan recognizes that several Requirements in TPL-007-1 are or may soon become effective, and that many entities may now be taking steps to complete the studies or assessments required by other Requirements in TPL-007-1 that will become enforceable in the future. The proposed implementation plan thus contains two phased compliance timelines depending on whether proposed Reliability Standard TPL-007-2 standard becomes effective before January 1, 2021 or on/after January 1, 2021:²⁹

- ∞ If the proposed standard becomes effective before **January 1, 2021**, a new phased compliance schedule would support entities completing Requirements for the supplemental GMD Vulnerability Assessment concurrently with Requirements for the benchmark GMD Vulnerability Assessment.³⁰
- ∞ If the standard becomes effective on or after **January 1, 2021**, entities would continue work on benchmark GMD Vulnerability Assessments and complete supplemental GMD Vulnerability Assessments during the next assessment cycle.

Under either timeline, entities would be required to comply with Requirements for the collection of GMD monitoring data within 24 months of the effective date of the standard. The phased-in compliance dates provided in the proposed implementation plan appropriately balance the reliability need to implement the new and revised Requirements while providing entities with sufficient time to meet their obligations.

VI. PROPOSED PROJECT TO DEVELOP A TPL-007-2 VARIANCE FOR CANADA

On February 14, 2018, NERC received a Standard Authorization Request ("SAR") proposing to develop a Variance to Reliability Standard TPL-007-2 for Canadian entities. The submission of a SAR is the first step to develop a regional Variance in accordance with Section 9

²⁹ Under the TPL-007-1 implementation plan, this is the date by which entities would be required to comply with TPL-007-1 Requirement R6 pertaining to transformer thermal impact assessments based on the benchmark GMD event in the United States.

³⁰ Depending on the date of FERC approval of TPL-007-2, the phased compliance dates for completing steps for both benchmark and supplemental GMD Vulnerability Assessments may be slightly delayed from the dates set forth for benchmark GMD Vulnerability Assessments under the TPL-007-1 implementation plan.

of NERC's Standard Processes Manual.³¹ As defined therein, a Variance is an approved, alternative method of achieving the reliability intent of one or more Requirements in a Reliability Standard. A Variance may be developed when one or more Requirements in a continent-wide standard cannot be met or complied with as written because of a physical difference in the Bulk Power System or because of an operational difference (such as with a federally or provincially approved tariff), but the Requirement's reliability objective can be achieved in a different fashion.

Variations are developed and balloted in the same manner as Reliability Standards. This process provides for, among other things, comment periods to assess the need and scope of a proposed Variance development project as well as comment and ballot periods to assess the degree of consensus for the language of the proposed Variance. A proposed Variance must be approved by the ballot body and adopted by the NERC Board of Trustees before it would be filed with the applicable governmental authorities. The process is described in detail in Section 4 of the NERC Standard Processes Manual. If the Variance is determined to be necessary, it may take approximately one year to complete the process of development. However, the timeline for development would ultimately depend on factors such as whether the SAR is complete upon initial submission or needs further technical work, the scope of the proposed Variance development project, and the degree of consensus for the proposed Variance. While the development process is underway, any approved Reliability Standard version would remain in effect. The first version of the TPL-007 standard, Reliability Standard TPL-007-1, became

³¹ The NERC Standard Processes Manual, Appendix 3A to the NERC Rules of Procedure, is available at: <http://www.nerc.com/AboutNERC/Pages/Rules-of-Procedure.aspx>.

effective in Ontario on July 1, 2017. Full implementation of the standard will occur over a five year period with full compliance expected by January 1, 2022.

VII. UPDATE ON NERC'S ONGOING GMD RESEARCH WORK PLAN AND SECTION 1600 GMD DATA REQUEST ACTIVITIES

As noted earlier in this filing, NERC is continuing work to address FERC's GMD research and data collection directives from Order No. 830. On June 5, 2017, NERC submitted a preliminary version of its GMD Research Work Plan describing how NERC would oversee research into the specific GMD topics of interest identified by FERC.³² NERC is working with the Electric Power Research Institute ("EPRI") to prepare an updated GMD Research Work Plan to submit by April 2018 in accordance with FERC's October 19, 2017 Order.³³ NERC and EPRI initiated the GMD Research Work plan in November 2017 through an EPRI project that is supported by utility and Independent System Operator participants and involves NERC GMD Task Force, U.S. national laboratories, equipment manufacturers, and other North American research partners.

To address FERC's Order No. 830 data collection directive, NERC recently prepared an initial draft Request for Data or Information under Section 1600 of the NERC Rules of Procedure. The draft was prepared in conjunction with the NERC GMD Task Force under the oversight of the NERC Planning Committee. In accordance with the NERC Rules of Procedure, NERC provided the initial draft to FERC's Office of Electric Reliability on January 8, 2018. NERC expects to post the draft request for a 45-day public comment period on or around January

³² *Geomagnetic Disturbance Research Work Plan of the North American Electric Reliability Corporation*, (June 5, 2017).

³³ *Order on GMD Research Work Plan*, 161 FERC ¶ 61,048 (Oct. 19, 2017) (accepting NERC's preliminary GMD Research Work Plan).

30, 2018. Following the close of this comment period, NERC will review the comments received and revise the draft Section 1600 GMD Data Request as appropriate. NERC will also continue work to develop the necessary information technology infrastructure and data reporting specifications to facilitate the collection of GMD data. NERC intends to seek authorization from the NERC Board of Trustees to issue the Section 1600 GMD Data Request in August 2018.

VIII. CONCLUSION

For the reasons set forth above, NERC respectfully requests approval of proposed Reliability Standard TPL-007-2 and related elements, the proposed implementation plan, and the retirement of currently-effective Reliability Standard TPL-007-1 as discussed herein.

Respectfully submitted,

/s/ Lauren A. Perotti

Shamai Elstein
Senior Counsel
Lauren A. Perotti
Counsel
Candice Castaneda
Counsel
North American Electric Reliability
Corporation
1325 G Street, N.W., Suite 600
Washington, D.C. 20005
(202) 400-3000
(202) 644-8099 – facsimile
shamai.elstein@nerc.net
lauren.perotti@nerc.net
candice.castaneda@nerc.net

*Counsel for the North American Electric
Reliability Corporation*

Date: February 27, 2018

EXHIBITS A — D and F — J

Exhibit E -- Reliability Standards Criteria

Reliability Standards Criteria

The discussion below explains how the proposed Reliability Standard has met or exceeded the Reliability Standards criteria.

1. Proposed Reliability Standards must be designed to achieve a specified reliability goal and must contain a technically sound means to achieve that goal.

Proposed Reliability Standard TPL-007-2 addresses the unique risks posed by a high-impact, low-frequency geomagnetic disturbance (“GMD”) event on the reliable operation of the Bulk-Power System (“BPS”) and is responsive to FERC’s directives in Order No. 830. Reliability Standard TPL-007-1 requires applicable entities to conduct initial and on-going assessments of the potential impact of a benchmark GMD event on BPS equipment and the BPS as a whole and requires corrective action to protect against instability, uncontrolled separation, and cascading failures of the BPS. Proposed Reliability Standard TPL-007-2 improves upon the current version of the standard by using the latest developments in GMD research to provide enhanced criteria and requirements to address reliability risks arising from GMDs, including the risks posed by severe, localized events. The proposed standard would require entities to perform a second, or supplemental, GMD Vulnerability Assessment based on the supplemental GMD event. As described in **Exhibit I** to this filing, this supplemental GMD event is designed to account for the localized peak effects of severe GMD events on systems and equipment.

The proposed standard also contains revisions to require the collection of GIC and magnetometer data to inform GMD Vulnerability Assessments and to implement FERC-specified deadlines for the development and completion of any necessary Corrective Action Plans.

2. Proposed Reliability Standards must be applicable only to users, owners and operators of the bulk power system, and must be clear and unambiguous as to what is required and who is required to comply.

The proposed Reliability Standard is clear and unambiguous as to what is required and who is required to comply. Consistent with currently-effective Reliability Standard TPL-007-1, proposed Reliability Standard TPL-007-2 is applicable to: (1) Planning Coordinators with a planning area that includes a power transformer(s) with a high side, wye-grounded winding with terminal voltage greater than 200 kV; (2) Transmission Planners with a planning area that includes a power transformer(s) with a high side, wye-grounded winding with terminal voltage greater than 200 kV; (3) Transmission Owners that own a Facility or Facilities that include a power transformer(s) with a high side, wye-grounded winding with terminal voltage greater than 200 kV; and (4) Generator Owners that own a Facility or Facilities that include a power transformer(s) with a high side, wye-grounded winding with terminal voltage greater than 200 kV.¹ The proposed Reliability Standard clearly articulates the actions that such entities must take to comply with the standard.

¹ A power transformer with a “high side wye-grounded winding” refers to a power transformer with windings on the high voltage side that are connected in a wye configuration and have a grounded neutral connection.

3. A proposed Reliability Standard must include clear and understandable consequences and a range of penalties (monetary and/or non-monetary) for a violation.

The Violation Risk Factors (“VRFs”) and Violation Severity Levels (“VSLs”) for the proposed Reliability Standard comport with NERC and FERC guidelines related to their assignment. The assignment of the severity level for each VSL is consistent with the corresponding requirement and the VSLs should ensure uniformity and consistency in the determination of penalties. The VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations. For these reasons, the proposed Reliability Standard includes clear and understandable consequences.

4. A proposed Reliability Standard must identify clear and objective criterion or measure for compliance, so that it can be enforced in a consistent and non preferential manner.

The proposed Reliability Standard contains Measures that support each Requirement by clearly identifying what is required and how the Requirement will be enforced. These measures help provide clarity regarding how the Requirements will be enforced and help ensure that the

Requirements will be enforced in a clear, consistent, and non-preferential manner and without prejudice to any party.

5. Proposed Reliability Standards should achieve a reliability goal effectively and efficiently — but do not necessarily have to reflect “best practices” without regard to implementation cost or historical regional infrastructure design.

The proposed Reliability Standard achieves its reliability goals effectively and efficiently.

The proposed Reliability Standard clearly enumerates the responsibilities of applicable entities with respect to conducting initial and on-going assessments of the potential impact of defined GMD events on BPS equipment and the BPS as a whole and provides entities the flexibility to select appropriate mitigation strategies to address identified vulnerabilities.

6. Proposed Reliability Standards cannot be “lowest common denominator,” i.e., cannot reflect a compromise that does not adequately protect Bulk-Power System reliability. Proposed Reliability Standards can consider costs to implement for smaller entities, but not at consequences of less than excellence in operating system reliability.

The proposed Reliability Standard does not reflect a “lowest common denominator” approach. To the contrary, the proposed Reliability Standard contains significant reliability benefits for the BPS and addresses directives and concerns identified by FERC in Order No. 830. The provisions of the proposed standard raise the level of preparedness by requiring applicable entities to plan for the reliable operation of the BPS during a second severe GMD event, one that is intended to account for localized peak effects. The proposed Reliability Standard and the new supplemental GMD event incorporate rigorous technical analysis that is representative of the complex nature of space weather phenomena and reflects a balanced and practical approach. By instituting Requirements for the collection of GIC and magnetometer data, the proposed standard increases the amount of information available to inform GMD Vulnerability Assessments. Lastly, the proposed standard revises Requirements for Corrective Action Plans to implement

FERC-directed deadlines for their development and completion while also providing an accountability-driven process to manage any revisions that may become necessary due to circumstances outside of the entity's control.

7. **Proposed Reliability Standards must be designed to apply throughout North America to the maximum extent achievable with a single Reliability Standard while not favoring one geographic area or regional model. It should take into account regional variations in the organization and corporate structures of transmission owners and operators, variations in generation fuel type and ownership patterns, and regional variations in market design if these affect the proposed Reliability Standard.**

The proposed Reliability Standard applies consistently throughout North America and does not favor one geographic area or regional model. The proposed standard includes technically-justified scaling factors that allow for entity-specific tailoring of the benchmark and supplemental GMD events. This approach provides for consistent application of the proposed Reliability Standard throughout North America while still accounting for the varying impact GMD events may have on each region.

8. **Proposed Reliability Standards should cause no undue negative effect on competition or restriction of the grid beyond any restriction necessary for reliability.**

Proposed Reliability Standard TPL-007-2 has no undue negative effect on competition and does not unreasonably restrict the available transmission capacity or limit the use of the BPS in a preferential manner. The proposed standard requires the same performance by each of the applicable entities. The information sharing required by the proposed standard is necessary for reliability and can be accomplished without presenting any market or competition-related concerns.

9. The implementation time for the proposed Reliability Standard is reasonable.

The proposed effective date for proposed Reliability Standard TPL-007-2 is just and reasonable and appropriately balances the urgency in the need to implement the standard against the reasonableness of the time allowed for those who must comply to develop necessary procedures, software, facilities, staffing or other relevant capability. The proposed implementation plan recognizes that several Requirements in TPL-007-1 are or will soon become effective, and that many entities may now be taking steps to complete the studies or assessments required by other Requirements in TPL-007-1 that will become enforceable in the future. NERC's proposed implementation plan therefore contains two phased compliance timelines based on the effective date of TPL-007-2: one timeline would support the concurrent completion of the benchmark and supplemental GMD Vulnerability Assessments, while the second would have entities complete benchmark GMD Vulnerability Assessments first and then complete supplemental GMD Vulnerability Assessments during the next assessment cycle. Either option would allow applicable entities adequate time to ensure compliance with the Requirements. The proposed implementation plan is attached as **Exhibit B** to this filing.

10. The Reliability Standard was developed in an open and fair manner and in accordance with the Reliability Standard development process.

The proposed Reliability Standard was developed in accordance with NERC's ANSI-accredited processes for developing and approving Reliability Standards. **Exhibit D** includes a summary of the Reliability Standard development proceedings, and details the processes followed to develop the proposed Reliability Standard. These processes included, among other things, multiple comment periods, pre-ballot review periods, and balloting periods. Additionally, all meetings of the standard drafting team were properly noticed and open to the public.

11. NERC must explain any balancing of vital public interests in the development of proposed Reliability Standards.

NERC has identified no competing public interests regarding the request for approval of this proposed Reliability Standard. No comments were received that indicated the proposed Reliability Standard conflicts with other vital public interests.

12. Proposed Reliability Standards must consider any other appropriate factors.

No other negative factors relevant to whether the proposed Reliability Standard is just and reasonable were identified.

Appendix C: Standard Authorization Request

Standard Authorization Request (SAR)

Complete and please email this form, with attachment(s) to: sarcomm@nerc.net

The North American Electric Reliability Corporation (NERC) welcomes suggestions to improve the reliability of the bulk power system through improved Reliability Standards.

Requested information			
SAR Title:	Canadian-specific Revision to proposed standard TPL-007-2 (Transmission System Planned Performance for Geomagnetic Disturbance Events)		
Date Submitted:	February 27, 2018		
SAR Requester			
Name:	Helen Lainis (IESO) and Payam Farahbakhsh (Hydro One)		
Organization:	Canadian Electricity Association (“CEA”) Members from Ontario (IESO and Hydro One), with the support of additional CEA Members including Manitoba Hydro, Hydro Québec and SaskPower.		
Telephone:	Helen: 905-855-4106 Payam: 416- 345 - 5484	Email:	Helen: helen.lainis@ieso.ca Payam: Payam.Farahbakhsh@HydroOne.com
SAR Type (Check as many as apply)			
<input type="checkbox"/> New Standard	<input type="checkbox"/> Imminent Action/ Confidential Issue (SPM Section 10)	<input checked="" type="checkbox"/> Revision to Existing Standard	<input checked="" type="checkbox"/> Variance development or revision
<input type="checkbox"/> Add, Modify or Retire a Glossary Term	<input type="checkbox"/> Other (Please specify)	<input type="checkbox"/> Withdraw/retire an Existing Standard	
Justification for this proposed standard development project (Check all that apply to help NERC prioritize development)			
<input type="checkbox"/> Regulatory Initiation	<input type="checkbox"/> NERC Standing Committee Identified	<input type="checkbox"/> Emerging Risk (Reliability Issues Steering Committee) Identified	<input type="checkbox"/> Enhanced Periodic Review Initiated
<input type="checkbox"/> Reliability Standard Development Plan	<input checked="" type="checkbox"/> Industry Stakeholder Identified		
Industry Need (What Bulk Electric System (BES) reliability benefit does the proposed project provide?):			
<p>The need for this SAR is to enable the option for Canadian Registered Entities to leverage operating experience, observed GMD effects and on-going research efforts for defining alternative Benchmark GMD Events and/or Supplemental GMD Events specific to their unique topology.</p> <p>Registered Entities from Ontario, Québec, Manitoba and Saskatchewan have indicated support for a revision to be included in TPL-007-2 as an option for Canadian Registered Entities to pursue. At a minimum, Registered Entities in Ontario (Hydro One and IESO) have indicated that this proposed</p>			

Requested information
<p>revision would be used to define and implement an alternative Benchmark GMD Event and/or Supplemental GMD Event that appropriately reflects their specific geographical and geological characteristics.</p>
<p>Purpose or Goal (How does this proposed project provide the reliability-related benefit described above?):</p> <p>The goal is to enable Canadian Registered Entities to define and implement alternative Benchmark GMD Events and/or Supplemental GMD Events that appropriately reflects the specific geographical and geological characteristics of the Canadian provinces, including those located on the Canadian Shield, a vast area of igneous rock exhibiting low electrical conductivity, through leveraging ongoing research efforts, operating experience, and observed GMD effects:</p> <ul style="list-style-type: none"> • Registered Canadian entities from Canadian provinces (most prominently Manitoba, Ontario and Québec) located on the Canadian Shield, are currently working to develop a Benchmark GMD Event and/or Supplemental GMD Event that takes into account their unique topology. • These Canadian Registered Entities have been researching the impact of GMD on their power systems for several years now, and have been collaborating with Natural Resources Canada to collect and analyze Canadian magnetometer data for their respective provinces.
<p>Project Scope (Define the parameters of the proposed project):</p> <p>Reliability Standard TPL-007-2 should be revised to allow Canadian jurisdictions to define and implement alternative Benchmark GMD Events and/or Supplemental GMD Events that are different from the ones defined in TPL-007-2 appropriate for a continent wide standard.</p> <p>The Benchmark GMD Event and/or Supplemental GMD Event described in TPL-007-2 should be options to pursue for Canadian Registered Entities for performing GMD Vulnerability Assessments.</p> <p>Implementation of Benchmark GMD Events and/or Supplemental GMD Events by Canadian Registered Entities should be subject to approval by applicable Canadian governmental authority or their agencies.</p>
<p>Detailed Description (Describe the proposed deliverable(s) with sufficient detail for a drafting team to execute the project. If you propose a new or substantially revised Reliability Standard or definition, provide: (1) a technical justification¹which includes a discussion of the reliability-related benefits of developing a new or revised Reliability Standard or definition, and (2) a technical foundation document (e.g. research paper) to guide development of the Standard or definition):</p> <p>NERC has spent a substantial amount of time and effort working with experts across the industry to develop scientifically sound Benchmark GMD Events defined in TPL-007-2 appropriate for a continent wide standard.</p>

¹ The NERC Rules of Procedure require a technical justification for new or substantially revised Reliability Standards. Please attach pertinent information to this form before submittal to NERC.

Requested information

The research and development in this field continues to evolve, and more remains to be learned, new assessment tools need to be developed and assessment models need to be verified. In Canada, there is on-going work being done on this subject. We request that TPL-007-2 provide the flexibility for Canadian jurisdictions to leverage their expertise and to build on their research and on GMD impact assessment methodologies to define alternative Benchmark GMD Events and/or Supplemental GMD Events targeted to their unique topology.

The Canadian Shield is a sprawling rock formation that stretches across nearly all of Québec, much of Ontario and Manitoba, the northern portion of Saskatchewan and the northeast corner of Alberta. This geological formation blocks current from being dissipated into the Earth, making these Canadian provinces more susceptible to solar storms.

As such, Registered Entities from several Canadian shield provinces have been researching the impact of GMD on the reliable operation of their BES for years. For example, Hydro One Networks Inc., has been conducting this work in Ontario, Manitoba Hydro has been conducting this work in Manitoba and Hydro Québec has been conducted this work in Québec. A list of several technical publications could be provided upon request of the SDT to demonstrate the depth of Hydro One’s, Manitoba Hydro’s, Hydro Québec’s and other jurisdictions’ technical research and expertise in modeling and analyzing GMD impacts. These references also describe significant development efforts on tools and operating processes to support planned transmission system performance during GMD events.

Natural Resources Canada has published their calculations of extreme value statistics for a 1-50 and 1-100 year geomagnetic storm based on data from 13 Natural Resources Canada geomagnetic observatories, and Natural Resources Canada and Registered Entities from Canadian shield provinces have been collaborating to collect and analyze Canadian magnetometer data for their respective provinces.

Cost Impact Assessment, if known (Provide a paragraph describing the potential cost impacts associated with the proposed project):

The cost implications of addressing a Benchmark GMD Event and/or Supplemental GMD Event is expected to be more significant for the Canadian shield provinces than for those registered entities in the lower 48 state portion of the United States. Furthermore, any capital investment must be approved by the applicable provincial regulatory authority. Consequently, it is essential that the requirements of the standard appropriately reflect conditions that exist in affected Canadian provinces. To this end, Registered Entities from these provinces are working with Natural Resources Canada and are using their own inputs to develop a Benchmark GMD Event and/or Supplemental GMD Event based on empirical data that will form the basis for seeking approval for any required investments with their respective regulatory authorities.

Please describe any unique characteristics of the BES facilities that may be impacted by this proposed standard development project (e.g. Dispersed Generation Resources):

Not Applicable

Requested information
To assist the NERC Standards Committee in appointing a drafting team with the appropriate members, please indicate to which Functional Entities the proposed standard(s) should apply (<i>e.g.</i> Transmission Operator, Reliability Coordinator, etc. See the most recent version of the NERC Functional Model for definitions):
Canadian Registered Entities that meet the applicability specified in Sections 4.1 and 4.2 of the proposed TPL-007-2 Reliability Standard.
Do you know of any consensus building activities ² in connection with this SAR? If so, please provide any recommendations or findings resulting from the consensus building activity.
The revision would be used, at a minimum, by IESO and Hydro One to avoid needing to seek remand to TPL-007-2 in Ontario, Canada. Working with CEA, IESO and Hydro One have engaged other Canadian Registered Entities to solicit feedback. Registered entities from Manitoba, Québec and Saskatchewan are supportive of a to TPL-007-2 as an option for Canadian Registered Entities to pursue. No Canadian Entity has voiced opposition to such a revision.
Are there any related standards or SARs that should be assessed for impact as a result of this proposed project? If so which standard(s) or project number(s)?
No
Are there alternatives (e.g. guidelines, white paper, alerts, etc.) that have been considered or could meet the objectives? If so, please list the alternatives.

Reliability Principles	
Does this proposed standard development project support at least one of the following Reliability Principles (Reliability Interface Principles)? Please check all those that apply.	
<input checked="" type="checkbox"/>	1. Interconnected bulk power systems shall be planned and operated in a coordinated manner to perform reliably under normal and abnormal conditions as defined in the NERC Standards.
<input type="checkbox"/>	2. The frequency and voltage of interconnected bulk power systems shall be controlled within defined limits through the balancing of real and reactive power supply and demand.
<input checked="" type="checkbox"/>	3. Information necessary for the planning and operation of interconnected bulk power systems shall be made available to those entities responsible for planning and operating the systems reliably.
<input type="checkbox"/>	4. Plans for emergency operation and system restoration of interconnected bulk power systems shall be developed, coordinated, maintained and implemented.
<input type="checkbox"/>	5. Facilities for communication, monitoring and control shall be provided, used and maintained for the reliability of interconnected bulk power systems.
<input type="checkbox"/>	6. Personnel responsible for planning and operating interconnected bulk power systems shall be trained, qualified, and have the responsibility and authority to implement actions.

² Consensus building activities are occasionally conducted by NERC and/or project review teams. They typically are conducted to obtain industry inputs prior to proposing any standard development project to revise, or develop a standard or definition.

Reliability Principles	
<input checked="" type="checkbox"/>	7. The security of the interconnected bulk power systems shall be assessed, monitored and maintained on a wide area basis.
<input type="checkbox"/>	8. Bulk power systems shall be protected from malicious physical or cyber-attacks.

Market Interface Principles	
Does the proposed standard development project comply with all of the following Market Interface Principles ?	Enter (yes/no)
1. A reliability standard shall not give any market participant an unfair competitive advantage.	YES
2. A reliability standard shall neither mandate nor prohibit any specific market structure.	YES
3. A reliability standard shall not preclude market solutions to achieving compliance with that standard.	YES
4. A reliability standard shall not require the public disclosure of commercially sensitive information. All market participants shall have equal opportunity to access commercially non-sensitive information that is required for compliance with reliability standards.	YES

Identified Existing or Potential Regional or Interconnection Variances	
Region(s)/ Interconnection	Explanation
e.g. NPCC	

For Use by NERC Only

SAR Status Tracking (Check off as appropriate)	
<input type="checkbox"/> Draft SAR reviewed by NERC Staff	<input type="checkbox"/> Final SAR endorsed by the SC
<input type="checkbox"/> Draft SAR presented to SC for acceptance	<input type="checkbox"/> SAR assigned a Standards Project by NERC
<input type="checkbox"/> DRAFT SAR approved for posting by the SC	<input type="checkbox"/> SAR denied or proposed as Guidance document

Version History

Version	Date	Owner	Change Tracking
1	June 3, 2013		Revised
1	August 29, 2014	Standards Information Staff	Updated template
2	January 18, 2017	Standards Information Staff	Revised

2	June 28, 2017	Standards Information Staff	Updated template
---	---------------	-----------------------------	------------------