



Hydro One FIT Process for LDCs

April 27, 2010

Agenda for Today

1. Overview of LDC FIT process for Capacity Allocation Exempt and Mainstream FIT Projects
 - CIA process Overview
 - Threshold CIA Concept
 - Capacity & Project Tracking
2. Q & A Session

Committed to Connecting Renewable

- We know generators rely on us to manage our obligations in a manner that brings certainty to the timing of their projects.
- We understand that what we do and when we do it can have financial implications for generators. We will continue to work with generators to identify their issues proactively on technical solutions.
- As stewards of the Province's transmission and distribution system, we must identify solutions that ensure power quality and protect the integrity and reliability of the system for everyone in Ontario.

Renewable Connections: Status 2010

- Hydro One has connected 112 generators to its distribution system totaling 377 MW and has more than 500 MW of RESOP contracted generation which the Company expects to connect in 2010.
- The Company has connected more than 5,500 MW of new generation to the transmission system since 2004 and in addition, there is almost 2,500 MW committed for connection to transmission.
- 1900 MW is renewable wind and hydro.

LDC CIA Application's

- LDC submits CIA application on behalf of the proponent for any projects > 10 kW
- Applications are submitted by the LDC to Hydro One's Business Customer Centre (BCC)
- HONI CIA completed in conjunction with the LDC's CIA
- Final CIA and documents for next steps returned to the LDC by the BCC
- An incomplete application will result in delays.

LDC CIA Application's - Three Categories

- LDC owned feeders (Connected to HONI TS)
- LDC Embedded feeders (Connected to HONI) feeder
- Upstream LDC (HONI embedded in an LDC) feeder

LDC Owned Feeder CIA

- Requires only a TS review from Hydro One because the feeder is owned by the LDC
- A streamlined process using Threshold CIA may apply
- 60 day turn around

LDC Embedded Feeder CIA

- Requires a TS and feeder review from Hydro One because the feeder is embedded in Hydro One Dx
- Streamlined CIA process does not apply
- 120 days to process the CIA as more than one LDC is involved

Upstream LDC CIA

- Hydro One requires a CIA from the LDC where we are embedded in an LDC feeder.
- Hydro One applies to the LDC for a CIA and signs a connection agreement on behalf of the generator connecting to Hydro One's feeder.
- 120 days to process the CIA as more than one LDC is involved

Hydro One Generation Connections

Generator Connections - Windows Internet Explorer
http://www.hydroone.com/Generators/Pages/Default.aspx

hydro one

myHome myBusiness ourCommitment

CUSTOMER LOGIN Where am I? Hydro One > Generators Search here...
Advanced Sitemap Contact Us


Generators

- Net Metering
- Generation Connections
- Distribution-connected
- Transmission
- FIT and microFIT
- IMPORTANT UPDATE FOR GENERATORS
- Technical Requirements





CONNECT YOUR GENERATOR

Hydro One connects generating facilities to the transmission and distribution network, delivering the electricity they produce at hydroelectric, coal, natural gas, wind and nuclear facilities to businesses and people across Ontario. We work with our customers to plan for the future and make sure facilities are in place to deliver electricity where it needs to be.

Connecting to Hydro One's **Distribution** or **Transmission** systems involves several steps and both the **generator** and **Hydro One** have **distinct responsibilities**.



Where do you want to go?


| Transmission | Distribution | Feed-In Tariffs (FIT) | Net Metering |
|--|---|---|---|
|  |  |  |  |
| Transmission-connected generators connect to the grid at more than 50,000 volts and are registered with the IESO | Distribution-connected generators connect to the power system at less than 50,000 volts | The Ontario Power Authority's FIT program sets fixed prices for buying back electricity generated by renewable energy installations | Our Net Metering program provides bill credits for the electricity generated from renewable energy technologies (RETs) connected to our network |

http://www.hydroone.com/MyBusiness

Local intranet 100%

start 10 Microsoft... Microsoft Pow... Study Agree... 3 Microsoft... Internet E... SnagIt 100% 11:11 AM

BCC Links



as the roles and responsibilities of each party.

Connection Impact Assessment (CIA)

A CIA is a more detailed assessment of a project's impact to the grid. The results include a technical report outlining project feasibility, technical specifications needed for the project and the impacts the project would have on the distribution grid. CIAs will only be accepted for projects where the OPA FIT contract has been awarded.

The Generator is required to submit a completed **Connection Impact Assessment Form B**, payment for the Connection Impact Assessment and a signed Study Agreement. Please email dxgenerationconnections@hydroone.com or by calling 1-877-447-4412 (choose option #2) for a Study Agreement suited to your project size.

A complete CIA application consists of:

- Completed and signed CIA Form
- Payment in full by cheque or money order payable to "Hydro One Networks Inc." (see Connection Impact Assessment Fee Schedule below)
- Signed Study Agreement
- Single Line Diagram (SLD)

NOTE: All technical submissions (Form B, single line diagrams, etc.) for projects greater than 10 kW must be signed and sealed by a licensed Ontario Professional Engineer (P.ENG).

| Project Type | Project Size | Cost** |
|--------------------------------------|--|---------|
| Net Metering Projects | >10 kW and ≤500 kW | \$3,000 |
| Small Projects (Except Net Metering) | a) ≤ 500 kW connected on distribution system voltage < 15 kV | \$3,000 |
| | b) ≤ 1MW connected on distribution system voltage ≥ 15 kV | |
| Mid-Size Projects | a) ≤ 10 MW but > 500 kW connected on distribution system voltage < 15 kV | \$5,000 |
| | b) > 1 MW but ≤ 10 MW connected on distribution system voltage ≥ 15 kV | |
| Large Projects | > 10 MW | \$6,000 |

**NOTE:

CIA Form B



Form B Connection Impact Assessment (CIA) Application Distribution System

This Application Form is for Generators applying for Connection Impact Assessment ("CIA") and for Generators with a project size >10 kW.

This Application Form is required for:

- **New** Generators applying for Connection Impact Assessment ("CIA")
- **New** Generators applying for revision to their original Connection Impact Assessment ("CIA") (for example XXXXXXXXXXXXXXXXXXXX)
- Generators applying for Connection Impact Assessment ("CIA") after rescinding a previous CIA. **Note:** Please include your previous CIA Project ID # below.
- **Existing** Generators to verify information related to current connection to the Hydro One system. It is part of the overall (Distribution) Connection Agreement.

For generation size ≤ 10 kW, please fill out [Form C](#) ("Micro-Generation Connection Application Form") at <http://www.hydroone.com/Generators/FITmicroFIT/Pages/microFIT.aspx>

Refer to [Technical Requirements for Generators Connecting to Hydro One's Distribution System](#) at <http://www.hydroone.com/Generators/FITmicroFIT/Pages/TechnicalRequirements.aspx>

IMPORTANT: All fields below are mandatory, except where noted. Incomplete applications may be returned by Hydro One Networks Inc. ("Hydro One").

If you have any questions please e-mail Hydro One's Business Customer Centre at dxgenerationconnections@hydroone.com or call 1-877-447-4412 (Option# 2 8:30 am to 5:00 pm Mon to Fri).

Please return the completed form, fees and other required documents by mail to:

Hydro One Networks Inc.
Attn: Business Customer Centre
Generation Connection Application
185 Clegg Road
Markham, Ontario L6G 1B7

Full Screen
Close Full Screen

NOTE 1: Applicants are cautioned NOT to incur major expenses until Hydro One approves to connect the proposed generation facility.

NOTE 2: All technical submissions (Form B, single line diagrams, etc.) must be signed and sealed by a licensed Ontario Professional Engineer (P.Eng.).

Date: (dd / mm / yyyy)

Application Type: New CIA Application CIA Revision/Rework

1. Original CIA Project ID# (if applicable):

Project Name:

2. Ontario Power Authority (OPA) Feed-In Tariff (FIT) Contract Number:

3. Proposed In-Service Date: (dd / mm / yyyy)

4. Project Size: Number of Units
Nomenclature Rating of Each Unit kW



CIA Report



483 Bay St., Toronto, Ontario M5G 2P5

CONNECTION IMPACT ASSESSMENT

[PROJECT NAME]

[DEVELOPER NAME]

[SIZE] MW [TYPE] Generation

Project ID # [###]

Revision 1

[DATE – to be filled in by GCD Planner]

NOTE: The Connection Impact Assessment (CIA) for project **[GCD Planner to insert project ID #]** was performed under the assumptions and key project and connection data contained in this CIA report. This CIA is valid for a period of no more than 6 months from the date listed above. Any future modifications to the assumptions and key project and connection data could affect the CIA results, and the CIA may need to be re-done at the Customer's expense. A Customer can request a re-work of an expired CIA at the Customer's expense.



Streamlined Process – Threshold CIA

- The Threshold CIA is
 - A “bundled” allocation of capacity up to 1MW where the list of projects is already known
 - An allocation of capacity for up to 1MW when the list of projects is not known
- The Threshold CIA may only include:
 - Inverter based generation only; non-inverter based generation will require individual CIAs
 - 1 MW limit per Threshold CIA
 - When nearing the station capacity, no Threshold CIA will be produced.

Threshold CIA - Final Product

- Body of report will contain connection requirements, Appendices will refer to individual projects when identified by an application in advance
- CCA maybe needed for every DG projects included in the threshold CIA.
- On a periodic basis HONI will ask for a list of DG included in each CIA.

Connecting Distributed Generation

- Connecting generators to distribution is a new experience:
 - Generation connected to long feeders
 - Short circuit considerations
 - Transformer station capacity
- Comparison with other jurisdictions
 - This is a learning experience for all

Challenges with Station Capacity

- Capacity is fluid, not static
 - System load is continually changing, new generation outside of FIT
- Newly connected renewable generator sites are uncovering unforeseen impacts to the grid system
 - Long Feeder, Short Circuit Considerations, Transformer Limitations
- Objective is to balance requirement to protect the performance and reliability of the system with the objective to accommodate new renewable sources of generation
 - Required to ensure that new renewables can be connected in a way which does not adversely impact load customers
 - In everyone's best interests to ensure that new renewable generation is viewed by broader public as a reliable source of energy

Station Capacity Limits Definition

- Consistent with the Distribution System Code, the following technical capacity limit has been determined by Hydro One:
 - Reverse power flow is not to exceed 60% of station capacity to protect the system in a situation where 1 transformer is out of service
- Short Circuit levels at the station low voltage bus must be within Transmission System Code limits

HONI Experience with Station Capacity

In preparation for FIT, Hydro One reviewed station capacity considering actual experience and new information.

Highlights:

- Some dual secondary winding transformers do not allow for reverse power flow conditions
- There was a reduction in minimum system load
- Short Circuit levels are already high at some stations

Short Circuit

- Short circuit limitations were previously identified after a Connection Impact Assessment (CIA) was completed
- Some short circuit limitations are presently identified on Hydro One's List of Allocated Capacity and on OPA's Connection Availability Table
- Short circuit information was provided to the OPA. But this information will not be considered in TAT. The evaluation will be done during the CIA.

Thermal Capacity Conclusions

- The station capacity shown on Hydro One's List of Allocated Capacity and OPA's Connection Availability Table reflects:
 - Dual secondary winding transformer capacity
 - Reduction in system load
 - More detailed analysis

List of Allocated Capacity

- Station capacity on Hydro One's List of Allocated Capacity was adjusted in preparation for FIT
- The Connection Availability Table posted by the OPA at FIT launch includes station capacity values
- OPA's values account for RESOP contracts awarded at the time of FIT launch
- Station capacity values represent the technical capability of the station to accept new generation

List of Allocated Capacity (Old)

| AGIMAK DS | | |
|------------------------------------|----|----|
| Thermal Capacity (MW) = 7 | | |
| Short Circuit Capacity (MVA) = 652 | | |
| | F1 | F2 |
| Allocated Capacity (MW) | 0 | 0 |

| AGINCOURT TS | | | | | | | | | | | |
|--------------------------------------|----|----|----|----|-----|--------|----|----|----|----|-----|
| Thermal Capacity (MW) = Sum of Buses | | | | | | | | | | | |
| Short Circuit Capacity (MVA) = N/A | | | | | | | | | | | |
| S = 11 | | | | | | Y = 11 | | | | | |
| Thermal Bus Capacity (MW) | | | | | | | | | | | |
| Short Circuit Bus Capacity (MVA) | | | | | | | | | | | |
| S = 124 | | | | | | | | | | | |
| Y = 125 | | | | | | | | | | | |
| | M2 | M4 | M5 | M8 | M10 | M12 | M1 | M3 | M6 | M7 | M11 |
| Allocated Capacity (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Station may supply another LDC's territory.
[Refer to OPA FIT LDC locator tool to find LDC.](#)

| *ALBION TS | | | |
|--|--|--------|--|
| Thermal Capacity (MW) = Sum of Buses | | | |
| Short Circuit Capacity (MVA) = N/A | | | |
| SQ = 9 | | JY = 9 | |
| Thermal Bus Capacity (MW) | | | |
| Short Circuit Bus Capacity (MVA) | | | |
| SQ = 113 | | | |
| JY = 112 | | | |
| For any information or inquiries please contact Hydro Ottawa | | | |

Station may supply another LDC's territory.
[Refer to OPA FIT LDC locator tool to find LDC.](#)

| ALEXANDER DS | | |
|------------------------------------|-----|-----|
| Thermal Capacity (MW) = 10 | | |
| Short Circuit Capacity (MVA) = N/A | | |
| | F1 | F4 |
| Allocated Capacity (MW) | 5.5 | 6.4 |

[ALEXANDER DS IS](#)
[Southwest of SOUTH](#)
[MARCH TS MS](#)

| ALLANBURG TS | | |
|------------------------------------|----|----|
| Thermal Capacity (MW) = 22 | | |
| Short Circuit Capacity (MVA) = 195 | | |
| | M6 | M7 |
| Allocated Capacity (MW) | 0 | 0 |

| ALLISTON TS | | | | | |
|------------------------------------|----|----|----|----|----|
| Thermal Capacity (MW) = 62 | | | | | |
| Short Circuit Capacity (MVA) = 407 | | | | | |
| | M1 | M2 | M3 | M4 | M6 |
| Allocated Capacity (MW) | 0 | 0 | 0 | 10 | 0 |

| ALMONTE TS | | | |
|------------------------------------|-----|--------|-----|
| Thermal Capacity (MW) = 24 | | | |
| Short Circuit Capacity (MVA) = N/A | | | |
| J = 17 | | G = 29 | |
| Thermal Bus Capacity (MW) | | | |
| Short Circuit Bus Capacity (MVA) | | | |
| J = 1119 | | | |
| G = 1161 | | | |
| | M25 | M26 | M28 |
| Allocated Capacity (MW) | 5 | 0 | 0 |

| ARDOCH DS | | |
|-----------------------------------|----|----|
| Thermal Capacity (MW) = 6 | | |
| Short Circuit Capacity (MVA) = 75 | | |
| | F1 | F2 |
| Allocated Capacity (MW) | 0 | 0 |

| ARMITAGE TS DESN 1 | | | | | | | |
|------------------------------------|-----|-----|-----|-----|-----|-----|-----|
| Thermal Capacity (MW) = 110 | | | | | | | |
| Short Circuit Capacity (MVA) = 402 | | | | | | | |
| | M11 | M12 | M13 | M14 | M21 | M22 | M23 |
| Allocated Capacity (MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Station may supply another LDC's territory.
[Refer to OPA FIT LDC locator tool to find LDC.](#)

SAMPLE - LIST OF CAPACITY

| Station Name | BUS Name | Dx Details Feeders | Tx - LV Level (KV) | Station Minimum Load | Station Thermal Capacity (MVA) | Station Short Circuit Capacity (MVA) | Upstream TS | Upstream TS feeder |
|--------------------|----------|--|--------------------|----------------------|--------------------------------|--------------------------------------|----------------|--------------------|
| AGIMAK DS | Total | F1, F2 | 24.9 | 1.0 | 7.0 | 652 | | |
| AGINCOURT TS | B | M2,M4,M5,M8,M10,M12 | 27.6 | 14.4 | 10.8 | 124 | | |
| AGINCOURT TS | Y | M1,M3,M5,M7,M11 | 27.6 | 13.2 | 10.8 | 125 | | |
| AGINCOURT TS | Total | M2,M4,M5,M8,M10,M12,M1,M3,M5,M7,M11 | 27.6 | 27.4 | Sum of Buses | 0 | | |
| ALBION TS | Total | N/A | 12.5 | 35.8 | Sum of Buses | 0 | | |
| ALBION TS | BQ | N/A | 12.5 | 20.9 | 9.0 | 113 | | |
| ALBION TS | JY | N/A | 12.5 | 14.3 | 9.0 | 112 | | |
| ALEXANDER DS | B1 | F1,F3 | 27.6 | 4.5 | 12.5 | N/A | SOUTH MARCH TS | M5 |
| ALEXANDER DS | B2 | F2,F4 | 27.6 | 2.3 | 10.3 | N/A | SOUTH MARCH TS | M5 |
| ALEXANDER DS | Total | F1,F2,F3,F4 | 27.6 | 6.9 | 14.9 | N/A | SOUTH MARCH TS | M5 |
| ALLANBURG TS | Total | M6, M7, M8 | 27.6 | 9.8 | 21.8 | 212 | | |
| ALLISTON TS | Total | M1, M2, M3, M4, M5, M6 | 44 | 21.6 | 61.5 | 467 | | |
| ALMONTE TS | J | M25 | 44 | 1.8 | 21.8 | 1142 | | |
| ALMONTE TS | Q | M26, M28 | 44 | 7.7 | 28.7 | 1148 | | |
| ALMONTE TS | Total | M25,M26,M28 | 44 | 10.6 | 29.1 | 0 | | |
| ARDOCH DS | Total | F1, F2 | 12.5 | 0.5 | 6.5 | 75 | | |
| ARMITAGE TS DESN 1 | QJ | M11, M12, M13, M14, M21, M22, M23, M24 | 44 | 59.6 | 118.0 | 411 | | |
| ARMITAGE TS DESN 2 | EY | M31, M32, M33, M34, M41, M42, M43, M44 | 44 | 60.4 | 85.2 | 300 | | |
| ARNPRIOR TS | Total | M1, M2 | 44 | 15.4 | 33.1 | 907 | | |
| AYLMER TS | Total | M1, M2 | 27.6 | 3.2 | 10.0 | 529 | | |
| BARRIE TS | Total | M1, M2, M3, M4, M5, M6, M7 | 44 | 24.5 | 68.5 | 644 | | |
| BASIN TS | ASA6 | T3A5, T3A6, T5A5, T5A6 | 13.8 | 10.7 | 9.0 | 65 | | |
| BASIN TS | ATA8 | T3A7,T3A8, T5A7, T5A8 | 13.8 | 9.5 | 8.1 | 65 | | |
| BASIN TS | Total | T3A5, T3A6, T5A5, T5A6,T3A7,T3A8, T5A7, T5A8 | 13.8 | 21.5 | Sum of Buses | 0 | | |
| BATHURST TS DESN 1 | B | M10,M4,M5, M6, M8 | 27.6 | 14.9 | 39.9 | 94 | | |
| BATHURST TS DESN 1 | Y | M1,M2,M3,M7,M9 | 27.6 | 11.8 | 41.8 | 108 | | |
| BATHURST TS DESN 1 | Total | M1,M2,M3,M7,M9,M10,M4,M5, M6, M8 | 27.6 | 26.6 | Sum of Buses | 0 | | |
| BATHURST TS DESN 2 | Total | M23,M25,M27,M31,M24,M26,M30,M32 | 27.6 | 24.0 | Sum of Buses | 0 | | |
| BATHURST TS DESN 2 | J | M24,M26,M30, M32 | 27.6 | 11.7 | 27.8 | 97 | | |
| BATHURST TS DESN 2 | Q | M23,M25,M27,M31 | 27.6 | 12.3 | 33.8 | 98 | | |
| BATTERSEA DS | T1 | F1,F2 | 12.5 | 1.1 | 7.1 | 409 | | |
| BATTERSEA DS | T2 | F3 | 12.5 | 1.0 | 7.7 | 396 | | |
| BATTERSEA DS | Total | F1,F2,F3 | 12.5 | 2.0 | 8.0 | 0 | | |
| BEACH TS - DESN1 | B1B2 | M11, M12, M13, M14, M21, M22, M23, M24 | 13.8 | 9.2 | 0.5 | 21 | | |
| BEACH TS - DESN1 | Total | M11, M12, M13, M14, M21, M22, M23, M24,M51,M52,M53,M54,M61,M62,M63 | 13.8 | 17.4 | Sum of Buses | 34 | | |
| BEACH TS - DESN1 | Y1Y2 | M51,M52,M53,M54,M61,M62,M63,M64 | 13.8 | 8.2 | 5.4 | 41 | | |
| BEACH TS - DESN2 | Total | M41,M42,M43, M44, M31,M32,M33,M34,M71,M72,M73,M74,M81,M82,M83,M84 | 13.8 | 0.4 | Sum of Buses | 21 | | |
| BEACH TS - DESN2 | J1J2 | M71,M72,M73,M74,M81,M82,M83,M84 | 13.8 | 7.1 | 2.8 | 34 | | |
| BEACH TS - DESN2 | Q1Q2 | M41,M42,M43, M44, M31,M32,M33,M34 | 13.8 | 6.7 | 5.8 | 20 | | |

SAMPLE - LIST OF APPLICATIONS

| Project Number | Station | Tx Feeder | Dx Station | Dx Feeder | CIA Initiated Date | Proposed Total Capacity (kW) |
|----------------|----------------|---------------------|-------------------------|-----------|--------------------|------------------------------|
| 752 | ALLANBURG TS | KM3 | | | 11/28/2006 | 1,056 |
| 2179 | ALLISTON TS | M4 | | | 9/7/2007 | 10,000 |
| 1830 | ALLISTON TS | M6 | | | 5/15/2008 | 10,000 |
| 63 | ALMONTE TS | M25 | | | 3/7/2007 | 5,000 |
| 1076 | ARMITAGE TS | M43 | | | 8/16/2007 | 1,500 |
| 1845 | ARMITAGE TS | M32 | | | 5/15/2008 | 10,000 |
| 1846 | ARMITAGE TS | M32 | | | 5/15/2008 | 10,000 |
| 1208 | ARNPRIOR TS | M2 | | | 9/28/2007 | 10,000 |
| 1209 | ARNPRIOR TS | M2 | | | 9/28/2007 | 10,000 |
| 561 | AYLMER TS | M2 | | | 12/4/2006 | 648 |
| 2098 | AYLMER TS | M2 | | | 7/17/2008 | 10,000 |
| 1266 | BASIN TS | A17BN, A19BN, A25BN | | | 2/5/2007 | 4,160 |
| 746 | BATHURST TS | M7 | | | 10/1/2006 | 6,000 |
| 1054 | BATTERSEA DS | F1 | | | 11/14/2007 | 498 |
| 2168 | BEAMSVILLE TS | M1 | | | 2/12/2008 | 10,000 |
| 2167 | BEAMSVILLE TS | M2 | | | 2/12/2008 | 10,000 |
| 2022 | BEAMSVILLE TS | M2 | | | 6/20/2008 | 10,000 |
| 1946 | BEARDMORE DS | F2 | | | 6/18/2008 | 700 |
| 1668 | BEAVERTON TS | M27 | PORT BOLSTER DS | F2 | 4/2/2008 | 100 |
| 10,110 | BEAVERTON TS | M24 | | | 2/12/2009 | 2,000 |
| 10,140 | BEAVERTON TS | M24 | | | 2/12/2009 | 2,500 |
| 8 | BELLE RIVER TS | M2 | | | 2/29/2000 | 10,000 |
| 837 | BELLEVILLE TS | M5 | STIRLING DS | F3 | 8/22/2007 | 498 |
| 10,130 | BELLEVILLE TS | M7 | | | 2/12/2009 | 6,800 |
| 1123 | BRANTFORD TS | M26 | | | 8/15/2007 | 8,100 |
| 1402 | BROCKVILLE TS | M3 | BROCKVILLE SCHOFIELD DS | F41 | 1/7/2008 | 90 |
| 1932 | BROWN HILL TS | M1 | | | 5/22/2008 | 10,000 |
| 1017 | BUCHANAN TS | M21 | | | 7/18/2007 | 10,000 |
| 1018 | BUCHANAN TS | M21 | | | 7/18/2007 | 10,000 |
| 1994 | BUCHANAN TS | M22 | | | 6/9/2008 | 2,850 |
| 2125 | BUCHANAN TS | M22 | | | 7/4/2008 | 10,000 |
| 2126 | BUCHANAN TS | M22 | | | 7/4/2008 | 7,000 |
| 750 | BUNTING TS | BUM55 (BUM61) | | | 5/30/2006 | 2,000 |

Thank You

Please stay in touch with your account executive
and monitor www.HydroOne.com
for future developments