



ALL DIMENSIONS IN CENTIMETRES
UNLESS OTHERWISE STATED

PARTS LIST			
PART No.	MM No.	DESCRIPTION	QTY.
1	30008431 30008430	INSULATOR, LP15 WITH CLAMP OR INSULATOR, LP28 WITH CLAMP	1
2	30000800	BRACKET, POLE TOP, TANGENT	1
3	30000905	STUD, INSULATOR, 3/4" x 3"	1
4	MM#	BOLT, 3/4"	4
5	30000808 30029184	CLAMP, NEUTRAL CONDUCTOR	1
6	30001595	WASHER, 3/4" x 2" x 2"	5
7	10000108	LOCKWASHER, FOR 3/4" BOLT	1
MM# = REFER TO SECTION 16 ONLY			A/R = AS REQUIRED

02	MAY 2017	GENERAL UPDATES. CHANGED TO NEW DWG. & NUMBERING FORMAT. FOR PREVIOUS REVISION REFER TO DL3-101.1-R1.	SO	PC	MM	JB
01	AUG 2011	MM# ADDED	WB	PC		
Rev No.	Date	Revision Particulars	dwn	ckd	des	app

Drawn By: WB	Checked By: PC	Designed By:	Design Approved By:
Scale: N.T.S.	Date: (yyyy/mm/dd) 2011/08/25	Pole ID:	



Title:
PRIMARY 1-PH TANGENT (LP INSULATOR)
1Ø, 2.4kV TO 16kV, MAX. SPAN 90m

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.
Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

Drawing No. DL3-101.1-0500	Rev. No. 02
-------------------------------	----------------

TITLE BLOCK REV 02 - AUGUST 2014