



ALL DIMENSIONS IN CENTIMETRES  
UNLESS OTHERWISE STATED

| PARTS LIST |                      |   |      |
|------------|----------------------|---|------|
| PART No.   | MM No.               | DESCRIPTION   | QTY. |
| 1          | 30008404<br>30008411 | INSULATOR, DEAD-END, DS15 OR<br>INSULATOR, DEAD-END, DS28 | 1    |
| 2          | 30007338             | CLEVIS BAIL, DEAD-END                                     | 2    |
| 3          | 30001595             | WASHER, 3/4" x 2" x 2"                                    | 2    |
| 4          | MM#                  | BOLT, 3/4"  | 2    |
| 5          | MM#                  | CLAMP, CONDUCTOR, DEAD-END                                | A/R  |
| 6          | MM#                  | GRIP, CONDUCTOR, PREFORMED, DEAD-END                      | 2    |
| 7          | 10000058             | BOLT-EYE, FOR 3/4" BOLT                                   | 2    |

MM# = REFER TO SECTION 16 ONLY    A/R = AS REQUIRED

|         |           |   |     |     |     |     |
|---------|-----------|---|-----|-----|-----|-----|
| 03      | JUNE 2022 | ADDED SWING AWAY OPTION ALTERNATIVE TO DEAD-END CLEVIS/PREFORM CONNECTION AT NEUTRAL LEVEL.         | PC  | MM  | SP  | MM  |
| 02      | MAY 2017  | GENERAL UPDATES. CHANGED TO NEW DWG. & NUMBERING FORMAT. FOR PREVIOUS REVISION REFER TO DL3-105-R1. | SO  | PC  | MM  | JB  |
| Rev No. | Date      | Revision Particulars  | dwn | ckd | des | app |

|                  |                                  |              |                     |
|------------------|----------------------------------|--------------|---------------------|
| Drawn By:<br>WB  | Checked By:<br>PC                | Designed By: | Design Approved By: |
| Scale:<br>N.T.S. | Date: (yyyy/mm/dd)<br>2011/08/25 | Pole ID:     |                     |



Title:  
PRIMARY 1-PH DEAD-END  
1Ø, 2.4kV TO 16kV, MAX. SPAN 90m

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.  
Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

|                             |                |
|-----------------------------|----------------|
| Drawing No.<br>DL3-105-0500 | Rev. No.<br>03 |
|-----------------------------|----------------|

TITLE BLOCK REV 02 – AUGUST 2014