


TABLE 1: CRIB HEIGHTS							
POLE HEIGHT IN m/(ft)	DL4-202-0500 SETTING "A" BUTT OF POLE RESTING ON OR PENETRATING SOLID EARTH AT NORMAL SETTING DEPTH					DL4-202-0500 SETTING "B" BUTT OF POLE NOT REACHING SOLID EARTH AT NORMAL SETTING DEPTH	
	DEPTH OF PENETRATION cm/(ft)						
	30 (1')	60 (2')	90 (3')	120 (4')	150 (5')	180 (6')	
HEIGHT OF CRIB IN cm/(ft)							
12.2 (40')	120 (4')	90 (3')	60 (2')	60 (2')	*	*	120 (4')
13.7 (45')	120 (4')	90 (3')	60 (2')	60 (2')	*	*	120 (4')
15.2 (50')	137 (4.5')	106 (3.5')	76 (2.5')	60 (2')	60 (2')	*	137 (4.5')
16.7 (55')	150 (5')	120 (4')	90 (3')	60 (2')	60 (2')	*	150 (5')
18.2 (60')	167 (5.5')	137 (4.5')	106 (3.5')	76 (2.5')	60 (2')	*	167 (5.5')
19.8 (65')	167 (5.5')	137 (4.5')	106 (3.5')	76 (2.5')	60 (2')	*	167 (5.5')
21.3 (70')	180 (6')	150 (5')	120 (4')	90 (3')	60 (2')	*	180 (6')
22.8 (75')	180 (6')	150 (5')	120 (4')	90 (3')	60 (2')	*	180 (6')
24.3 (80')	198 (6.5')	167 (5.5')	137 (4.5')	106 (3.5')	76 (2.5')	60 (2')	198 (6.5')

* NO CRIBBING REQUIRED, HOWEVER IN THE IMMEDIATE AREA OF THE POLE, REMOVE SWAMP AND MOVE MUSKEG BETWEEN SOLID EARTH LEVEL AND GRADE AND REPLACE WITH STONE AS SHOWN IN DL4-202-0500.

NOTES:

1. MINIMUM HEIGHT OF CRIB FOR ANY CONDITION SHALL BE 60cm (2').

ALL DIMENSIONS ARE IN CENTIMETRES UNLESS STATED OTHERWISE

02	AUG 2021	UPDATED TABLE FORMAT AND REMOVED NOTE 2. UPDATED TO NEW DRAWING AND NUMBERING FORMAT. FOR PREVIOUS REVISIONS REFER TO DL4-201-R1.	LS	PC	JX	MM	Drawn By: BA	Checked By:	Designed By:	Design Approved By: *	
01	AUG 2014	DEFINITION OF "*"	SO	PC			Scale:	Date: (yyyy/mm/dd) *	Pole ID:		
Rev No.	Date	Revision Particulars	dwn	ckd	des	app	Title: TABLE OF CRIB HEIGHTS FOR WOOD POLE IN SWAMP				
							Drawing No. DL4-201-0500				Rev. No. 02

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.
Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

TITLE BLOCK REV 02 – AUGUST 2014