



LOAD
(CUSTOMER)
THREE PHASE, FOUR WIRE
GROUNDED WYE SERVICE
120/208V, 277/480 OR 347/600V

NOTES

1. SEPARATE BONDING CONDUCTOR TO BE RUN TO METER SOCKET FROM NEUTRAL BONDING POINT IN MAIN SERVICE DISCONNECT.

TITLE BLOCK REV 02 - AUGUST 2014

01	DEC 2021	ORIGINAL RM8-19-0500 NOW SUPERSEDED BY THIS NEW DRAWING/REVISION.	PC	MS	MS	MS
Rev No.	Date	Revision Particulars	dwn	ckd	des	app
Hydro One Networks Inc.		Title: SELF-CONTAINED SOCKET METER-BASE 3PH, 4W, UP TO 347/600V, CWD 200A MAXIMUM				
© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.			Drawing No. RM8-200-0500		Rev. No. 01	
Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.						