



Stantec Consulting Ltd.
300 - 675 Cochrane Drive West Tower
Markham ON L3R 0B8
Tel: (905) 944-7777
Fax: (905) 474-9889

June 13, 2014
File: 160900764

Attention: Mr. Paul Dalmazzi
HydroOne
Environmental Engineering and Project Support
483 Bay Street, 6th Floor, South Tower
Toronto, ON M5G 2P5

Dear Mr. Dalmazzi,

Reference: Groundwater and Surface Water Monitoring Program, Clarington Transformer Station

Stantec Consulting Ltd. (Stantec) is pleased to submit to Hydro One Networks Inc. (Hydro One) our Groundwater and Surface Water Monitoring Program for the Clarington Transformer Station. The transformer station is to be located on Hydro One property ('*Project Area*') located in the Regional Municipality of Durham, in the Municipality of Clarington, on Part Lots 33, 34, and 35, Concession Road #7. The *Project Area* and the extents of the transformer station itself, hereinafter referred to as the '*Site*', are shown on Figure 1.

BACKGROUND

In their Class EA Project Environmental Study Report (Project ESR), Hydro One has committed to undertake a groundwater and surface water monitoring program that includes monitoring wells and surface water monitoring locations within its property boundaries (*Project Area*), and offering private well monitoring to well owners on properties immediately adjacent to the *Site*. This commitment is to cover pre, during, and post transformer station construction periods, and will include monitoring of water levels and water quality.

Stantec compiled available geotechnical and hydrogeological information as well as reviewed Ontario Ministry of the Environment (MOE) water well records, Ontario Geological Survey mapping, Oak Ridges Moraine Conservation Plan, and Ministry of Affairs and Housing Greenbelt Plan. Stratigraphy beneath the *Site* is found to consist of silt till overburden which is known as the Newmarket Till, with pockets of Halton Till at surface. The till contains occasional isolated sand to silty sand lenses, with several nearby private wells reportedly installed within these lenses. The MOE water well record database indicates the presence of a deep (greater than 75 m below ground surface) silty sand aquifer consisting of medium to fine sand and gravel which is regionally recognized as the Thorncliffe Aquifer.

OBJECTIVES

The following Groundwater and Surface Water Monitoring Program has three primary objectives: to fulfill Hydro One's commitment to implement a pre, during, and post transformer station



Reference: Groundwater and Surface Water Monitoring Program, Clarington Transformer Station

construction groundwater and surface water monitoring program; to refine our understanding of the physical and chemical characteristics of the shallow and intermediate depth groundwater systems at the *Site*; and to establish a pre-construction baseline of groundwater conditions, including seasonal variations of groundwater quality, quantity, and surface water / groundwater interaction. The monitoring data collected will provide the technical foundation on which to assess whether adverse impacts occurred during or post construction.

MONITORING PROGRAM SCOPE

The Groundwater and Surface Water Monitoring Program includes several key tasks, including installing new groundwater monitoring wells (completed in Fall 2013), implementing a private well monitoring program, surface water monitoring, decommissioning of geotechnical monitoring wells (completed Fall 2013), water level and water quality monitoring, and preparing annual monitoring summary reports through the duration of the monitoring program.

Complementing the groundwater monitoring program, surface water features located on the north (wetland), west (creek), and south (drainage swale) sides of the *Site* will be monitored. Background water levels within three newly installed shallow piezometers (mini shallow wells) will be recorded prior to construction of the transformer station, and compared to monitoring results recorded during and post construction. The monitoring data collected will provide the technical foundation on which to further characterize our understanding of the shallow groundwater system, to assess whether adverse impacts occurred during or post construction, and to provide guidance for appropriate mitigation, if needed.

Owners of private wells on properties immediately adjacent to the east and south of the *Site* will be able to have the water level and water quality in their wells monitored prior to, during, and post construction of the transformer station. A baseline of seasonal normal groundwater levels and groundwater quality will be established prior to construction of the transformer station. Once construction of the transformer station begins, the well monitoring program will continue with observations compared to baseline conditions, allowing for an assessment of potential impacts on the natural environment and of the efficacy of the engineered containment structures and water treatment systems to be installed.

Groundwater and surface water data collected prior to construction of the transformer station will help define the relationship between the shallow and intermediate depth groundwater systems at the Site and how they interact with each other; providing a baseline to which monitoring data collected during construction and post construction will be compared. Specifically, the Groundwater and Surface Water Monitoring Program will allow for quantification of the following hydrogeological characteristics of the site:

- Refinement of Site geologic stratigraphy;
- Seasonal shallow and intermediate groundwater water levels across the site;
- Seasonal shallow and intermediate groundwater chemistry;



Reference: Groundwater and Surface Water Monitoring Program, Clarington Transformer Station

- Vertical groundwater gradients (identify areas of upward, neutral, or downward groundwater movement) between surface water and shallow groundwater system, and shallow and intermediate depth groundwater systems;
- Shallow and intermediate depth hydraulic conductivity, including variations in hydraulic conductivity associated with the different geologic materials identified during previous and recent drilling programs;
- Continuous (hourly) groundwater level monitoring to allow for observation and calculation of seasonal variations in surface water, groundwater, and private wells; and,
- Potential changes in shallow groundwater elevation associated with the cut portion (east side) of the grading area, including the potential radius of groundwater influence, and potential for private well interference.

The hydrogeologic conditions presented in the Project ESR will be confirmed through the analyses and interpretation of groundwater and surface water data collected prior to construction of the transformer station. The monitoring program will continue during and post construction of the transformer station in order to confirm that the mitigation measures and engineered containment structures designed to protect the natural form and function of the surface water system, shallow and intermediate groundwater systems, and the adjacent private water wells are functioning as designed.

MONITORING INSTALLATIONS

The Groundwater and Surface Water Monitoring Program takes into consideration potential adverse impacts of the project on the natural environment in the absence of implementing any mitigations measures (containment structures, water treatment, etc.). These include the introduction of chemical substances and changes to the natural form and function of the shallow and intermediate depth groundwater and surface water systems. As a result, the depths of the monitoring wells, monitoring frequency, and selected water quality analyses of the entire monitoring program have been selected with detection of potential changes to these receptors as their primary objective.

Site Monitoring Wells

The groundwater monitoring wells installed at the *Site* during the previous geotechnical investigations were all installed at an intermediate depth (screened between approximately 11 m and 15 m depth). These monitoring wells were located where excavations for footings or foundations are planned, and as a result, needed to be decommissioned prior to construction of these foundations.

In the Fall of 2013, this monitoring program was initiated by installing pairs of new monitoring wells on each side of the *Site* (Figure 1). The new intermediate depth (approximately 10 m to 15 m depth) wells have been paired with shallow depth wells (approximately 1 m to 3 m depth) intended to intersect the elevation of the shallow water table. By installing pairs of shallow and intermediate depth wells, changes in groundwater levels, groundwater chemistry and vertical



Reference: Groundwater and Surface Water Monitoring Program, Clarington Transformer Station

hydraulic gradients (upward or downward movement of groundwater) will be able to be measured and monitored seasonally prior to, during, and post construction of the transformer station.

Drive point piezometers (shallow mini wells) have also been installed within the *Site's* surface water features in order to monitor seasonal shallow groundwater and surface water levels within the wetland (north side), creek (west side) and drainage swale (south side) features found on-*Site*.

The new groundwater monitoring wells were installed according to the MOE Water Resource Act (O. Reg. 903). A licensed well drilling contractor was retained and has completed the following:

- Installation of three (3) stream/wetland drive-point piezometers;
- Drilling and installation of four (4) shallow and intermediate depth pairs of groundwater monitoring wells (8 wells in total); advanced to depth of approximately 1 to 3 m and 10 to 15 m, respectively;
- Complete grouting (sealing) of outer well annulus;
- Installation of protective and lockable well casing; and
- Decommissioning of former geotechnical wells according to the MOE Water Resource Act (O. Reg. 903).

Upon completing installation of the new monitoring wells in December 2013, the water level in several wells were observed to have recovered slowly, with some not recovering sufficiently after several days to allow for a collection of water quality samples. Monitoring of the new wells will continue with the completion of a water level monitoring event in Winter 2014, noting if any wells are frozen.

In Spring 2014, the new wells will be developed, hydraulically tested (slug tests) to confirm estimates presented in the Project ESR, and sampled for groundwater quality. Selected representative soil samples obtained and preserved during drilling will be submitted for laboratory sieve grain size analyses.

Private Well Monitoring

The private well monitoring program will include providing notification to all potential groundwater users within 1,200 m of the *Site*, informing the property and/or well owners of the transformer station construction schedule, and the parameters of the private well monitoring program.

The distributed notification information will provide the details of the monitoring program, and include appropriate project contact information for Hydro One regarding construction concerns. During the door-to-door site visits, Stantec will also make note of and attempt to contact well owners that may not appear in the MOE's records for the purpose of offering participation in the private well monitoring program.



Reference: Groundwater and Surface Water Monitoring Program, Clarington Transformer Station

Participation in the private well monitoring program will only be completed with the owner's authorization, and will include water quality sampling and water level monitoring, depending on well accessibility. Water level monitoring involves installing an automated well water level logger (pressure transducer), which can only be completed at accessible wells by a licensed well contractor. The automated loggers will monitor 'continuous' water levels (at 5 to 60 minute intervals) from Spring 2014 until two years following completion of construction. The loggers would be removed at the end of the monitoring program.

Private well water quality samples will be collected from a raw water tap (prior to any treatment or filtration), where available. If no raw water tap is present, a sample may be collected directly from the well, depending on well accessibility and well owner authorization. After purging water from the well, the samples will be collected directly into laboratory supplied sample containers. The samples will not be field filtered and will be submitted for general chemistry, turbidity, metals, hydrocarbons (F1-F4 and BTEX), and bacteriological analyses. To supplement and provide quality assurance, temperature, conductivity, and pH data will be collected in the field at the time of sampling.

Individual private well analytical results will be presented in a letter to each resident following each sampling event along with the available water level data. Private well data will remain confidential, and is not permitted to be shared with the general public. However, monitoring reports for data collected on-*Site* will be prepared annually and made available to the public by Hydro One.

SURFACE WATER MONITORING

A Stantec terrestrial ecologist will monitor the *Site* prior to transformer station construction to confirm the presence or absence of groundwater seeps within the *Project Area*, identifying notable indicator parameters and plant species. Ecological monitoring will continue annually during construction of the transformer station, and for two years following completion of construction. Surface water levels and water quality samples will be collected from three (3) surface water monitoring locations (at piezometer installation locations) and submitted for laboratory analyses following the monitoring schedule discussed below.

WATER QUALITY ANALYSES

Groundwater water quality samples from each of the new on-*Site* monitoring wells and participating private wells will be collected according to laboratory protocols, preserved, and submitted for laboratory analyses (general chemistry, metals, and hydrocarbons (F1-F4 and BTEX)) to Maxxam Analytics, an accredited laboratory. Well water quality parameter analyses will be compared to Ontario Drinking Water Quality Standards (ODWQS).

Surface water quality samples will be collected from each of the three new surface water monitoring locations adjacent to the new piezometer installations (when surface water is present) according to laboratory protocols, preserved, and submitted for laboratory analyses (general



Reference: Groundwater and Surface Water Monitoring Program, Clarington Transformer Station

chemistry, metals, and hydrocarbons (F1-F4 and BTEX)) to Maxxam Analytics. Surface water quality parameter analyses will be compared to Provincial Water Quality Objectives (PWQO).

A water quality parameter list is included in the attached Tables 1 and 2.

MONITORING SCHEDULE

The Groundwater and Surface Water Monitoring Program schedule frequency is designed to record groundwater levels continuously with the use of automated pressure transducers, and to seasonally (quarterly) collect groundwater and surface water quality samples for laboratory analyses for the first year of monitoring in order to establish potential seasonal variations in groundwater levels and chemistry. Table 1 presents the program water quality sampling schedule. Following the first year of quarterly (seasonal) monitoring, the schedule will change to semi-annual monitoring (spring and fall). Upon completion of construction, monitoring of groundwater, surface water, and private wells will continue semi-annually for two years.

For scheduling purposes, it is anticipated that quarterly seasonal monitoring will take place from Fall 2013 to Summer 2014; semi-annual (construction) monitoring will continue from Fall 2014 through to Fall 2017; and semi-annual post-construction monitoring will extend for 2 years following completion of construction. Presently, construction is anticipated to be completed in Fall 2017, with this monitoring program continuing until Fall 2019.

Table 1 - Monitoring Schedule

Pre-Construction and Construction Monitoring Schedule											
2013				2014				2015			
Winter	Spring	Summer	Fall	Winter	Spring	Summer	Fall	Winter	Spring	Summer	Fall
			X	X	X	X	X		X		X
2016				2017							
Winter	Spring	Summer	Fall	Winter	Spring	Summer	Fall				
	X		X		X		X				
Post-Construction Monitoring Schedule											
2018				2019							
Winter	Spring	Summer	Fall	Winter	Spring	Summer	Fall				
	X		X		X		X				



June 13, 2014
Mr. Paul Dalmazzi
Page 7 of 8

Reference: Groundwater and Surface Water Monitoring Program, Clarington Transformer Station

REPORTING

A *Baseline Conditions Report* will be prepared following the Fall 2014 monitoring event presenting the *Site* baseline groundwater and surface water data collected prior to construction of the transformer station (Fall 2013 through Fall 2014).

Subsequent annual monitoring program summary reports will be prepared following the annual Fall monitoring and sampling events. The reports will present continuous records of all on-Site groundwater and surface water monitoring data and a general summary of private well water level and water quality data. Private well owners will be provided with the data (water level and water quality) from their own individual well(s) only. In the event private water quality laboratory results indicate an exceedence of the ODWQS, the private well owner will be advised of the exceedence immediately upon receipt and review of the data.

IMPLEMENTATION

A Community Liaison Committee (CLC) was formed on May 29, 2014 and conducted its first meeting on June 5, 2014. The committee consists of representatives from HydroOne, local environmental organizations, local area residents and three First Nations. CLC meetings are also open to any other organizations and/or members of the public to observe, and observers are also given the opportunity to ask questions or to comment at the conclusion of each meeting. The CLC provides a forum for the exchange and dissemination of project information between Hydro One and the local community, as per Condition 5.1 of the Minister of the Environment's decision to deny the Part II Order Requests received for the Clarington TS Class Environmental Assessment.

CLC meetings will be the primary avenue for Hydro One to disseminate monitoring information and results to community members. A presentation was made at the initial CLC meeting on June 5, 2014 introducing the Monitoring Program, and questions and comments were received from CLC members and observers. The next CLC meeting is planned for late Fall 2014, in advance of the start of site grading and construction of the Clarington Transformer Station itself. The *Baseline Conditions Report* will be provided to the MOE, CLOCA, and CLC stakeholders in advance of the Fall 2014 meeting for review.

Hydro One will also actively disseminate information and engage in dialogue with members of the community through avenues other than the CLC. Hydro One will share information and interact with the community through newspaper ads, Project newsletters, personal communications with interested stakeholders, a dedicated project hotline and email inbox, and a project website: (<http://www.hydroone.com/Projects/Clarington/Pages/default.aspx>).

Hydro One will also be employing a dedicated Community Liaison Officer to be on-site during the construction phase of the project. All of the above-mentioned avenues for communication with the community will be used to share information about the Monitoring Program progress and results, where necessary.



June 13, 2014
Mr. Paul Dalmazzi
Page 8 of 8

Reference: Groundwater and Surface Water Monitoring Program, Clarington Transformer Station

The Monitoring Program will be adaptive. Changes to the monitoring program and/or laboratory analyses may be implemented, as determined by Hydro One and its environmental consultant, subject to approval of the MOE Central Region Director, with consideration of the monitoring results and professional interpretations derived from them. HydroOne will continue to encourage input from regulatory agencies, CLC stakeholders, and individual well owners as this project progresses from pre-construction through to completion and on to post-construction monitoring.

CLOSURE

This Groundwater and Surface Water Monitoring Program will fulfill the environmental monitoring commitments made by Hydro One in the Project's ESR by establishing background hydrogeological conditions and by providing a monitoring program that will identify and monitor the natural form and function of the shallow and intermediate depth groundwater system during and post construction.

Regards,

STANTEC CONSULTING LTD.

J. Brant Gill, H.B.Sc., P.Geo.
Senior Hydrogeologist
Phone: (905) 415-6330
Fax: (905) 474-9889
brant.gill@stantec.com









Attachment: Figure 1 – Groundwater and Surface Water Monitoring Locations
Figure 2 – Private Well Monitoring Program Area
Table 1 – General Chemistry and Hydrocarbon Water Quality Parameters
Table 2 – Semi-VOC and VOC Water Quality Parameters

c. Dan Eusebi - Stantec

jbg let_MOE-GW-SW Monitoring Program_13Jun2014_FINAL.docx



Legend

-  Monitoring Well (Stantec, 2013)
-  Piezometer (Stantec, 2013)
-  Existing Power Feature
-  New Infrastructure
-  Topographic Contour (mAMSL)
-  Watercourse
-  Project Area
-  Clarington TS Site

Notes

1. Coordinate System: NAD 1983 UTM Zone 17N
2. Base features produced under license with the Ontario Ministry of Natural Resources © Queen's Printer for Ontario, 2012.
3. Orthoimagery © First Base Solutions, 2012.



Stantec







February 2014
160960745

Client/Project
Hydro One Networks Inc.
Groundwater and Surface Water Monitoring Program
Clarington, Ontario

Figure No.
1

Title
**Groundwater & Surface Water
Monitoring Locations**




- Legend**
-  Clarington Transformer Station
 -  Private Well Monitoring Area
 -  MOE Water Well Record
 -  Topographic Contour (mAMSLL)
 -  Watercourse
 -  Waterbody

- Notes**
1. Coordinate System: NAD 1983 UTM Zone 17N
 2. Base features produced under license with the Ontario Ministry of Natural Resources © Queen's Printer for Ontario, 2013.
 3. Orthoimagery © First Base Solutions, 2012.
 4. MOE Water well locations are approximate and have been positioned based on published UTM coordinates © Queen's Printer for Ontario, 2012.

Client/Project
 Hydro One Networks Inc.
 Hydrogeologic & Hydrologic Assessment Report
 Clarington, Ontario

Figure No.
2

Title
Private Well Monitoring



G:\archive\60960745\drawing\WXD\Hydrogeology\GW_SW_Monitoring\160960745_GWSWM_Fig02_GW_SW_PrivateWellMon.mxd
 Revised: 2014-04-13 By: searles

June 2014
 160960745

Table 1 - General Chemistry and Hydrocarbon Groundwater Parameters

General Chemistry			Limit	Dissolved Metals			Limit
Acidity (as CaCO ₃)	mg/L	n/v		Dissolved Aluminum (Al)	mg/L	0.075	
Alkalinity - Bicarbonate (as CaCO ₃)	mg/L	n/v		Dissolved Mercury (Hg)	mg/L	0.0002	
Alkalinity - Carbonate (as CaCO ₃)	mg/L	n/v					
Alkalinity - Total (as CaCO ₃)	mg/L	25%		Total Metals			
Anion Sum	meq/L	n/v		Total Antimony (Sb)	mg/L	0.020	
Cation Sum	meq/L	n/v		Total Arsenic (As)	mg/L	0.020	
Chloride (Dissolved)	mg/L	n/v		Total Barium (Ba)	mg/L	0.210	
Cyanide (Free)	mg/L	0.005		Total Beryllium (Be)	mg/L	0.011	
Dissolved Organic Carbon (DOC)	mg/L	n/v		Total Boron (B)	mg/L	0.200	
Electrical Conductivity	µmhos/cm	n/v		Total Cadmium (Cd)	mg/L	0.008	
Fluoride	mg/L	n/v		Total Chromium VI	mg/L	0.08	
Total Hardness (CaCO ₃)	mg/L	n/v		Total Cobalt (Co)	mg/L	0.0009	
Ion Balance	%	n/v		Total Copper (Cu)	mg/L	0.05	
Nitrate (as N)	mg/L	n/v		Total Iron (Fe)	mg/L	0.300	
Nitrate + Nitrite (as N)	mg/L	n/v		Total Lead (Pb)	mg/L	0.12	
Nitrite (as N)	mg/L	n/v		Total Molybdenum (Mo)	mg/L	0.040	
Orthophosphate (as P)	mg/L	n/v		Total Nickel (Ni)	mg/L	0.15	
pH	S.U.	6.5 - 8.5		Total Phosphorus (P)	mg/L	0.02	
Phosphorus, Total	mg/L	0.02		Total Selenium (Se)	mg/L	0.020	
Sulfate (Dissolved)	mg/L	n/v		Total Thallium (Tl)	mg/L	0.0003	
Total Dissolved Solids	mg/L	n/v		Total Vanadium (V)	mg/L	0.006	
Total Dissolved Solids (Calculated)	mg/L	n/v		Total Zinc (Zn)	mg/L	0.040	
Total Organic Carbon	mg/L	n/v		Total Zirconium (Zr)	mg/L	0.004	
Total Suspended Sediment	mg/L	CCME*					
Turbidity, Lab	ntu	CCME*		BTEX & F1 Hydrocarbons			
				F1 (C6-C10)	mg/L	0.025	
				F1 (C6-C10) - BTEX	mg/L	0.025	
				F2-F4 Hydrocarbons			
				F2 (C10-C16 Hydrocarbons)	mg/L	0.010	
				F3 (C16-C34 Hydrocarbons)	mg/L	0.240	
				F4 (C34-C50 Hydrocarbons)	mg/L	0.120	

Table 2 - Semivolatile and Volatile Organics

Semivolatile Organics			Volatile Organics		Limit
1,2,4-Trichlorobenzene	mg/L	0.00005	Acetone (2-Propanone)	mg/L	0.00050
1-Methylnaphthalene	mg/L	0.00005	Benzene	mg/L	0.00002
2,4,5-Trichlorophenol	mg/L	0.0001	Bromodichloromethane	mg/L	0.00005
2,4,6-Trichlorophenol	mg/L	0.0001	Bromoform	mg/L	0.00005
2,4-Dichlorophenol	mg/L	0.0001	Bromomethane	mg/L	0.00005
2,4-Dimethylphenol	mg/L	0.0002	Carbon Tetrachloride	mg/L	0.00005
2,4-Dinitrophenol	mg/L	0.002	Chlorobenzene	mg/L	0.00005
2,4-Dinitrotoluene	mg/L	0.0005	Chloroform	mg/L	0.00005
2,6-Dinitrotoluene	mg/L	0.0005	Dibromochloromethane	mg/L	0.00005
2-Chlorophenol	mg/L	0.0001	1,2-Dichlorobenzene	mg/L	0.00005
2-Methylnaphthalene	mg/L	0.00005	1,3-Dichlorobenzene	mg/L	0.00005
3,3'-Dichlorobenzidine	mg/L	0.001	1,4-Dichlorobenzene	mg/L	0.00005
Acenaphthene	mg/L	0.00005	Dichlorodifluoromethane (FREON 12)	mg/L	0.00005
Acenaphthylene	mg/L	0.000093	1,1-Dichloroethane	mg/L	0.00005
Anthracene	mg/L	0.00005	1,2-Dichloroethane	mg/L	0.00005
Benzo(a)anthracene	mg/L	0.000095	1,1-Dichloroethylene	mg/L	0.00005
Benzo(a)pyrene	mg/L	0.00005	cis-1,2-Dichloroethylene	mg/L	0.00005
Benzo(b/j)fluoranthene	mg/L	0.0003	trans-1,2-Dichloroethylene	mg/L	0.00005
Benzo(g,h,i)perylene	mg/L	0.0002	1,2-Dichloropropane	mg/L	0.00005
Benzo(k)fluoranthene	mg/L	0.00005	cis-1,3-Dichloropropene	mg/L	0.00005
Biphenyl	mg/L	0.00005	trans-1,3-Dichloropropene	mg/L	0.00005
Bis(2-chloroethyl)ether	mg/L	0.0005	Ethylbenzene	mg/L	0.00005
Bis(2-chloroisopropyl)ether	mg/L	0.0005	Ethylene Dibromide	mg/L	0.00005
Bis(2-ethylhexyl)phthalate	mg/L	0.005	Hexane	mg/L	0.00005
Chrysene	mg/L	0.00018	Methylene Chloride(Dichloromethane)	mg/L	0.00005
Dibenz(a,h)anthracene	mg/L	0.0001	Methyl Isobutyl Ketone	mg/L	0.0005
Diethyl phthalate	mg/L	0.0005	Methyl Ethyl Ketone (2-Butanone)	mg/L	0.0005
Dimethyl phthalate	mg/L	0.0005	Methyl t-butyl ether (MTBE)	mg/L	0.00005
Fluoranthene	mg/L	0.00024	Styrene	mg/L	0.00005
Fluorene	mg/L	0.00005	1,1,1,2-Tetrachloroethane	mg/L	0.00005
Indeno(1,2,3-cd)pyrene	mg/L	0.00011	1,1,2,2-Tetrachloroethane	mg/L	0.00005
Naphthalene	mg/L	0.00005	Tetrachloroethylene	mg/L	0.00005
p-Chloroaniline	mg/L	0.0005	Toluene	mg/L	0.0002
Pentachlorophenol	mg/L	0.0001	1,1,1-Trichloroethane	mg/L	0.00005
Phenanthrene	mg/L	0.00019	1,1,2-Trichloroethane	mg/L	0.00005
Phenol	mg/L	0.0005	Trichloroethylene	mg/L	0.00005
Pyrene	mg/L	0.00019	Vinyl Chloride	mg/L	0.00002
PCBs			p+m-Xylene	mg/L	-
Total PCBs	mg/L	0.0003	o-Xylene	mg/L	-
			Xylene (Total)	mg/L	0.00005
			Trichlorofluoromethane (Freon 11)	mg/L	0.00005