



# **Metro Toronto**

## **REGIONAL INFRASTRUCTURE PLAN**

January 12, 2016



[This page is intentionally left blank]

**Prepared by:**

Hydro One Networks Inc. (Lead Transmitter)

**With support from:**

| Company                                 |
|---|
| Enersource Hydro Mississauga            |
| Hydro One Networks Inc. (Distribution)  |
| Independent Electricity System Operator |
| PowerStream Inc.                        |
| Toronto Hydro-Electric System Limited   |
| Veridian Connections Inc.               |



[This page is intentionally left blank]

## DISCLAIMER

This Regional Infrastructure Plan (“RIP”) report was prepared for the purpose of developing an electricity infrastructure plan to address electrical supply needs identified in previous planning phases and also any additional needs identified based on new and/or updated information provided by the RIP Working Group.

The preferred solution(s) that have been identified in this report may be reevaluated based on the findings of further analysis. The load forecast and results reported in this RIP report are based on the information provided and assumptions made by the participants of the RIP Working Group.

Working Group participants, their respective affiliated organizations, and Hydro One Networks Inc. (collectively, “the Authors”) make no representations or warranties (express, implied, statutory or otherwise) as to the RIP report or its contents, including, without limitation, the accuracy or completeness of the information therein and shall not, under any circumstances whatsoever, be liable to each other, or to any third party for whom the RIP report was prepared (“the Intended Third Parties”), or to any other third party reading or receiving the RIP report (“the Other Third Parties”), for any direct, indirect or consequential loss or damages or for any punitive, incidental or special damages or any loss of profit, loss of contract, loss of opportunity or loss of goodwill resulting from or in any way related to the reliance on, acceptance or use of the RIP report or its contents by any person or entity, including, but not limited to, the aforementioned persons and entities.

[This page is intentionally left blank]

## EXECUTIVE SUMMARY

THIS REGIONAL INFRASTRUCTURE PLAN (“RIP”) WAS PREPARED BY HYDRO ONE WITH SUPPORT FROM THE WORKING GROUP IN ACCORDANCE TO THE ONTARIO TRANSMISSION SYSTEM CODE REQUIREMENTS. IT IDENTIFIES INVESTMENTS IN TRANSMISSION FACILITIES, DISTRIBUTION FACILITIES, OR BOTH, THAT SHOULD BE DEVELOPED AND IMPLEMENTED TO MEET THE ELECTRICITY INFRASTRUCTURE NEEDS WITHIN THE METRO TORONTO REGION.

The participants of the RIP Working Group included members from the following organizations:

- Enersource Hydro Mississauga
- Hydro One Networks Inc. (Distribution)
- Independent Electricity System Operator (“IESO”)
- PowerStream Inc.
- Toronto Hydro-Electric System Limited (“THESL”)
- Veridian Connections Inc.
- Hydro One Networks Inc. (Transmission)

This RIP is the final phase of the regional planning process and it follows the completion of the Central Toronto Sub-Region’s Integrated Regional Resource Plan (“IRRP”) by the IESO in April 2015 and the and Metro Toronto Northern Sub-Region’s Needs Assessment (“NA”) Study by Hydro One in June 2014.

This RIP provides a consolidated summary of needs and recommended plans for both the Central Toronto Sub-Region and Metro Toronto Northern Sub-Region that make up the Metro Toronto Region.

The Central Toronto IRRP has identified longer term needs beyond 2025. These longer term needs are also reviewed and discussed in this report. However, as the need dates are beyond 2025, adequate time is available to develop a preferred alternative in the next planning cycle expected to be started in 2018.

The major infrastructure investments planned for the Metro Toronto Region over the near and mid-term, identified in the various phases of the regional planning process, are given in the Table below.

| No. | Project   | I/S date | Cost (\$M) |
|-----|---|----------|------------|
| 1   | Manby Autotransformer Overload Protection Scheme            | 2018     | \$2        |
| 2   | Runnymede TS Expansion & Manby x Wiltshire Corridor Upgrade | 2019     | \$90       |
| 3   | Horner TS Expansion   | 2020     | \$53       |
| 4   | Richview x Manby Corridor Upgrade                           | 2020     | \$20-40    |
| 5   | Copeland MTS Phase 2  | 2020+    | \$46       |

In accordance with the Regional Planning process, the Regional Planning cycle should be triggered at least every five years. As mentioned above, the next planning cycle is expected to be started in 2018. However, the Region will continue to be monitored and should there be a need that emerges due to a change in load forecast or any other reason, the regional planning cycle will be started earlier to address the need.



# TABLE OF CONTENTS

|  |    |
|--|----|
| Disclaimer .....   | 5  |
| Executive Summary .....  | 7  |
| Table of Contents .....  | 9  |
| List of Figures .....  | 11 |
| List of Tables .....   | 11 |
| 1. Introduction .....  | 13 |
| 1.1 Scope and Objectives.....  | 14 |
| 1.2 Structure.....   | 14 |
| 2. Regional Planning Process .....   | 15 |
| 2.1 Overview .....   | 15 |
| 2.2 Regional Planning Process .....  | 15 |
| 2.3 RIP Methodology .....  | 18 |
| 3. Regional Characteristics.....   | 19 |
| 3.1 Central Toronto Sub-Region.....  | 19 |
| 3.2 Metro Toronto Northern Sub-Region .....  | 20 |
| 4. Transmission Facilities Completed and/or Underway over the Last Ten Years ..... | 23 |
| 5. Forecast and Other Study Assumptions .....                                      | 24 |
| 5.1 Load Forecast .....  | 24 |
| 5.2 Other Study Assumptions.....   | 26 |
| 6. Adequacy of Existing Facilities.....  | 27 |
| 6.1 Metro Toronto Northern Sub-Region .....  | 29 |
| 6.1.1 230kV Transmission Facilities .....  | 29 |
| 6.1.2 Step-Down Transformer Station Facilities .....                               | 29 |
| 6.2 Central Toronto Sub-Region.....  | 30 |
| 6.2.1 230kV Transmission Facilities .....  | 30 |
| 6.2.2 115kV Transmission Facilities .....  | 30 |
| 6.2.3 Step-Down Transformer Facilities.....  | 31 |
| 7. Regional Needs and Plans .....  | 33 |
| 7.1 West Toronto Area .....  | 33 |
| 7.1.1 Station Capacity - Runnymede TS & Fairbank TS.....                           | 33 |
| 7.1.2 Line Capacity - Manby TS x Wiltshire TS 115kV circuits.....                  | 33 |
| 7.1.3 Recommended Plan and Current Status.....                                     | 34 |
| 7.2 Southwest Toronto Area.....  | 35 |
| 7.2.1 Station Capacity – Southwest Toronto (Manby TS & Horner TS).....             | 35 |
| 7.2.2 Recommended Plan and Current Status.....                                     | 35 |
| 7.3 Downtown District .....  | 36 |
| 7.3.1 Station Capacity – JETC Area .....   | 36 |
| 7.3.2 Recommended Plan and Current Status.....                                     | 37 |
| 7.4 Transmission Line Capacity – 230 kV Richview TS to Manby TS Corridor.....      | 38 |
| 7.4.1 Description.....   | 38 |
| 7.4.2 Alternatives Considered.....   | 39 |
| 7.4.3 Recommended Plan and Current Status.....                                     | 40 |

7.5 Transmission Line Capacity – Circuit C10A (Duffin Jct. to Agincourt Jct) ..... 40

7.6 Breaker Failure at Manby TS ..... 41

    7.6.1 Description..... 41

    7.6.2 Recommended Plan and Current Status..... 41

7.7 Breaker Failure at Leaside TS ..... 41

7.8 Cherrywood to Leaside (CxL) Double Circuit Contingencies ..... 42

7.9 Load Restoration – Northern Sub-Region (Bathurst TS, Fairchild TS, Leslie TS)..... 42

7.10 Long Term Needs ..... 43

- Transmission Line Capacity – 115 kV Manby West To Riverside Junction..... 43
- Transformation Capacity – 230/115 kV Manby TS..... 43
- Transformation Capacity – 230/115 kV Leaside TS ..... 43
- Leaside TS x Wiltshire TS 115kV circuits ..... 43

8. Conclusions and Next Steps ..... 44

9. References ..... 46

Appendix A. Stations in the Metro Toronto Region..... 47

Appendix B. Transmission Lines in the Metro Toronto Region..... 50

Appendix C. Distributors in the Metro Toronto Region..... 51

Appendix D. Metro Toronto Regional Load Forecast (2015-2035) ..... 53

Appendix E. List of Acronyms ..... 55

## LIST OF FIGURES

|  |    |
|--|----|
| Figure 1-1 Map of Metro Toronto Region .....   | 13 |
| Figure 2-1 Regional Planning Process Flowchart.....  | 17 |
| Figure 2-2 RIP Methodology .....   | 18 |
| Figure 3-1 Metro Toronto Region – Supply Areas .....   | 21 |
| Figure 3-2 Metro Toronto Region – Single Line Diagram .....                                      | 22 |
| Figure 5-1 Metro Toronto Region Summer Extreme Weather Peak Forecast.....                        | 24 |
| Figure 5-2 Effect of Metrolinx Electrification on the Metro Toronto Region Summer Peak Load..... | 25 |
| Figure 7-1 West Toronto Area - Fairbank TS and Runnymede TS .....                                | 34 |
| Figure 7-2 Horner TS and Manby TS Supply Area .....  | 35 |
| Figure 7-3 Toronto Downtown Supply Area .....  | 36 |
| Figure 7-4 Richview x Manby Supply Area Map .....  | 38 |

## LIST OF TABLES

|  |    |
|--|----|
| Table 6-1 Needs identified in Previous Stages of the Regional Planning Process .....       | 28 |
| Table 6-2 Adequacy of 230kV Transmission Facilities.....                                   | 30 |
| Table 6-3 Overloaded Sections of 115kV circuits .....                                      | 31 |
| Table 6-4 Adequacy of Step-Down Transformer Stations - Areas Requiring Relief .....        | 32 |
| Table 7-1 Manby x Wiltshire Corridor Capability.....                                       | 33 |
| Table 7-2 Coincident RIP MW Load Forecast for Richview TS x Manby TS Area .....            | 39 |
| Table 7-3 Maximum Load Loss during Two Circuit Contingencies .....                         | 42 |
| Table 8-1 Regional Plans – Needs Identified in the Regional Planning Process.....          | 44 |
| Table 8-2 Regional Plans – Next Steps, Lead Responsibility and Plan In-Service Dates ..... | 44 |

[This page is intentionally left blank]

# 1. INTRODUCTION

THIS REPORT PRESENTS THE REGIONAL INFRASTRUCTURE PLAN (“RIP”) TO ADDRESS THE ELECTRICITY NEEDS OF THE METRO TORONTO REGION.

The report was prepared by Hydro One Networks Inc. (“Hydro One”) on behalf of the Working Group that consists of Hydro One, Enersource Hydro Mississauga, Hydro One Networks Inc. Distribution, the Independent Electricity System Operator (“IESO”), PowerStream Inc., Toronto Hydro-Electric System (“THESL”), and Veridian Connections Inc. in accordance with the new Regional Planning process established by the Ontario Energy Board in 2013.

The Metro Toronto Region is comprised of the City of Toronto. Electrical supply to the Region is provided by thirty five 230kV and 115kV transmission and step-down stations as shown in Figure 1-1. The eastern, northern and western parts of the Region are supplied by eighteen 230/27.6kV step-down transformer stations. The central area is supplied by two 230/115kV autotransformer stations (Leaside TS and Manby TS) and fifteen 115/13.8kV and two 115/27.6kV step-down transformer stations. The summer 2015 area load of the Metro Toronto region was about 4700MW.




Figure 1-1 Map of Metro Toronto Region

## 1.1 Scope and Objectives

This RIP report examines the needs in the Metro Toronto Region. Its objectives are to:

- Identify new supply needs that may have emerged since previous planning phases (e.g., Needs Assessment, Scoping Assessment, Local Plan, and/or Integrated Regional Resource Plan);
- Assess and develop a wires plan to address these needs;
- Provide the status of wires planning currently underway or completed for specific needs;
- Identify investments in transmission and distribution facilities or both that should be developed and implemented on a coordinated basis to meet the electricity infrastructure needs within the region.

The RIP reviews factors such as the load forecast, transmission and distribution system capability along with any updates with respect to local plans, conservation and demand management (“CDM”), renewable and non-renewable generation development, and other electricity system and local drivers that may impact the need and alternatives under consideration.

The scope of this RIP is as follows:

- A consolidated report of the needs and relevant wires plans to address near and medium-term needs (2015-2025) identified in previous planning phases (Needs Assessment, Local Plan or Integrated Regional Resource Plan);
- Identification of any new needs over the 2015-2025 period and a wires plan to address these needs based on new and/or updated information;
- Develop a plan to address any longer term needs identified by the Working Group.

## 1.2 Structure

The rest of the report is organized as follows:

- Section 2 provides an overview of the regional planning process;
- Section 3 describes the region;
- Section 4 describes the transmission work completed over the last ten years;
- Section 5 describes the load forecast used in this assessment;
- Section 6 describes the results of the adequacy assessment of the transmission facilities and identifies the needs;
- Section 7 discusses the needs and provides the alternatives and preferred solutions;
- Section 8 provides the conclusion and next steps.

## 2. REGIONAL PLANNING PROCESS

### 2.1 Overview

Planning for the electricity system in Ontario is done at essentially three levels: bulk system planning, regional system planning, and distribution system planning. These levels differ in the facilities that are considered and the scope of impact on the electricity system. Planning at the bulk system level typically looks at issues that impact the system on a provincial level, while planning at the regional and distribution levels looks at issues on a more regional or localized level.

Regional planning looks at supply and reliability issues at a regional or local area level. Therefore, it largely considers the 115 kV and 230 kV portions of the power system that supply various parts of the province.

### 2.2 Regional Planning Process

A structured regional planning process was established by the Ontario Energy Board in 2013 through amendments to the Transmission System Code (“TSC”) and Distribution System Code (“DSC”). The process consists of four phases: the Needs Assessment<sup>1</sup> (“NA”), the Scoping Assessment (“SA”), the Integrated Regional Resource Plan (“IRRP”), and the Regional Infrastructure Plan (“RIP”).

The regional planning process begins with the NA phase which is led by the transmitter to determine if there are regional needs. The NA phase identifies the needs and the Working Group determines whether further regional coordination is necessary to address them. If no further regional coordination is required, further planning is undertaken by the transmitter and the impacted local distribution company (“LDC”) or customer and develops a Local Plan (“LP”) to address them. These needs are local in nature and can be best addressed by a straight forward wires solution.

In situations where identified needs require coordination at the regional or sub-regional levels, the IESO initiates the SA phase. During this phase, the IESO, in collaboration with the transmitter and impacted LDCs, reviews the information collected as part of the NA phase, along with additional information on potential non-wires alternatives, and makes a decision on the most appropriate regional planning approach. The approach is either a RIP, which is led by the transmitter, or an IRRP, which is led by the IESO. If more than one sub-region was identified in the NA phase, it is possible that a different approach could be taken for different sub-regions.

The IRRP phase will generally assess infrastructure (wires) versus resource (CDM and Distributed Generation) options at a higher or more macro level, but sufficient to permit a comparison of options. If the IRRP phase identifies that infrastructure options may be most appropriate to meet a need, the RIP phase will conduct detailed planning to identify and assess the specific wires alternatives and recommend

---

<sup>1</sup> Also referred to as Needs Screening.

a preferred wires solution. Similarly, resource options which the IRRP identifies as best suited to meet a need are then further planned in greater detail by the IESO. The IRRP phase also includes IESO led stakeholder engagement with municipalities and establishes a Local Advisory Committee (LAC) in the region or sub-region. For the Metro Toronto Region, community engagement through a formal LAC is on-going.

The RIP phase is the final stage of the regional planning process and involves: confirmation of previously identified needs; identification of any new needs that may have emerged since the start of the planning cycle; and development of a wires plan to address the needs where a wires solution would be the best overall approach. This phase is led and coordinated by the transmitter and the deliverable of this stage is a comprehensive report of a wires plan for the region. Once completed, this report can be referenced in rate filing submissions or as part of LDC rate applications with a planning status letter provided by the transmitter. Reflecting the timelines provisions of the RIP, plan level stakeholder engagement is not undertaken at this stage. However, stakeholder engagement at a project specific level will be conducted as part of the project approval requirement.

To efficiently manage the regional planning process, Hydro One has been undertaking wires planning activities in collaboration with the IESO and LDCs for the region as part of and/or in parallel with:

- Planning activities that were already underway in the region prior to the new regional planning process taking effect;
- The NA, SA, and LP phases of regional planning;
- Participating in and conducting wires planning as part of the IRRP for the region or sub-region.

Figure 2-1 illustrates the various phases of the regional planning process (NA, SA, IRRP, and RIP) and their respective phase trigger, lead, and outcome.







Figure 2-1 Regional Planning Process Flowchart

### 2.3 RIP Methodology

The RIP phase consists of four steps (see Figure 2-2) as follows:

- 1) **Data Gathering:** The first step of the RIP process is the review of planning assessment data collected in the previous stages of the regional planning process. Hydro One collects this information and reviews it with the Working Group to reconfirm or update the information as required. The data collected includes:
  - Net peak demand forecast at the transformer station level. This includes the effect of any distributed generation or conservation and demand management programs.
  - Existing area network and capabilities including any bulk system power flow assumptions.
  - Other data and assumptions as applicable such as asset conditions; load transfer capabilities, and previously committed transmission and distribution system plans.
- 2) **Technical Assessment:** The second step is a technical assessment to review the adequacy of the regional system including any previously identified needs. Additional near and mid-term needs may be identified at this stage.
- 3) **Alternative Development:** The third step is the development of wires options to address the needs and to come up with a preferred alternative based on an assessment of technical considerations, feasibility, environmental impact and costs.
- 4) **Implementation Plan:** The fourth and last step is the development of the implementation plan for the preferred alternative.



**Figure 2-2 RIP Methodology**

### 3. REGIONAL CHARACTERISTICS

THE METRO TORONTO REGION INCLUDES THE AREA ROUGHLY BORDERED GEOGRAPHICALLY BY LAKE ONTARIO ON THE SOUTH, STEELES AVENUE ON THE NORTH, HIGHWAY 427 ON THE WEST AND REGIONAL ROAD 30 ON THE EAST. IT CONSISTS OF THE CITY OF TORONTO, WHICH IS THE LARGEST CITY IN CANADA AND THE FOURTH LARGEST IN NORTH AMERICA.

Bulk electrical supply to the Metro Toronto Region is provided through three 500/230 kV transformers stations - Claireville TS, Cherrywood TS and Parkway TS and a network of 230 kV and 115 kV transmission lines and step-down transformation facilities. Local generation in the area consists of the 550 MW Portlands Energy Centre located near downtown area and connected to the 115 kV network at Hearn Switching Station. The Metro Toronto Region 2015 peak summer demand was about 4700MW which represents about 20% of the gross electrical demand in the province.

Toronto Hydro-Electric System Limited (“THESL”) is the Local Distribution Company (“LDC”) that serves the electricity demands for the city of Toronto. Other LDCs supplied from electrical facilities in the Metro Toronto Region are Hydro One Networks Inc. Distribution, PowerStream Inc., Veridian Connections Inc., and Enersource Hydro Mississauga. The LDCs receive power at the step down transformer stations and distribute it to the end users – industrial, commercial and residential customers.

The April 2015 Integrated Regional Integrated Regional Resource Plan (“IRRP”) report, prepared by the IESO in conjunction with Hydro One and the LDC, focused on the Central Toronto Area which included the 115kV network and the 230kV facilities in the western part of Region. The June 2014 Metro Toronto Northern Sub-Region Needs Assessment report, prepared by Hydro One, considered the remainder of the Metro Toronto region. A map and a single line diagram showing the electrical facilities of the Metro Toronto Region, consisting of the two sub-regions, is shown in Figure 3-1 and Figure 3-2 respectively. Please note that the facilities shown include the new Leaside TS to Bridgman TS 115kV circuit L18W and the new Copeland MTS. The L18W circuit is being built as part of the Midtown Transmission Reinforcement Project and Copeland MTS is a new THESL owned transformer station to serve the downtown area. Work on these projects is in the advanced stage and both are expected to come into service in 2016.

#### 3.1 Central Toronto Sub-Region

The Central Toronto Sub-Region includes the area extending northward from Lake Ontario to roughly Highway 401, westward to Highway 427 and Etobicoke Creek, and eastward to Victoria Park Avenue.

The Central Toronto Sub-Region was identified as a “transitional” region, as planning activities in the region were already underway before the new regional planning process was introduced. The NA and SA phases were deemed to be complete, and the regional planning process was considered to be in the IRRP phase. An IRRP for the region was completed in April 2015.

The Central Toronto Sub-region is further subdivided into two areas:

- The Richview Manby 230kV area: This includes the former borough of Etobicoke and is served by the Richview TS to Manby TS 230kV circuits. The area has two 230/27.6kV step-down transformer stations. The coincident peak summer 2015 area load was about 320 MW. The Richview TS to Manby 230kV circuits together with the Richview TS to Cooksville TS circuit R24C supply a number of stations in the GTA West Southern Sub-Region. These stations while outside the Metro Toronto Region have therefore been included in Figure 3-2.
- The Central 115kV Area: The central area is supplied by two 230/115kV autotransformer stations (Leaside TS and Manby TS), fifteen 115/13.8kV and two 115/27.6kV step-down transformer stations. The area includes the downtown core including the financial, entertainment and educational districts. The 2015 summer coincident area load was about 1900MW.

Please see Figure 3-1 and 3-2 for a map and single line diagram of the Sub-Region facilities.

### **3.2 Metro Toronto Northern Sub-Region**

The Metro Toronto Northern Sub-Region comprises the remainder of the Metro Toronto region. It includes the area roughly bordered geographically by Highway 401 on the south, Steeles Avenue on the north, Highway 427 on the west and Regional Road 30 on the east in addition to the area east of the Don Valley Parkway and north of O'Connor Dr.

Electrical supply to the Metro Toronto Northern Sub-Region is provided through 230 kV transmission lines and step-down transformation facilities. Supply to this sub-region is provided from a 230 kV transmission system consisting of the Richview TS to Parkway TS, the Richview TS to Cherrywood TS, the Richview TS to Claireville TS, as well as the Cherrywood TS to Leaside TS 230kV transmission system. The area is served primarily at 27.6kV by fifteen step-down transformer stations with a pocket of 13.8kV load supplied from Leaside TS and Leslie TS. The 2015 summer coincident area load was about 2500 MW.

Please see Figure 3-1 and 3-2 for a map and single line diagram of the Sub-Region facilities.




Figure 3-1 Metro Toronto Region – Supply Areas




Figure 3-2 Metro Toronto Region – Single Line Diagram

## 4. TRANSMISSION FACILITIES COMPLETED AND/OR UNDERWAY OVER THE LAST TEN YEARS

OVER THE LAST 10 YEARS A NUMBER OF TRANSMISSION PROJECTS HAVE BEEN PLANNED AND COMPLETED BY HYDRO ONE, OR ARE UNDERWAY, AIMED AT IMPROVING THE SUPPLY TO THE METRO TORONTO REGION IN GENERAL AND THE TORONTO 115 KV NETWORK IN PARTICULAR.

These projects together with the new 550 MW Portlands Energy Centre that went into service in 2009 have ensured that the City continues to receive adequate and reliable supply. A brief listing of these projects is given below:

- Parkway 500/230 kV TS (2005) – built to provide adequate 500/230 kV transformation capacity following the retirement of Lakeview GS. The station while just outside the Metro Toronto Region is a key contributor in ensuring supply adequacy to the Region.
- John TS to Esplanade TS underground cable circuits (2008) – built to provide transfer capability between the Leaside TS and the Manby TS 115 kV areas.
- Incorporation of the 550 MW Portlands Energy Centre (2009) – covered modification to the Hearn 115kV switchyard to connect the new generation.
- 115 kV Switchyard Work at Hearn SS, Leaside TS & Manby TS (2013 & 2014) – covered replacement of the aging 115 kV switchyard at Hearn SS with a new GIS switchyard and replacement of all 115 kV breakers at Leaside TS and Manby TS.
- Manby 230 kV Reconfiguration (2014) – re-tapped Horner TS from the circuit R15K to R13K at Manby TS to balance / improve the distribution of loading on the 230 kV Richview TS to Manby TS system.
- Lakeshore Cable Refurbishment project (2015) – covered replacement of the aging K6J/H2JK 115 kV circuits between Riverside Jct. and Strachan TS.
- Midtown Transmission Reinforcement Project (expected completion by 2016) – covered replacement of the aging L14W underground cable and building an additional fourth 115 kV circuit between Leaside TS and Bridgman TS.
- Clare R. Copeland 115kV switching station (expected completion by 2016) – built to connect a new THESL owned 115/13.8 kV step-down transformer station in the downtown district.

## 5. FORECAST AND OTHER STUDY ASSUMPTIONS

### 5.1 Load Forecast

The load in the Metro Toronto Region is forecast to increase at an average rate of approximately 0.9% annually up to 2020, at 0.67% between 2020 and 2025 and at 0.61% beyond 2025. The growth rate varies across the region – from about 0.35% in the Northern Sub-Region to 1.07% in the City’s downtown area over the 20 years.

Figure 5-1 shows the Metro Toronto Region’s planning load forecast (summer net, non-coincident and regional-coincident extreme weather peak) under the IRRP high growth scenario. The regional-coincident (at the same time) forecast represents the total peak load of the 35 step-down transformer stations in the Metro Toronto. The coincident regional peak load is forecast to increase from 5176 MW in 2015 to 6196 MW by 2035.




Figure 5-1 Metro Toronto Region Summer Extreme Weather Peak Forecast

The coincident and non-coincident extreme weather peak load forecast for the individual stations in the Metro Toronto Region is given in Appendix D. The coincident forecast represents the sum of the area stations peak load at the time of Metro Toronto Region peak demand and represents loads that would be seen by transmission lines and autotransformer stations and is used to determine the need for additional line and auto-transformation capacity. The non-coincident forecast represents the sum of the individual stations peak load and is used to determine the need for station capacity.




The individual station forecasts were developed by projecting 2015 summer peak loads, corrected for extreme weather, using the area stations growth rates as per the 2015 IESO’s IRRP study (High Demand Scenario) for the Central Toronto Sub-Region [1] and as per the 2014 Hydro One’s Need Assessment study [2] for the Metro Toronto Northern Sub-Region. The growth rates from [1] only account for existing Distributed Generation (“DG”), and do not include any new CDM and DG. The growth rates from [2] are the net growth rates seen by station equipment and account for CDM measures and connected DG. Details on the CDM and connected DG are provided in [1] and [2] and are not repeated here.

**Impact of Metrolinx Go Transit Electrification**

In June 2015, Metrolinx advised Hydro One that they are planning to proceed with the electrification of the Go transit rail system. This information was provided after the IRRP was completed in April 2015. Under their plan three Traction Power Stations (TPS) are proposed to be built in the Metro Toronto Region. These stations are as follows:

- Mimico TPS – For the Lakeshore West Go Transit Line (2020)
- Cityview TPS – For the Pearson Airport and Kitchener Go Transit lines (2020)
- Warden TPS – For the Lakeshore East Go Transit Line (2020)



**Figure 5-2 Effect of Metrolinx Electrification on the Metro Toronto Region Summer Peak Load**

The impact of the Metrolinx load on the regional forecast is shown in Figure 5-2. Each of the three Metro area stations is expected to have an initial load of 40MW increasing to 80MW in 4 years. The net result is to increase the Region peak load by 240MW.

## 5.2 Other Study Assumptions

The following other assumptions are made in this report.

- The study period for the RIP Assessments is 2015-2035.
- All planned facilities for which work has been initiated and are listed in Section 4 are assumed to be in-service.
- Summer is the critical period with respect to line and transformer loadings. The assessment is therefore based on summer peak loads.
- Station capacity adequacy is assessed by comparing the non-coincident peak load with the station's normal planning supply capacity, assuming a 90% lagging power factor for stations having no low-voltage capacitor banks and 95% lagging power factor for stations having low voltage capacitor banks. Normal planning supply capacity for transformer stations in this Sub-Region is determined by the summer 10-Day Limited Time Rating (LTR).
- For THESL 13.8kV stations, an additional 95% factor is applied to the normal planning supply capacity in this study. This is to reflect the fact that all the capacity cannot be effectively utilized due to the large relative size of the individual customer loads.

## 6. ADEQUACY OF EXISTING FACILITIES

THIS SECTION REVIEWS THE ADEQUACY OF THE EXISTING TRANSMISSION AND DELIVERY STATION FACILITIES SUPPLYING THE METRO TORONTO REGION OVER THE 2015-2035 PERIOD. IT ASSUMES THAT ALL PROJECTS CURRENTLY UNDER WAY ARE IN SERVICE.

Within the current regional planning cycle two regional assessments have been conducted for the Metro Toronto Region. The findings of these studies are input to the RIP. The studies are:

- 1) IESO's Central Toronto Integrated Regional Resource Plan – dated April 28, 2015<sup>[1]</sup>
- 2) Hydro One's Needs Assessment Report – Metro Toronto – Northern Sub-Region – June 11, 2014<sup>[2]</sup>

The IRRP and NA planning assessments identified a number of regional needs to meet the area forecast load demands. These regional needs are summarized in Table 6-1 and include needs for which work is already underway and/or being addressed by a LP study. A detailed description and status of work initiated or planned to meet these needs is given in Section 7.

A review of the loading on the transmission lines and stations in the Metro Toronto Region was also carried out as part of the RIP report using the latest Regional Forecast based on the IRRP high load growth scenario and as given in Section 5. The impact of Metrolinx Electrification on the regional infrastructure has been included.

For cases where a need was identified in the near or mid-term by the high growth scenario, a sensitivity analysis was done using the IRRP low growth scenario to get a range on the need date. Sections 6.1 to 6.2 present the results of this review. Additional needs identified as a result of the review are also listed in Table 6-1.

**Table 6-1 Needs identified in Previous Stages of the Regional Planning Process**

| Type   | Section | Needs   | Timing               |
|--|---------|---|----------------------|
| Station Capacity                             | 7.1     | West Toronto (Runnymede TS & Fairbank TS)                                       | Today                |
|  | 7.2     | Southwest Toronto (Manby TS & Horner TS)  | 2020-2027            |
|  | 7.3     | Downtown District (JETC <sup>(1)</sup> Area)                                    | 2020+ <sup>(2)</sup> |
| Transmission Line Capacity                   | 7.4     | 230 kV Richview TS to Manby TS Corridor   | 2020-2023            |
|  | 7.5     | Circuit C10A (Duffin Jct. to Agincourt Jct.)                                    | Completed            |
| Supply Security, Reliability and Restoration | 7.6     | Breaker failure contingencies at Manby W and Manby E TS                         | 2018/2021            |
|  | 7.7     | Breaker failure contingency at Leaside TS                                       | Today                |
|  | 7.8     | Double circuit contingencies C2L/C3L or C16L/C17L (Cherrywood TS to Leaside TS) | 2021                 |
|  | 7.9     | Load Restoration – Northern Sub-Region (Bathurst TS, Fairchild TS, Leslie TS)   | Today                |
| Long-Term                                    | 7.10    | 115 kV Manby West To Riverside Jct. Lines                                       | 2035+                |
|  |         | 230/115 kV Manby TS transformer capacity  | 2035+                |
|  |         | 230/115 kV Leaside TS transformer capacity                                      | 2026+                |
| Additional Long-Term Need Identified in RIP  | 7.10    | Leaside TS x Wiltshire TS circuits  | 2034                 |

<sup>(1)</sup> JETC denotes John TS, Esplanade TS, Terauley TS, and Copeland MTS which jointly supply the Downtown District.

<sup>(2)</sup> The need date will be around 2027 based on the station capacity consideration alone for the Downtown District stations. However, a need date of 2020+ was established by the WG based upon other considerations, such as requirements for spare feeder position. More details are given in Section 7.3.

## 6.1 Metro Toronto Northern Sub-Region

### 6.1.1 230kV Transmission Facilities

The Northern 230kV facilities consist of the following 230kV transmission circuits (Please refer to Figure 3-2):

- a) Claireville TS to Richview TS 230kV circuits: V72R, V73R, V74R, V76R, V77R and V79R.
- b) Cherrywood TS to Richview TS 230kV circuits: C4R, C5R, C18R and C20R.
- c) Parkway TS to Richview 230kV circuits: P21R and P22R
- d) Cherrywood TS to Agincourt TS 230kV circuit C10A.
- e) Cherrywood TS to Leaside TS 230kV circuits: C2L, C3L C14L, C15L, C16L and C17L.

The Claireville TS to Richview TS circuits, the Cherrywood TS to Richview TS circuits and the Parkway TS circuits to Richview TS circuits carry bulk transmission flows as well as serve local area station loads within the Sub-Region. These circuits are adequate over the study period.

The Cherrywood TS to Agincourt TS circuit C10A is a radial circuit that supplies Agincourt TS and Cavanagh TS. The Need Assessment for the Metro Toronto Northern Sub-Region had identified that line capacity was restricted due to inadequate clearance from underbuilt street lighting and distribution line. Field surveys carried out by Hydro One have confirmed that the limiting underbuilds have been removed. The circuit is adequate over the study period.

The Cherrywood TS to Leaside TS 230kV circuits supply the Leaside TS 230/115kV autotransformers as well as serve local area load. Loading on these circuits is adequate over the study period.

### 6.1.2 Step-Down Transformer Station Facilities

The Sub-Region has the following step down transformer stations:

|               |             |
|---------------|-------------|
| Agincourt TS  | Leaside TS  |
| Bathurst TS   | Leslie TS   |
| Bermondsey TS | Malvern TS  |
| Cavanagh MTS  | Rexdale TS  |
| Ellesmere TS  | Scarboro TS |
| Fairchild TS  | Sheppard TS |
| Finch TS      | Warden TS   |

The Metro Toronto Northern Sub-Region Needs Assessment Report had identified that the gross load was approaching station capacity at Cavanagh MTS and the Leslie TS (T1/T2, 27.6kV windings) and the Sheppard TS (T3/T4) DESN units. No action was recommended as the net load after considering the CDM and DG program is within ratings. The RIP report has reviewed the station loading and confirms that station capacity is adequate over the study period. However, the station loads will be monitored to ensure facility ratings are not exceeded.

## 6.2 Central Toronto Sub-Region

### 6.2.1 230kV Transmission Facilities

The 230kV transmission facilities in the Central Toronto Sub-Region are as follows (Please refer to Figure 3-2):

- a) Richview TS x Manby TS 230kV circuits: R1K, R2K, R13K and R15K
- b) Cooksville TS x Manby TS 230kV circuits: K21C/K23C
- c) Manby TS 230/115kV autotransformers
- d) Leaside TS 230kV/115kV autotransformers

The Richview TS to Manby TS circuits and the Cooksville TS to Manby TS circuits supply the Manby 230/115kV autotransformer station as well as Horner TS. Please note that the K21C and K23C circuits connect back to Richview TS through Cooksville TS and 230kV circuit R24C.

Table 6-2 summarizes the result of adequacy studies and gives the need date for transmission reinforcement for each of the above facilities.

**Table 6-2 Adequacy of 230kV Transmission Facilities**

| Facilities  | 2015 MW Load <sup>(1)</sup> | MW Load Meeting Capability (LMC) | Limiting Contingency | Need Date                |
|---|-----------------------------|----------------------------------|----------------------|--------------------------|
| Richview x Manby 230kV Corridor                       | 1456                        | 1540                             | R2K                  | 2020-2023 <sup>(2)</sup> |
| Manby E. 230/115kV autos                              | 330                         | 560                              | T2                   | 2035+                    |
| Manby W. 230/115kV autos                              | 397                         | 612                              | T9                   | 2035+                    |
| Leaside 230/115kV autos + Portlands GS <sup>(1)</sup> | 1340                        | 1525-1915 <sup>(3)</sup>         | None                 | 2026+ <sup>(4)</sup>     |

- (1) The loads shown have been adjusted for extreme weather.
- (2) The 2020 and 2023 need dates correspond to the high growth and low growth rate scenarios without considering Metrolinx Mimico TPS. Assuming Metrolinx Mimico TPS comes into service in 2020, the need date will become 2020 under both scenarios.
- (3) The Leaside 115kV area is supplied by the Leaside TS 230/115kV autotransformers and the 550MW Portlands GS. Load Meeting capability is dependent on the generation from Portlands GS which backs up the flow through the Leaside autotransformers. The 1525MW LMC assumes only 160MW generation at Portland GS while the 1915MW LMC assumes the full 550MW generation at Portland GS.
- (4) The need date is based on the 1525MW LMC which assumes that two of the three units are out at Portlands GS and total plant generation is 160MW.

### 6.2.2 115kV Transmission Facilities

The 115kV facilities in the Metro Toronto Region (see Figure 3-2) can be divided into five main corridors:

1. Manby TS East x Wiltshire TS – Four circuits K1W, K3W, K11, K12W. Forecast loading can exceed corridor rating under certain conditions. More details are provided in Section 7.1.2.
2. Manby TS West x John TS – Four circuits H2JK, K6J, K13J and K14J. These circuits are adequate over the study period.
3. Leaside TS x Hearn TS – Six circuits H6LC, H8LC, H1L, H3L, H7L and H11L. These circuits are expected to be adequate over the study period. .
4. Leaside TS x Cecil TS – Three circuits L4C, L9C, and L12C. These are expected to be adequate over the study period.
5. Leaside TS x Wiltshire TS – Four circuits L13W/L14W/L15/L18W. The L18W circuit is expected to go into service in summer 2016. Loading will exceed corridor rating by 2034 for loss of the L18W circuit. More details are provided in Section 7.10.4.

The loading on the limiting sections is summarized in Table 6-3.

**Table 6-3 Overloaded Sections of 115kV circuits**

| <b>Facilities</b>                         | <b>2015 MW Load</b> | <b>MW Load Meeting Capability</b> | <b>Limiting Contingency</b> | <b>Need Date</b>         |
|---|---------------------|-----------------------------------|-----------------------------|--------------------------|
| Manby TS x Wiltshire TS<br>115kV Corridor | 330                 | 348/410 <sup>(1)</sup>            | K11W                        | 2019-2023 <sup>(1)</sup> |
| Leaside TS x Wiltshire TS                 | 310                 | 350                               | L18W                        | 2034                     |

- (1) The Manby x Wiltshire corridor provides emergency backup for Dufferin TS load under Leaside area contingencies. Assuming that a 100MW of back up capability is provided, the maximum load that can be supplied in the Fairbanks/Runnymede area is 348MW and the need date for upgrading the corridor is 2019. If 75MW of back up capability is required, the need date will become 2023. However, if back up capability during peak is not considered, maximum load meeting capability is 410MW. The need in this case would be beyond 2035.

### 6.2.3 Step-Down Transformer Facilities

There are a total of 20 step-down transformers stations in the Central Toronto Sub Region.as follows:

|             |              |              |
|-------------|--------------|--------------|
| Basin TS    | Esplanade TS | Fairbank TS  |
| Bridgman TS | Gerrard TS   | Copeland MTS |
| Carlaw TS   | Glengrove TS | John TS      |
| Cecil TS    | Main TS      | Strachan TS  |
| Charles TS  | Terauley TS  | Horner TS    |
| Dufferin TS | Wiltshire TS | Manby TS     |
| Duplex TS   | Runnymede TS |              |

The stations non-coincident loads are given in Appendix D Table D-1. The areas and the stations requiring relief are given in Table 6-4.

**Table 6-4 Adequacy of Step-Down Transformer Stations - Areas Requiring Relief**

| <b>Area/Supply</b>  | <b>Capacity (MW)</b> | <b>2015 Loading (MW)</b> | <b>Need Date</b>         |
|---|----------------------|--------------------------|--------------------------|
| West Toronto:<br>Fairbanks TS and Runnymede TS                                  | 285                  | 291                      | Now                      |
| Southwest Toronto :<br>Manby TS and Horner TS area                              | 400                  | 376                      | 2020-2027 <sup>(1)</sup> |
| Downtown Toronto:<br>John TS, Esplanade TS, Terauley TS and Copeland MTS (JETC) | 739                  | 632                      | 2020+ <sup>(2)</sup>     |

- (1) The need dates are based on high and low demand growth rates scenario
- (2) The need date will be around 2027 based on the station capacity consideration alone for the Downtown District stations. However, a need date of 2020+ was established by the WG based upon other considerations, such as requirements for spare feeder position. More details are given in Section 7.3.



## 7. REGIONAL NEEDS AND PLANS

THIS SECTION DISCUSSES THE ELECTRICAL SUPPLY NEEDS FOR THE METRO TORONTO REGION AND SUMMARIZES THE REGIONAL PLANS FOR ADDRESSING THE NEEDS. THESE NEEDS ARE LISTED IN TABLE 6-1 AND INCLUDE NEEDS PREVIOUSLY IDENTIFIED IN THE IRRP FOR THE CENTRAL TORONTO SUB-REGION <sup>[1]</sup> AND THE NA FOR THE METRO TORONTO NORTHERN SUB-REGION <sup>[2]</sup> AS WELL AS THE ADEQUACY ASSESSMENT CARRIED OUT AS PART OF THE CURRENT RIP REPORT.

### 7.1 West Toronto Area

#### 7.1.1 Station Capacity - Runnymede TS & Fairbank TS

Runnymede TS and Fairbank TS are 115/27.6 kV transformer stations that supply the load demand in the west end of Toronto. The two stations are connected to the 115 kV Manby East transmission system and have been operating at or near their capacity limits for the last five years. THESL has managed growth by transferring loads to adjacent area stations.

The area 2015 extreme weather peak load was 291 MW and exceeded the stations capacity of 285MW. The area is experiencing some re-development and the proposed Eglinton Crosstown Light Railway Transit (“LRT”) project by MetroLinx will add an additional 14 MW of load to Runnymede TS in 2021. Additional step down transformation capacity is required now to provide relief and be able to meet the forecast load demand.

#### 7.1.2 Line Capacity - Manby TS x Wiltshire TS 115kV circuits

The Manby TS x Wiltshire TS four circuit 115kV tower line carries circuits K1W, K3W, K11W and K12W. These circuits supply Fairbanks TS, Runnymede TS and well as Wiltshire TS. Under Lease area outage conditions, these circuits are also used to pick up all or parts of Dufferin TS and/or Bridgman TS loads. The total corridor capability is dependent on the Fairbanks TS and Runnymede TS load and the load picked up and is given in table below:

**Table 7-1 Manby x Wiltshire Corridor Capability**

| Year | Fairbanks TS, Runnymede TS, and Wiltshire TS Load Forecast (MW) | Amount of Dufferin TS and Bridgman TS Load that can be picked up (MW) | Total Corridor Capability (MW) |
|------|---|---|--------------------------------|
| 2015 | 330   | 120   | 450                            |
| 2019 | 349   | 97  | 446                            |
| 2023 | 375   | 68  | 443                            |
| 2027 | 390   | 46  | 436                            |
| 2031 | 399   | 25  | 424                            |
| 2035 | 406   | 10  | 416                            |

The timing of the Manby TS x Wiltshire TS circuits upgrade is dependent on the backup capability desired. If backup capability is not considered, the upgrade can be deferred to beyond 2035. However, if at least 70MW of back up capability - equal to about half of Dufferin TS load - is deemed appropriate, the upgrade would be deferred to about 2023.



Figure 7-1 West Toronto Area - Fairbank TS and Runnymede TS

### 7.1.3 Recommended Plan and Current Status

The Working Group has considered and reviewed several options to provide additional transformation capacity in West Toronto area as part of the Central Toronto IRRP. Based upon the review, and consistent with the IRRP Working Group recommendation is to expand Runnymede TS by adding two 115/27.6 kV 50/83 MVA transformers and a 27.6kV switchyard with six feeders. This work is required to be completed as early as possible.

The Working Group also recommends that the Manby TS to Wiltshire TS tower line carrying circuits K1W/K3W/K11W/K12W be also upgraded at the same time. This option would maintain the load transfer capability between Leaside TS and the Manby TS under emergency or outage conditions in addition to supplying future load growth in the West Toronto Area.

The estimated total cost of the work is approximately \$90 M, which includes \$34 M for the station work at Runnymede TS, \$16 M for the upgrade of four 9.5 km long circuits between Manby TS and Wiltshire TS and \$40 M for distribution facilities by THESL. The transmission cost of \$50M is expected to be recovered in accordance with the TSC.

Hydro One has initiated development work on the project covering preparation of estimates and obtaining of EA approvals. The estimate is expected to be completed by the end of Q2 2016. It will also confirm if

the targeted in-service date of May 2019 for this project is achievable. A Section 92 application will be submitted in 2016.

## 7.2 Southwest Toronto Area

### 7.2.1 Station Capacity – Southwest Toronto (Manby TS & Horner TS)

Manby TS and Horner TS are two 230/27.6 kV transformer stations supplying the load demand in the southwest end of Toronto (see Figure 7-2). Based on the current RIP forecast the 400MW combined station capacity of the stations is forecast to be exceeded by summer 2020. Additional step down transformation is required to provide relief.



Figure 7-2 Horner TS and Manby TS Supply Area

### 7.2.2 Recommended Plan and Current Status.

To address the need for additional step down transformation capacity in the Southwest Toronto area, the Working Group’s recommended building a second 230/27.6 kV DESN at the existing Horner TS site. Two 75/125MVA transformers will be installed at the station along with a new 27.6kV switchyard. Load transfer out of Manby TS to Horner TS is required to relieve Manby TS as the loading at that station exceeds its capacity. New distribution feeder ties are required to be built between Manby TS and Horner TS by THESL.

The estimated total cost of the work is about \$53M, which includes \$34 M for the station work at Horner TS and \$19M for THESL distribution facilities. The transmission cost of \$34M is expected to be recovered in accordance with the TSC.

Hydro One has initiated development work on the project covering preparation of estimates and obtaining of EA approvals at the request of THESL. The current in-service date for the project is expected to be May 2020.

### 7.3 Downtown District

#### 7.3.1 Station Capacity – JETC<sup>2</sup> Area

The Toronto Downtown Core area is mainly supplied by the three existing 115/13.8 kV stations: John TS, Esplanade TS, and Terauley TS. John TS is connected to the Manby West system while Esplanade TS and Terauley TS are fed from the 115 kV Leaside / Hearn system. (see Figure 7-3)



Figure 7-3 Toronto Downtown Supply Area

John TS was built in the 1950's and the THESL switchgear at the station is approaching end of life. THESL is building a new 115/13.8kV owned transformer station, Copeland MTS in the Downtown

<sup>2</sup> JETC denotes John TS, Esplanade TS, Terauley TS, and Copeland MTS which jointly supply the Downtown District.

District near John TS with normal supplied from the 115 kV Manby West system. The station first phase capacity will be around 130 MVA and it is expected to be in service in 2016. Copeland MTS will provide a new source of supply to the area customers and facilitate the replacement of end of life switchgear at John TS.

With the new Copeland MTS in-service in 2016, adequate transformation capacity will be available in the Downtown District till 2027. However, most of this capacity will be at John TS as 13.8kV buses at both Terauley TS and Esplanade TS are at or approaching capacity limits. THESL anticipates that the need for new transformation facility is more advanced due to limited spare feeder positions available at John TS for new customer connection and load transfer required to facilitate the refurbishment work at John TS. At the current pace of development in these areas, both bus and feeder position in the Downtown Core area are expected to be at or near capacity within five to ten years<sup>3</sup>. Specific issues identified by THESL Hydro are as follows:

- By 2019 THESL forecasts that two busses will be overloaded (ie. loaded beyond 10 Day LTR) at George and Duke MS and two busses overloaded at John/Windsor TS.
- By 2025 THESL forecasts that one bus will be overloaded at Copeland TS, two busses overloaded at George and Duke MS and three busses overloaded at John/Windsor TS.
- At John/Windsor TS, four out of six busses have no spare feeder positions to connect new customers. One bus has a single spare feeder position and one bus has two spare feeder positions.
- At George and Duke MS, one bus has no spare feeder positions and one bus has six spare feeder positions.
- At Esplanade TS, there is only one bus with three spare feeder positions.
- Once in service, Copeland TS is forecasted to have six and three spare positions on each its two busses, respectively.

### **7.3.2 Recommended Plan and Current Status**

Based on the current information, the need to relieve the stations in Downtown District is expected to be beyond 2020. However, the need date may get delayed or brought forward if the load growth in this area is slower or faster than currently anticipated. The Working Group recommends that this need and timing should be further refined by THESL through their distribution planning process and included in updates to the IRRP and RIP. The uptake of CDM and DG should be preserved and re-assessed.

In the case where CDM and DG are deemed insufficient, building Copeland Phase 2 and installing additional transformers and two new buses at Copeland MTS site is the most cost effective way to meet the required THESL needs. The site and the high voltage switching facilities required to accommodate this expansion (Copeland Phase 2) are already included as part of the Copeland MTS Phase 1 project. Copeland MTS is an underground station and is not located adjacent to residential land uses. The THESL estimated cost for Copeland MTS Phase 2 to be approximately \$46 M.

---

<sup>3</sup> Further information may be found in THESL's rate application EB-2014-0116 to the Ontario Energy Board



**Table 7-2 Coincident RIP MW Load Forecast for Richview TS x Manby TS Area**

|   | Limit | 2015 | 2017 | 2019 | 2021        | 2023        | 2025 | 2027 | 2029 | 2031 | 2033 | 2035 |
|---|-------|------|------|------|-------------|-------------|------|------|------|------|------|------|
| <b>Base - Without Metrolinx Mimico TPS load</b> |       |      |      |      |             |             |      |      |      |      |      |      |
| <b>High Growth</b>                              | 1540  | 1456 | 1488 | 1536 | <b>1580</b> | 1617        | 1646 | 1674 | 1698 | 1722 | 1742 | 1763 |
| <b>Low Growth</b>                               | 1540  | 1456 | 1481 | 1503 | 1530        | <b>1544</b> | 1557 | 1566 | 1572 | 1577 | 1597 | 1617 |
| <b>With Metrolinx Mimico TPS load</b>           |       |      |      |      |             |             |      |      |      |      |      |      |
| <b>High Growth</b>                              | 1540  | 1456 | 1488 | 1536 | <b>1640</b> | 1697        | 1726 | 1754 | 1778 | 1802 | 1822 | 1843 |
| <b>Low Growth</b>                               | 1540  | 1456 | 1481 | 1503 | <b>1590</b> | 1624        | 1637 | 1646 | 1652 | 1657 | 1677 | 1697 |

### 7.4.2 Alternatives Considered

The following alternatives are currently under consideration:

Upgrade four existing 230kV Richview TS x Manby TS circuits: Re-conductor with higher-capacity conductors on existing towers. Hydro One will check the feasibility of this option without major tower modifications and also in terms of outages arrangement. The estimated total cost of this option is about \$16M, assuming that no major tower modifications and no bypass lines during re-conductoring are required.

Rebuild existing 115kV Richview TS x Manby TS line: Rebuild the existing idle 115 kV double-circuit line as a 230kV double-circuit line. The new 230 kV line is to share the existing terminations for circuits R2K and R15K at Richview TS and Manby TS. The ampacity of the new conductors are to be equal to or better than that of the existing circuits, effectively doubling the ampacity of R2K and R15K. This alternative requires the replacement of all the existing 115 kV towers with 230 kV towers. The estimated total cost of this option is about \$19.5M.

Build two new 230 kV Richview TS x Manby TS circuits: Similar to the second alternative above, rebuild the two existing idle 115 kV double-circuit line as a 230kV double-circuit line. New terminations for these circuits are required at Richview TS and Manby TS. The ampacity of the new conductors are to be equal to or better than that of the existing circuits. This alternative not only provides higher transmission capacity but also increases the supply reliability to the Central Downtown and Southwest GTA area. The estimated total cost of this option is around \$39.5M due to the extra station work required at the Richview TS and Manby TS.

Extend the Cooksville TS x Oakville TS line to Trafalgar TS: Extend the Cooksville TS x Oakville TS 230kV double circuit line B15C/B16C about 8km to Trafalgar TS where new 230kV switching facilities are also required. This alternative increases supply capacity and reliability to Southwest GTA area from Trafalgar TS, and thus alleviates the loading on the Richview x Manby corridor. The total estimated cost of this line and station work is around \$54M.

CDM & DG: According to Central Toronto IRRP report, the potential DG development, targeted demand response and the potential incremental demand response in these areas supplied by Manby TS may defer the need for this transmission reinforcement by several years, depending on the load growth rate. However, with Mimico TPS connected near Horner TS, these targeted and potential incremental demand response will not be adequate due to the size of the extra load added by the TPS.

The Maintain Status Quo or Do Nothing alternative was not considered as it does not provide relief for the Richview x Manby transmission lines.

### **7.4.3 Recommended Plan and Current Status**

The Metrolinx Mimico TPS information is new and was provided as part of the RIP after the IRRP was completed in April 2015. If this TPS is going to be in-service as planned in 2020, CDM initiatives will not effectively defer the need date for this transmission corridor because of the size of the additional load. Therefore, upgrading the existing Richview x Manby corridor or new supply path for the areas served by Manby TS will be required before the Metrolinx Mimico TPS can be connected.

The Trafalgar x Oakville line alternative, at \$54M, is the highest cost alternative (\$14.5M higher than the next most expensive alternative) and there is a risk that it may not be able to be completed in time to connect the the Metrolinx Mimico TPS in 2020. This alternative may also trigger the need for additional transformation facilities and thus would incur additional costs.

As a result, Working Group recommends that Hydro One proceed with the development and estimate work on the first three alternatives listed in Section 7.4.2 in 2016. Both EA and Section 92 approvals will be required and it is expected to take at least 3-4 years for the implementation of a wire solution. The Working Group will select the preferred alternative by December 2016. Hydro One will then plan to initiate project execution by summer 2018 in order to enable the connection of MetroLinx Mimico TPS by summer 2020.

### **7.5 Transmission Line Capacity – Circuit C10A (Duffin Jct. to Agincourt Jct)**

C10A is a 20 km long radial circuit in Metro Toronto Northern Sub-Region from Cherrywood TS supplying Agincourt TS and Cavanagh MTS. The Metro Toronto Northern Sub-Region NA identified that the capacity of this circuit was thermally limited by a section approximately 4 km long between Duffin Jct. and Agincourt Jct. The flow on this section of the circuit might exceed its long-term emergency (LTE) rating under summer peak load conditions following certain contingencies.

A preliminary study based on the old field survey data was done in July 2015. The old record showed that the LTE rating was limited by some underbuilds along the line section. A new field survey was then carried out in October 2015. It was discovered that the aforementioned underbuilds had been previously removed, and the LTE rating of this line section should be 840A. The record is being updated. No further action is required.



## **7.6 Breaker Failure at Manby TS**

### **7.6.1 Description**

The failure of any of the Manby TS breakers A1H4 and H1H4 in the Manby West 230kV yard and the breaker H2H3 in the Manby east 230kV yard can cause the outage of any two of the three 230/115kV autotransformers at either the west or east yard of Manby TS. This may result in the overload of the remaining autotransformer. Based on the Coincident RIP Forecast the need date for the work is summer 2018 and summer 2021 for Manby West and Manby East respectively.

### **7.6.2 Recommended Plan and Current Status**

The Working Group has recommended that installation of a Special Protection Scheme (SPS) is the most cost effective means to mitigate the breaker failure risk.

Hydro One is working on the development and estimate work for the SPS at Manby TS. The preliminary estimate for this work is approximately \$2M and this will be updated when the development work is complete by summer 2016. The planned in-service of this work is summer 2018.

## **7.7 Breaker Failure at Leaside TS**

The failure of breaker L14L15 at Leaside TS can cause the outage of two of the Leaside TS to Bridgman TS circuits. This may result in the loss of Transformers T11, T12, T14 and T15 at Bridgman TS. Under this scenario, two of the four LV buses will be lost by configuration. Only transformer T13 remains in service and supplies buses HLA1 and HLA7.

The 15 minute LTR for the X and Y windings of Transformer T13 is 55MVA. Therefore, as long as the loading on the HLA1 and HLA7 does not exceed the 15 minutes LTR, the operator can take action to reduce load to within transformer LTE ratings.

A new normally open switch is being installed at Bridgman TS as part of the Leaside-Bridgman Transmission Reinforcement project. This new switch can be closed remotely following the loss of the circuit L15W to resupply the two Bridgman transformers from the circuit L13W. This will alleviate the loading of the transformer T13 and the circuit L18W. and any possible voltage issue at Bridgman TS. Therefore, no investment is recommended.

### 7.8 Cherrywood to Leaside (CxL) Double Circuit Contingencies

Double circuit contingencies involving the lines C2L/C3L or C16L/C17L from Cherrywood TS to Leaside TS (CxL) can result in the loss of two of the three 230/115kV autotransformers on the same half of Leaside TS. The long-term emergency rating of the remaining autotransformer may be exceeded if only a single combustion unit at the Portland Energy Centre (PEC) is available, coincident with either of the abovementioned double contingencies during peak load condition.

The Working Group recommends that no further work is required in the near- and mid-term as there is already an existing operating instruction in place to cover the overload issue of the remaining Leaside autotransformer by closing the 115kV bus-tie at Leaside TS.

### 7.9 Load Restoration – Northern Sub-Region (Bathurst TS, Fairchild TS, Leslie TS)

Bathurst TS, Fairchild TS, and Leslie TS are supplied by the 230 kV Richview x Cherrywood x Parkway system in the Metro Toronto Northern Sub-Region. Following two circuit contingencies, approximately 240-300 MW of load during summer peak time could be lost during each contingency scenario, as follows:

**Table 7-3 Maximum Load Loss during Two Circuit Contingencies**

| Double Element Contingency | Station Connected | Non-Coincident Load Forecast (MW) |      |
|----------------------------|-------------------|-----------------------------------|------|
|                            |                   | 2015                              | 2025 |
| P22R + C18R                | Bathurst TS       | 271                               | 279  |
| C18R + C20R                | Fairchild TS      | 292                               | 301  |
| P21R + C5R                 | Leslie TS         | 239                               | 249  |

There are currently no existing transmission switching facilities to allow load restoration immediately. Partial load could be restored via distribution transfer to the nearby stations.

For Bathurst and Leslie cases, the stations are supplied by circuits on separate transmission lines for all or most sections. The probability of occurrence of overlapping outages on circuits on different tower lines is extremely low. The supplied circuits for Fairchild TS are on common tower for two-third of the line (approximately 32km).

Based on the outage records in the past 25 years there has been no incidence of any double contingencies described above.

A single transformer station would require four motorized disconnect switches to be useful. Typical cost for installing these transmission switching facilities per station would be between \$8-10M.

Based on the low probability of frequency of such events versus the high mitigation cost, the Working Group recommendation is that no further action is required.

## 7.10 Long Term Needs

Four longer term needs had been identified in the Central Toronto IRRP as follows:

- Transmission Line Capacity – 115 kV Manby West To Riverside Junction
- Transformation Capacity – 230/115 kV Manby TS
- Transformation Capacity – 230/115 kV Leaside TS
- Leaside TS x Wiltshire TS 115kV circuits

Loading on Manby TS and the Manby TS x Riverside Junction circuit are within ratings over the study period under the Coincident RIP forecast. The Working Group recommendation is that no further action is required.

The Leaside TS transformer and the Leaside TS x Wiltshire circuits will require relief in the long term. This issue will be considered in the next planning cycle. The Working Group recommendation is that no further action is required. However, Hydro One and IESO will continue to monitor loads and initiate necessary relief measures, if required.

## 8. CONCLUSIONS AND NEXT STEPS

THIS REGIONAL INFRASTRUCTURE PLAN REPORT CONCLUDES THE REGIONAL PLANNING PROCESS FOR THE METRO TORONTO REGION. THIS REPORT MEETS THE INTENT OF THE PROCESS DESCRIBED IN SECTION 2 WHICH IS ENDORSED BY THE OEB AND MANDATED IN THE TSC AND DSC.

This RIP report addresses regional needs identified in the earlier phases of the Regional Planning process and any new needs identified during the RIP phase. These needs are summarized in the Table 8-1 below.

**Table 8-1 Regional Plans – Needs Identified in the Regional Planning Process**

| No. | Need Description  |
|-----|---|
| I   | Supply Security – Breaker Failure at Manby West & East TS |
| II  | West Toronto Area - Station Capacity and Line Capacity    |
| III | Southwest Toronto - Station Capacity                      |
| IV  | Downtown District - Station Capacity                      |
| V   | 230 kV Richview x Manby Corridor– Line Capacity           |
| VI  | Leaside Autotransformers                                  |
| VII | Line Capacity – 115 kV Leaside x Wiltshire Corridor       |

Next Steps, Lead Responsibility, and Timeframes for implementing the wires solutions for the near-term and mid-term needs are summarized in the Table 8-2 below. Investments to address the long-term needs where there is time to make a decision (Need No. VI & VII), will be reviewed and finalized in the next regional planning cycle.

**Table 8-2 Regional Plans – Next Steps, Lead Responsibility and Plan In-Service Dates**

| Id | Project   | Next Steps                             | Lead Responsibility | I/S Date | Est. Cost | Needs Mitigated |
|----|---|--|---------------------|----------|-----------|-----------------|
| 1  | Manby SPS   | Transmitter to carry out the work      | Hydro One           | 2018     | \$2M      | I               |
| 2  | Runnymede Expansion & 115 kV Manby x Wiltshire Corridor Upgrade | Transmitter to carry out the work      | Hydro One           | 2019     | \$90M     | II              |
| 3  | Horner Expansion  | Transmitter to carry out the work      | Hydro One           | 2020     | \$53M     | III             |
| 4  | 230 kV Richview x Manby Corridor Upgrade                        | Transmitter to carry out the work      | Hydro One           | 2020     | \$20-40M  | V               |
| 5  | Copeland Phase 2  | LDC to carry out work & monitor growth | THESL               | 2020+    | \$46M     | IV              |

In accordance with the Regional Planning process, the Regional Planning cycle should be triggered every five years. The next planning cycle for the Metro Toronto Region is expected to be started in 2018. However, the Region will continue to be monitored and should there be a need that emerges due to a change in load forecast or any other reason, the regional planning cycle will be started earlier to address the need.

## 9. REFERENCES

- [1]. Independent Electricity System Operator, “Central Toronto Integrated Regional Resource Plan”, 28 April 2015.  
[http://www.ieso.ca/Documents/Regional-Planning/Metro\\_Toronto/2015-Central-Toronto-IRRP-Report.pdf](http://www.ieso.ca/Documents/Regional-Planning/Metro_Toronto/2015-Central-Toronto-IRRP-Report.pdf)
- [2]. Hydro One, “Needs Screening Report, Metro Toronto Region – Northern Sub-Region”, 11 June 2014.  
<http://www.hydroone.com/RegionalPlanning/Toronto/Documents/Needs%20Assessment%20Report%20-%20Metro%20Toronto%20-%20Northern%20Subregion.pdf>

## Appendix A. Stations in the Metro Toronto Region

| Station (DESN)                  | Voltage (kV) | Supply Circuits           |
|---------------------------------|--------------|---------------------------|
| Agincourt TS T5/T6              | 230/27.6     | C4R/C10A                  |
| Basin TS T3/T5                  | 115/13.8     | H3L/H1L                   |
| Bathurst TS T1/T2               | 230/27.6     | P22R/C18R                 |
| Bathurst TS T3/T4               | 230/27.6     | P22R/C18R                 |
| Bermondsey TS T1/T2             | 230/27.6     | C17L/C14L                 |
| Bermondsey TS T3/T4             | 230/27.6     | C17L/C14L                 |
| Bridgman TS T11/T12/T13/T14/T15 | 115/13.8     | L13W/L15W/L14W            |
| Carlaw TS T1/T2                 | 115/13.8     | H1L/H3L                   |
| Cecil TS T1/T2                  | 115/13.8     | Cecil Buses H & P         |
| Cecil TS T3/T4                  | 115/13.8     | Cecil Buses P & H         |
| Charles TS T1/T2                | 115/13.8     | L4C/L9C                   |
| Charles TS T3/T4                | 115/13.8     | L12C/L4C                  |
| Dufferin TS T1/T3               | 115/13.8     | L13W/L15W                 |
| Dufferin TS T2/T4               | 115/13.8     | L13W/L15W                 |
| Duplex TS T1/T2                 | 115/13.8     | L16D/L5D                  |
| Duplex TS T3/T4                 | 115/13.8     | L5D/L16D                  |
| Ellesmere TS T3/T4              | 230/27.6     | C2L/C3L                   |
| Esplanade TS T11/T12/T13        | 115/13.8     | H2JK/H10EJ(C5E)/H9EJ(C7E) |
| Fairbank TS T1/T3               | 115/27.6     | K3W/K1W                   |
| Fairbank TS T2/T4               | 115/27.6     | K3W/K1W                   |
| Fairchild TS T1/T2              | 230/27.6     | C18R/C20R                 |

| <b>Station (DESN)</b>       | <b>Voltage (kV)</b> | <b>Supply Circuits</b>       |
|-----------------------------|---------------------|------------------------------|
| Fairchild TS T3/T4          | 230/27.6            | C18R/C20R                    |
| Finch TS T1/T2              | 230/27.6            | C20R/P22R                    |
| Finch TS T3/T4              | 230/27.6            | P21R/C4R                     |
| Gerrard TS T1/T3/T4         | 115/13.8            | H3L/H1L                      |
| Glengrove TS T1/T3          | 115/13.8            | D6Y/L2Y                      |
| Glengrove TS T2/T4          | 115/13.8            | D6Y/L2Y                      |
| Horner TS T3/T4             | 230/27.6            | R13K/R2K                     |
| John TS T1/T2/T3/T4         | 115/13.8            | John Buses K1 & K2 & K3 & K4 |
| John TS T5/T6               | 115/13.8            | John Buses K1 & K4           |
| Leaside TS T19/T20/T21 13.8 | 230/13.8            | C2L/C3L/C16L                 |
| Leaside TS T19/T20/T21 27.6 | 230/27.6            | C2L/C3L/C16L                 |
| Leslie TS T1/T2 13.8        | 230/13.8            | P21R/C5R                     |
| Leslie TS T1/T2 27.6        | 230/27.6            | P21R/C5R                     |
| Leslie TS T3/T4             | 230/27.6            | P21R/C5R                     |
| Main TS T3/T4               | 115/13.8            | H7L/H11L                     |
| Malvern TS T3/T4            | 230/27.6            | C4R/C5R                      |
| Manby TS T13/T14            | 230/27.6            | Manby W Buses A1 & H1        |
| Manby TS T3/T4              | 230/27.6            | Manby W Buses A1 & H1        |
| Manby TS T5/T6              | 230/27.6            | Manby E Buses H2 & A2        |
| Rexdale TS T1/T2            | 230/27.6            | V74R/V76R                    |
| Richview TS T1/T2           | 230/27.6            | Richview Buses H1 & A1       |
| Richview TS T5/T6           | 230/27.6            | V74R/V72R                    |
| Richview TS T7/T8           | 230/27.6            | Richview Buses H2 & A2       |
| Runnymede TS T3/T4          | 115/27.6            | K12W/K11W                    |



| <b>Station (DESN)</b>       | <b>Voltage (kV)</b> | <b>Supply Circuits</b>            |
|-----------------------------|---------------------|-----------------------------------|
| Scarboro TS T21/T22         | 230/27.6            | C14L/C2L                          |
| Scarboro TS T23/T24         | 230/27.6            | C15L/C3L                          |
| Sheppard TS T1/T2           | 230/27.6            | C16L/C15L                         |
| Sheppard TS T3/T4           | 230/27.6            | C15L/C16L                         |
| Strachan TS T12/T14         | 115/13.8            | H2JK/K6J                          |
| Strachan TS T13/T15         | 115/13.8            | K6J/H2JK                          |
| Terauley TS T1/T4           | 115/13.8            | C7E/C5E                           |
| Terauley TS T2/T3           | 115/13.8            | C7E/C5E                           |
| Warden TS T3/T4             | 230/27.6            | C14L/C17L                         |
| Wiltshire TS T1/T6          | 115/13.8            | K1W/K3W (Wiltshire Buses H1 & H3) |
| Wiltshire TS T2/T5          | 115/13.8            | K1W/K3W (Wiltshire Buses H1 & H3) |
| Wiltshire TS T3/T4          | 115/13.8            | K1W/K3W (Wiltshire Buses H1 & H3) |
| Cavanagh MTS T1/T2          | 230/27.6            | C20R/C10A                         |
| IBM Markham CTS T1/T2       | 230/13.8            | P21R/P22R                         |
| Markham MTS #1 T1/T2        | 230/27.6            | P21R/P22R                         |
| Copeland MTS T1/T3 (Future) | 115/13.8            | D11J/D12J                         |

## Appendix B. Transmission Lines in the Metro Toronto Region

| <b>Location</b>           | <b>Circuit Designations</b>        | <b>Voltage (kV)</b> |
|---------------------------|------------------------------------|---------------------|
| Richview x Manby          | R1K, R2K, R13K, R15K               | 230                 |
| Richview x Cooksville     | R24C                               | 230                 |
| Manby x Cooksville        | K21C, K23C                         | 230                 |
| Cherrywood x Leaside      | C2L, C3L, C14L, C15L, C16L, C17L   | 230                 |
| Cherrywood x Richview     | C4R, C5R, C18R, C20R               | 230                 |
| Cherrywood x Agincourt    | C10A                               | 230                 |
| Parkway x Richview        | P21R, P22R                         | 230                 |
| Claireville x Richview    | V72R, V73R, V74R, V76R, V77R, V79R | 230                 |
| Manby East x Wiltshire    | K1W, K3W, K11W, K12W               | 115                 |
| Manby West x John         | K6J, K13J, K14J                    | 115                 |
| Manby West x John x Hearn | H2JK                               | 115                 |
| John x Esplanade x Hearn  | H9EJ, H10EJ                        | 115                 |
| Esplanade x Cecil         | C5E, C7E                           | 115                 |
| Hearn x Cecil x Leaside   | H6LC, H8LC                         | 115                 |
| Hearn x Leaside           | H1L, H3L, H7L, H11L                | 115                 |
| Leaside x Charles         | L4C                                | 115                 |
| Leaside x Cecil           | L9C, L12C                          | 115                 |
| Leaside x Duplex          | L5D, L16D                          | 115                 |
| Leaside x Glengrove       | L2Y                                | 115                 |
| Duplex x Glengrove        | D6Y                                | 115                 |

## Appendix C. Distributors in the Metro Toronto Region

| Distributor Name                      | Station Name  | Connection Type |
|---------------------------------------|---------------|-----------------|
| Toronto Hydro-Electric System Limited | Agincourt TS  | Tx              |
|                                       | Basin TS      | Tx              |
|                                       | Bathurst TS   | Tx              |
|                                       | Bermondsey TS | Tx              |
|                                       | Bridgman TS   | Tx              |
|                                       | Carlaw TS     | Tx              |
|                                       | Cecil TS      | Tx              |
|                                       | Charles TS    | Tx              |
|                                       | Dufferin TS   | Tx              |
|                                       | Duplex TS     | Tx              |
|                                       | Ellesmere TS  | Tx              |
|                                       | Esplanade TS  | Tx              |
|                                       | Fairbank TS   | Tx              |
|                                       | Fairchild TS  | Tx              |
|                                       | Finch TS      | Tx              |
|                                       | Gerrard TS    | Tx              |
|                                       | Glengrove TS  | Tx              |
|                                       | Horner TS     | Tx              |
|                                       | John TS       | Tx              |
|                                       | Leaside TS    | Tx              |
|                                       | Leslie TS     | Tx              |
|                                       | Main TS       | Tx              |
|                                       | Malvern TS    | Tx              |
|                                       | Manby TS      | Tx              |
|                                       | Rexdale TS    | Tx              |
|                                       | Richview TS   | Tx              |
|                                       | Runnymede TS  | Tx              |
|                                       | Scarboro TS   | Tx              |
|                                       | Sheppard TS   | Tx              |
|                                       | Strachan TS   | Tx              |
|                                       | Terauley TS   | Tx              |
|                                       | Warden TS     | Tx              |
| Wiltshire TS                          | Tx            |                 |
| Cavanagh MTS                          | Tx            |                 |
| Copeland MTS (Future)                 | Tx            |                 |

| Distributor Name                  | Station Name | Connection Type |
|-----------------------------------|--------------|-----------------|
| Hydro One Networks Inc. (Dx)      | Agincourt TS | Tx              |
|                                   | Fairchild TS | Tx              |
|                                   | Finch TS     | Tx              |
|                                   | Leslie TS    | Tx              |
|                                   | Malvern TS   | Tx              |
|                                   | Richview TS  | Tx              |
|                                   | Sheppard TS  | Tx              |
|                                   | Warden TS    | Tx              |
|                                   |              |                 |
| PowerStream Inc.                  | Agincourt TS | Dx              |
|                                   | Fairchild TS | Dx              |
|                                   | Finch TS     | Dx              |
|                                   | Leslie TS    | Dx              |
|                                   |              |                 |
| Veridian Connections Inc.         | Malvern TS   | Dx              |
|                                   | Sheppard TS  | Dx              |
|                                   |              |                 |
| Enersource Hydro Mississauga Inc. | Richview TS  | Dx              |

## Appendix D. Metro Toronto Regional Load Forecast (2015-2035)

**Table D-1 Non-Coincident RIP Forecast (High Demand Growth)**

|                             |                            |                      | LTR                | 2015        | 2016        | 2017        | 2018        | 2019        | 2020        | 2021        | 2023        | 2025        | 2027        | 2029        | 2031        | 2033        | 2035        |
|-----------------------------|----------------------------|----------------------|--------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Central 115kV               | Lea115                     | Basin                | 84                 | 57          | 60          | 64          | 67          | 68          | 69          | 70          | 71          | 73          | 75          | 77          | 79          | 81          | 83          |
|                             |                            | Bridgman             | 179                | 174         | 177         | 179         | 181         | 182         | 183         | 184         | 185         | 187         | 189         | 191         | 193         | 195         | 198         |
|                             |                            | Carlaw               | 131                | 65          | 66          | 68          | 70          | 71          | 73          | 74          | 72          | 71          | 72          | 75          | 78          | 80          | 82          |
|                             |                            | Cecil                | 204                | 168         | 169         | 171         | 173         | 175         | 177         | 178         | 181         | 183         | 186         | 190         | 193         | 196         | 199         |
|                             |                            | Charles              | 200                | 151         | 153         | 156         | 158         | 159         | 161         | 162         | 165         | 167         | 170         | 172         | 173         | 177         | 181         |
|                             |                            | Dufferin             | 161                | 141         | 144         | 147         | 149         | 150         | 150         | 150         | 152         | 154         | 156         | 158         | 159         | 161         | 163         |
|                             |                            | Duplex               | 121                | 103         | 105         | 107         | 109         | 110         | 111         | 112         | 114         | 116         | 118         | 121         | 123         | 125         | 127         |
|                             |                            | Espanade             | 177                | 169         | 170         | 172         | 173         | 176         | 178         | 180         | 185         | 190         | 196         | 201         | 206         | 210         | 215         |
|                             |                            | Gerrard              | 62                 | 44          | 45          | 46          | 48          | 49          | 50          | 51          | 63          | 78          | 88          | 90          | 92          | 93          | 94          |
|                             |                            | Glengrove            | 84                 | 55          | 57          | 58          | 59          | 60          | 60          | 61          | 62          | 63          | 64          | 66          | 67          | 68          | 69          |
|                             | Main                       | 72                   | 65                 | 64          | 63          | 62          | 63          | 64          | 66          | 65          | 65          | 66          | 69          | 72          | 75          | 77          |             |
|                             | Terauley                   | 205                  | 187                | 191         | 196         | 201         | 205         | 209         | 213         | 217         | 220         | 224         | 230         | 236         | 240         | 245         |             |
|                             | ManbyE115-13.8             | Wiltshire            | 113                | 67          | 68          | 69          | 70          | 70          | 71          | 72          | 72          | 72          | 73          | 74          | 75          | 76          |             |
|                             | ManbyE115-27.6             | Runnymede            | 109                | 116         | 118         | 120         | 122         | 122         | 123         | 123         | 125         | 126         | 128         | 129         | 131         | 132         | 133         |
|                             |                            | Runnymede -LRT       | 0                  | 0           | 0           | 0           | 0           | 0           | 0           | 14          | 18          | 23          | 26          | 26          | 26          | 26          | 26          |
|                             | ManbyW115                  | Fairbank             | 176                | 175         | 178         | 181         | 184         | 186         | 187         | 188         | 190         | 193         | 195         | 197         | 199         | 201         | 203         |
|                             |                            | Copeland             | 111                | 0           | 0           | 86          | 102         | 102         | 102         | 102         | 106         | 111         | 113         | 113         | 113         | 113         | 113         |
|                             |                            | John                 | 246                | 276         | 276         | 189         | 189         | 192         | 195         | 198         | 202         | 206         | 209         | 213         | 218         | 221         | 225         |
|                             |                            | Strachan             | 161                | 130         | 133         | 135         | 138         | 139         | 141         | 143         | 145         | 146         | 149         | 152         | 154         | 156         | 157         |
| <b>Central 115kV Total</b>  |                            |                      | <b>2595</b>        | <b>2143</b> | <b>2175</b> | <b>2206</b> | <b>2255</b> | <b>2279</b> | <b>2303</b> | <b>2341</b> | <b>2390</b> | <b>2444</b> | <b>2495</b> | <b>2540</b> | <b>2587</b> | <b>2626</b> | <b>2666</b> |
| Eastern 230kV               | CxL230                     | Bermondsey           | 348                | 194         | 196         | 198         | 200         | 200         | 200         | 200         | 202         | 203         | 204         | 206         | 207         | 209         | 210         |
|                             |                            | Ellesmere            | 189                | 169         | 171         | 173         | 175         | 175         | 175         | 175         | 176         | 177         | 178         | 180         | 181         | 182         | 183         |
|                             |                            | Leaside              | 210                | 156         | 158         | 159         | 161         | 161         | 161         | 161         | 163         | 165         | 166         | 168         | 170         | 172         | 174         |
|                             |                            | Scarboro             | 340                | 222         | 225         | 227         | 230         | 230         | 230         | 230         | 231         | 233         | 234         | 236         | 238         | 239         | 241         |
|                             |                            | Sheppard             | 204                | 170         | 170         | 171         | 171         | 171         | 171         | 171         | 173         | 174         | 175         | 176         | 178         | 179         | 180         |
|                             |                            | Warden               | 183                | 126         | 128         | 129         | 130         | 130         | 130         | 130         | 131         | 132         | 133         | 134         | 135         | 136         | 137         |
|                             |                            | Metrolinx            | Metrolinx - Warden | 0           | 0           | 0           | 0           | 0           | 0           | 40          | 60          | 80          | 80          | 80          | 80          | 80          | 80          |
|                             | <b>Eastern 230kV Total</b> |                      |                    | <b>1474</b> | <b>1037</b> | <b>1047</b> | <b>1057</b> | <b>1067</b> | <b>1067</b> | <b>1107</b> | <b>1127</b> | <b>1155</b> | <b>1164</b> | <b>1172</b> | <b>1180</b> | <b>1189</b> | <b>1197</b> |
| Northern 230kV              | CxR                        | Agincourt            | 174                | 95          | 97          | 99          | 101         | 102         | 103         | 104         | 104         | 105         | 106         | 107         | 107         | 108         | 109         |
|                             |                            | Bathurst             | 334                | 271         | 272         | 274         | 275         | 275         | 275         | 275         | 277         | 279         | 281         | 283         | 285         | 287         | 289         |
|                             |                            | Cavanagh             | 157                | 141         | 141         | 141         | 142         | 142         | 142         | 142         | 143         | 144         | 145         | 146         | 147         | 148         | 149         |
|                             |                            | Fairchild            | 357                | 292         | 293         | 295         | 297         | 297         | 297         | 297         | 299         | 301         | 303         | 306         | 308         | 310         | 312         |
|                             |                            | Finch                | 363                | 289         | 292         | 295         | 298         | 298         | 298         | 298         | 300         | 302         | 304         | 306         | 309         | 311         | 313         |
|                             |                            | Leslie               | 325                | 239         | 241         | 244         | 246         | 246         | 246         | 246         | 248         | 249         | 251         | 253         | 255         | 256         | 258         |
|                             |                            | Malvern              | 176                | 106         | 106         | 107         | 107         | 107         | 107         | 107         | 108         | 109         | 109         | 110         | 111         | 112         | 113         |
| <b>Northern 230kV Total</b> |                            |                      | <b>1885</b>        | <b>1433</b> | <b>1444</b> | <b>1455</b> | <b>1466</b> | <b>1467</b> | <b>1468</b> | <b>1469</b> | <b>1479</b> | <b>1490</b> | <b>1500</b> | <b>1511</b> | <b>1521</b> | <b>1532</b> | <b>1543</b> |
| Western 230kV               | Manby230                   | Horner               | 179                | 144         | 146         | 148         | 150         | 151         | 152         | 153         | 155         | 157         | 157         | 156         | 155         | 157         | 159         |
|                             |                            | Manby                | 221                | 232         | 236         | 240         | 244         | 246         | 249         | 251         | 255         | 259         | 265         | 273         | 282         | 286         | 290         |
|                             | Metrolinx                  | Metrolinx - Cityview | 0                  | 0           | 0           | 0           | 0           | 0           | 40          | 60          | 80          | 80          | 80          | 80          | 80          | 80          | 80          |
|                             |                            | Metrolinx - Mimico   | 0                  | 0           | 0           | 0           | 0           | 0           | 40          | 60          | 80          | 80          | 80          | 80          | 80          | 80          | 80          |
|                             | Rich230                    | Rexdale              | 187                | 135         | 135         | 135         | 135         | 134         | 133         | 132         | 133         | 134         | 135         | 136         | 137         | 138         | 139         |
|                             |                            | Richview T1T2EZ      | 154                | 130         | 131         | 131         | 131         | 130         | 129         | 128         | 129         | 130         | 131         | 132         | 133         | 134         | 135         |
|                             |                            | Richview T5T6JQ      | 188                | 109         | 110         | 110         | 110         | 109         | 108         | 108         | 108         | 109         | 110         | 111         | 111         | 112         | 113         |
|                             | Richview T7T8BY            | 113                  | 54                 | 54          | 54          | 54          | 54          | 54          | 53          | 54          | 54          | 54          | 55          | 55          | 56          | 56          |             |
| <b>Western 230kV Total</b>  |                            |                      | <b>1042</b>        | <b>805</b>  | <b>811</b>  | <b>818</b>  | <b>825</b>  | <b>825</b>  | <b>905</b>  | <b>945</b>  | <b>994</b>  | <b>1003</b> | <b>1013</b> | <b>1023</b> | <b>1034</b> | <b>1043</b> | <b>1052</b> |
| <b>Grand Total</b>          |                            |                      | <b>6995</b>        | <b>5419</b> | <b>5477</b> | <b>5537</b> | <b>5613</b> | <b>5638</b> | <b>5783</b> | <b>5883</b> | <b>6019</b> | <b>6100</b> | <b>6180</b> | <b>6254</b> | <b>6331</b> | <b>6398</b> | <b>6466</b> |

**Table D-2 Coincident RIP Forecast (High Demand Growth)**

|                      |                |                      | LTR       | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2023 | 2025 | 2027 | 2029 | 2031 | 2033 | 2035 |     |
|----------------------|----------------|----------------------|-----------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|-----|
| Central 115kV        | Lea115         | Basin                | 84        | 52   | 55   | 58   | 61   | 62   | 63   | 63   | 65   | 66   | 68   | 70   | 72   | 73   | 75   |     |
|                      |                | Bridgman             | 179       | 171  | 173  | 175  | 177  | 179  | 180  | 181  | 182  | 183  | 185  | 187  | 189  | 192  | 194  |     |
|                      |                | Cariaw               | 131       | 61   | 63   | 65   | 67   | 68   | 69   | 70   | 69   | 68   | 68   | 71   | 74   | 76   | 78   |     |
|                      |                | Cecil                | 204       | 152  | 154  | 156  | 158  | 159  | 161  | 162  | 165  | 167  | 170  | 173  | 176  | 178  | 181  |     |
|                      |                | Charles              | 200       | 150  | 152  | 155  | 157  | 159  | 160  | 161  | 164  | 166  | 169  | 171  | 172  | 176  | 180  |     |
|                      |                | Dufferin             | 161       | 139  | 142  | 144  | 147  | 147  | 148  | 148  | 150  | 152  | 153  | 155  | 157  | 159  | 160  |     |
|                      |                | Duplex               | 121       | 103  | 105  | 107  | 109  | 110  | 111  | 112  | 114  | 116  | 118  | 121  | 123  | 125  | 127  |     |
|                      |                | Esplanade            | 177       | 169  | 170  | 172  | 173  | 176  | 178  | 180  | 185  | 190  | 195  | 200  | 206  | 210  | 215  |     |
|                      |                | Gerrard              | 62        | 44   | 45   | 46   | 47   | 48   | 49   | 50   | 62   | 77   | 87   | 89   | 91   | 92   | 93   |     |
|                      |                | Glengrove            | 84        | 52   | 53   | 55   | 56   | 57   | 57   | 58   | 59   | 60   | 61   | 62   | 64   | 64   | 65   |     |
|                      |                | Main                 | 72        | 59   | 59   | 58   | 57   | 58   | 59   | 60   | 60   | 60   | 61   | 64   | 67   | 69   | 71   |     |
|                      |                | Terauley             | 205       | 187  | 191  | 196  | 201  | 205  | 209  | 213  | 217  | 220  | 224  | 230  | 236  | 240  | 245  |     |
|                      |                | ManbyE115-13.8       | Wiltshire | 113  | 61   | 61   | 62   | 63   | 64   | 64   | 65   | 65   | 65   | 65   | 66   | 67   | 68   | 69  |
|                      |                | ManbyE115-27.6       | Runnymede | 109  | 96   | 98   | 99   | 101  | 101  | 102  | 102  | 103  | 105  | 106  | 107  | 109  | 110  | 110 |
|                      | Runnymede -LRT |                      | 0         | 0    | 0    | 0    | 0    | 0    | 0    | 14   | 18   | 23   | 26   | 26   | 26   | 26   | 26   |     |
|                      | ManbyW115      | Fairbank             | 176       | 174  | 177  | 179  | 183  | 184  | 185  | 186  | 188  | 191  | 193  | 195  | 197  | 199  | 201  |     |
|                      |                | Copeland             | 111       | 0    | 0    | 86   | 102  | 102  | 102  | 102  | 106  | 111  | 113  | 113  | 113  | 113  | 113  |     |
|                      |                | John                 | 246       | 267  | 266  | 179  | 179  | 182  | 185  | 188  | 191  | 195  | 199  | 202  | 206  | 210  | 213  |     |
|                      | Strachan       | Strachan             | 161       | 130  | 133  | 135  | 138  | 139  | 141  | 143  | 145  | 146  | 149  | 152  | 154  | 156  | 157  |     |
|                      |                | Central 115kV Total  | 2595      | 2067 | 2097 | 2128 | 2176 | 2198 | 2222 | 2259 | 2307 | 2359 | 2409 | 2453 | 2498 | 2536 | 2575 |     |
| Eastern 230kV        | CxL230         | Bermondsey           | 348       | 194  | 196  | 198  | 200  | 200  | 200  | 200  | 202  | 203  | 204  | 206  | 207  | 209  | 210  |     |
|                      |                | Ellesmere            | 189       | 154  | 155  | 157  | 159  | 159  | 159  | 159  | 160  | 161  | 162  | 163  | 164  | 166  | 167  |     |
|                      |                | Leaside              | 210       | 154  | 156  | 158  | 159  | 159  | 159  | 161  | 163  | 165  | 167  | 168  | 170  | 172  |      |     |
|                      |                | Scarboro             | 340       | 220  | 222  | 225  | 227  | 227  | 227  | 227  | 229  | 230  | 232  | 234  | 235  | 237  | 239  |     |
|                      |                | Sheppard             | 204       | 164  | 164  | 165  | 165  | 165  | 165  | 166  | 168  | 169  | 170  | 171  | 172  | 174  |      |     |
|                      |                | Warden               | 183       | 125  | 126  | 127  | 129  | 129  | 129  | 130  | 130  | 131  | 132  | 133  | 134  | 135  |      |     |
|                      | Metrolinx      | Metrolinx - Warden   | 0         | 0    | 0    | 0    | 0    | 0    | 40   | 60   | 80   | 80   | 80   | 80   | 80   | 80   |      |     |
| Eastern 230kV Total  | 1474           | 1010                 | 1020      | 1030 | 1040 | 1040 | 1080 | 1100 | 1128 | 1136 | 1144 | 1152 | 1160 | 1168 | 1176 |      |      |     |
| Northern 230kV       | CxR            | Agincourt            | 174       | 95   | 97   | 99   | 101  | 102  | 103  | 104  | 104  | 105  | 106  | 107  | 107  | 108  | 109  |     |
|                      |                | Bathurst             | 334       | 245  | 247  | 248  | 249  | 249  | 249  | 249  | 251  | 253  | 255  | 257  | 258  | 260  | 262  |     |
|                      |                | Cavanagh             | 157       | 119  | 119  | 119  | 120  | 120  | 120  | 120  | 120  | 121  | 122  | 123  | 124  | 125  | 126  |     |
|                      |                | Fairchild            | 357       | 256  | 257  | 259  | 260  | 260  | 260  | 260  | 262  | 264  | 266  | 268  | 270  | 272  | 273  |     |
|                      |                | Finch                | 363       | 273  | 276  | 278  | 281  | 281  | 281  | 281  | 283  | 285  | 287  | 289  | 291  | 293  | 295  |     |
|                      |                | Leslie               | 325       | 223  | 225  | 227  | 229  | 229  | 229  | 231  | 233  | 234  | 236  | 238  | 239  | 241  |      |     |
|                      |                | Malvern              | 176       | 106  | 106  | 106  | 107  | 107  | 107  | 107  | 108  | 108  | 109  | 110  | 111  | 111  | 112  |     |
| Northern 230kV Total | 1885           | 1317                 | 1327      | 1337 | 1347 | 1348 | 1349 | 1351 | 1360 | 1370 | 1379 | 1389 | 1399 | 1408 | 1418 |      |      |     |
| Western 230kV        | Manby230       | Horner               | 179       | 129  | 131  | 133  | 135  | 136  | 137  | 138  | 140  | 141  | 142  | 141  | 139  | 141  | 143  |     |
|                      |                | Manby                | 221       | 232  | 236  | 240  | 244  | 246  | 249  | 251  | 255  | 259  | 265  | 273  | 282  | 286  | 290  |     |
|                      | Metrolinx      | Metrolinx - Cityview | 0         | 0    | 0    | 0    | 0    | 0    | 40   | 60   | 80   | 80   | 80   | 80   | 80   | 80   | 80   |     |
|                      |                | Metrolinx - Mimico   | 0         | 0    | 0    | 0    | 0    | 0    | 40   | 60   | 80   | 80   | 80   | 80   | 80   | 80   |      |     |
|                      | Rich230        | Rexdale              | 187       | 133  | 133  | 133  | 133  | 132  | 131  | 130  | 131  | 132  | 133  | 134  | 135  | 136  | 137  |     |
|                      |                | Richview T1T2EZ      | 154       | 128  | 128  | 129  | 129  | 128  | 127  | 126  | 127  | 128  | 129  | 130  | 131  | 131  | 132  |     |
|                      |                | Richview T5T6JQ      | 188       | 107  | 107  | 108  | 108  | 107  | 106  | 106  | 106  | 107  | 108  | 109  | 109  | 110  | 111  |     |
| Richview T7T8BY      |                | 113                  | 52        | 52   | 52   | 52   | 52   | 51   | 51   | 51   | 52   | 52   | 53   | 53   | 53   | 54   |      |     |
| Western 230kV Total  | 1042           | 782                  | 788       | 794  | 801  | 801  | 881  | 921  | 970  | 979  | 988  | 998  | 1009 | 1018 | 1027 |      |      |     |
| Grand Total          | 6995           | 5176                 | 5232      | 5289 | 5363 | 5388 | 5532 | 5631 | 5765 | 5843 | 5920 | 5992 | 6066 | 6131 | 6196 |      |      |     |

## Appendix E. List of Acronyms

| Acronym | Description   |
|---------|---|
| A       | Ampere  |
| BES     | Bulk Electric System                                  |
| BPS     | Bulk Power System                                     |
| CDM     | Conservation and Demand Management                    |
| CIA     | Customer Impact Assessment                            |
| CGS     | Customer Generating Station                           |
| CTS     | Customer Transformer Station                          |
| DESN    | Dual Element Spot Network                             |
| DG      | Distributed Generation                                |
| DSC     | Distribution System Code                              |
| GS      | Generating Station                                    |
| GTA     | Greater Toronto Area                                  |
| HV      | High Voltage  |
| IESO    | Independent Electricity System Operator               |
| IRRP    | Integrated Regional Resource Plan                     |
| kV      | Kilovolt  |
| LDC     | Local Distribution Company                            |
| LP      | Local Plan  |
| LTE     | Long Term Emergency                                   |
| LTR     | Limited Time Rating                                   |
| LV      | Low Voltage   |
| MTS     | Municipal Transformer Station                         |
| MW      | Megawatt  |
| MVA     | Mega Volt-Ampere                                      |
| MVAR    | Mega Volt-Ampere Reactive                             |
| NA      | Needs Assessment                                      |
| NERC    | North American Electric Reliability Corporation       |
| NGS     | Nuclear Generating Station                            |
| NPCC    | Northeast Power Coordinating Council Inc.             |
| NUG     | Non-Utility Generator                                 |
| OEB     | Ontario Energy Board                                  |
| OPA     | Ontario Power Authority                               |
| ORTAC   | Ontario Resource and Transmission Assessment Criteria |
| PF      | Power Factor  |
| PPWG    | Planning Process Working Group                        |
| RIP     | Regional Infrastructure Plan                          |
| ROW     | Right-of-Way  |
| SA      | Scoping Assessment                                    |
| SIA     | System Impact Assessment                              |
| SPS     | Special Protection Scheme                             |
| SS      | Switching Station                                     |
| TS      | Transformer Station                                   |
| TSC     | Transmission System Code                              |
| UFLS    | Under Frequency Load Shedding                         |
| ULTC    | Under Load Tap Changer                                |
| UVLS    | Under Voltage Load Rejection Scheme                   |