



ALL DIMENSIONS IN CENTIMETRES  
UNLESS OTHERWISE STATED

PARTS LIST			
PART No.	MM No.	DESCRIPTION	QTY.
1	30008404	INSULATOR, DEAD-END, DS15 OR	1
	30008411	INSULATOR, DEAD-END, DS28	
2	30007010	CLAMP, CONDUCTOR, ANGLE	2
3	30001595	WASHER, 3/4" x 2" x 2"	2
4	MM#	BOLT, 3/4"	2
5	10000058	BOLT-EYE, FOR 3/4" BOLT	2
MM# = REFER TO SECTION 16 ONLY   A/R = AS REQUIRED			

02	MAY 2017	GENERAL UPDATES. CHANGED TO NEW DWG. & NUMBERING FORMAT. FOR PREVIOUS REVISIONS REFER TO DL3-103-R1.	SO	PC	MM	JB
01	AUG 2011	MM# ADDED	WB	PC		
Rev No.	Date	Revision Particulars	dwn	ckd	des	app

Drawn By: WB	Checked By: PC	Designed By:	Design Approved By:
Scale: N.T.S.	Date: (yyyy/mm/dd) 2011/08/25	Pole ID:	



Title:  
PRIMARY 1-PH LINE ANGLE 16° TO 60°  
1Ø, 2.4kV TO 16kV, MAX. SPAN 90m

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.  
Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

Drawing No. DL3-103-0500	Rev. No. 02
-----------------------------	----------------

TITLE BLOCK REV 02 - AUGUST 2014