



NOTES:

1. TYPICAL HOLE SPACING FROM 15cm CAN BE REDUCED TO 10cm FOR ATTACHMENT HOLES AT RIGHT ANGLE.

ALL DIMENSIONS IN CENTIMETRES UNLESS OTHERWISE STATED

PARTS LIST

PART No.	MM No.	DESCRIPTION	QTY.
1	30008404 30008411	INSULATOR, DEAD-END, DS15 OR INSULATOR, DEAD-END, DS28	2
2	30007338	CLEVIS BAIL, DEAD-END	4
3	30001595	WASHER, 3/4" x 2" x 2"	4
4	MM#	BOLT, 3/4"	4
5	MM#	CLAMP, CONDUCTOR, DEAD-END	A/R
6	MM#	GRIP, CONDUCTOR, PREFORMED, DEAD-END	4
7	MM#	CONNECTOR, TAP, WEDGE-TYPE	2
8	10000058	BOLT-EYE, FOR 3/4" BOLT	4

MM# = REFER TO SECTION 16 ONLY A/R = AS REQUIRED

03	JUNE 2022	ADDED SWING AWAY OPTION ALTERNATIVE TO DEAD-END CLEVIS/PREFORM CONNECTION AT NEUTRAL LEVEL.	PC	MM	SP	MM
02	MAY 2017	GENERAL UPDATES. CHANGED TO NEW DWG. & NUMBERING FORMAT. FOR PREVIOUS REVISION REFER TO DL3-104-R1. GENERAL UPDATES.	SO	PC	MM	JB
Rev No.	Date	Revision Particulars	dwn	ckd	des	app

Drawn By: WB	Checked By: PC	Designed By:	Design Approved By:
Scale: N.T.S.	Date: (yyyy/mm/dd) 2011/08/25	Pole ID:	



Hydro One Networks Inc.

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.
Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

PRIMARY 1-PH LINE ANGLE 61° TO 90°
1Ø, 2.4kV TO 16kV, MAX. SPAN 90m

Drawing No.
DL3-104-0500

Rev. No.
03

TITLE BLOCK REV 02 – AUGUST 2014