


ALL DIMENSIONS IN CENTIMETRES
UNLESS OTHERWISE STATED

PARTS LIST			
PART No.	MM No.	DESCRIPTION	QTY.
1	30008404 30008411	INSULATOR, DEAD-END, DS15 OR INSULATOR, DEAD-END, DS28	1
2	30007338	CLEVIS BAIL, DEAD-END	2
3	30001595	WASHER, 3/4" x 2" x 2"	2
4	MM#	BOLT, 3/4"	2
5	MM#	CLAMP, CONDUCTOR, DEAD-END	A/R
6	MM#	GRIP, CONDUCTOR, PREFORMED, DEAD-END	2
7	10000058	BOLT-EYE, FOR 3/4" BOLT	2
8	10000108	LOCKWASHER, 3/4"	2
MM# = REFER TO SECTION 16 ONLY A/R = AS REQUIRED			

04	FEB 2025	ADDED PART# 8.	PC	MM	AA	MM
03	JUNE 2022	ADDED SWING AWAY OPTION ALTERNATIVE TO DEAD-END CLEVIS/PREFORM CONNECTION AT NEUTRAL LEVEL.	PC	MM	SP	MM
Rev No.	Date	Revision Particulars	dwn	ckd	des	app

Drawn By: WB	Checked By: PC	Designed By:	Design Approved By:
Scale: N.T.S.	Date: (yyyy/mm/dd) 2011/08/25	Pole ID:	
Title: PRIMARY 1-PH DEAD-END 1Ø, 2.4kV TO 16kV, MAX. SPAN 90m			

**Hydro One Networks Inc.**

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.
Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

Drawing No. DL3-105-0500	Rev. No. 04
------------------------------------	-----------------------

TITLE BLOCK REV 02 - AUGUST 2014