


MINIMUM VERTICAL CLEARANCES
BETWEEN PHASE CONDUCTOR
AND SPAN GUY WHEN
SPAN GUY IS BELOW



MINIMUM VERTICAL CLEARANCES BETWEEN PHASE CONDUCTOR AND SPAN GUY WHEN SPAN GUY IS ABOVE




FIG.6

MINIMUM VERTICAL CLEARANCES
BETWEEN PHASE CONDUCTOR
AND NEUTRAL/SECONDARY

TABLE 1

MAXIMUM SPAN LENGTH (m)	MINIMUM SPACING BETWEEN SPAN GUY A NEUTRAL/BUS (cm)	
45	15	
60	20	
75	25	

FOR SHEET 1 OF THIS DRAWING SEE DL5-102-0500

ALL DIMENSIONS IN CENTIMETRES UNLESS OTHERWISE STATED

| OCT | OCT | OCT | 2022 | OCT | OCT

	Drawn By: GO	Checked By:	Designed By:	Design Approved By:
	Scale: N.T.S.	Date: (yyyy/mm/dd) 2010/06/10	Pole ID:	
Р	T'41	•	•	

hydro Gne

Hydro One Networks Inc.

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.

nformation contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

DL5-102-0501

50

SPAN AND ANCHOR GUY

03