

TIE CABLE TO POLE
WITH ROPE. CABLE TO BE
LONG ENOUGH TO REACH
OVERHEAD LINE TO WHICH
IT IS TO BE CONNECTED

GROUNDING INSTALLED
BY HYDRO ONE
PER O/H SECTION 12
SEE
NOTE 1

CABLE GUARD/CONDUIT
TO BE EXTENDED BY
HYDRO ONE WHEN THE CABLE
TERMINATION IS COMPLETED

PROVIDE PVC
CONDUIT/CABLE GUARD
PER U/G SECTION 8
AS APPLICABLE

~1200
TYP.

600

600

FINISHED GRADE

900

SEE
NOTE 2

GROUNDING PER
O/H SECTION 12

NOTES:

1. IF GROUNDING DOES NOT ALREADY EXIST WHEN CONTRACTOR PLACES CABLES, THEN IT SHALL BE INSTALLED BY CONTRACTOR.
2. RADIUS MUST BE GREATER THAN THE SPECIFIED CABLE MINIMUM BENDING RADIUS. LEAVE SOME SLACK TO ALLOW FOR GROUND SETTLEMENT.

ALL DIMENSIONS IN MILLIMETERS
UNLESS OTHERWISE STATED

03	SEP 2018	GENERAL UPDATES. REMOVED GROUND ROD DETAILS AND NOTE EDITS. CHANGED TO NEW DWG. & NUMBERING FORMAT. FOR PREVIOUS REVISIONS REFER TO DU-03-213-R2.	SO	PC	AS	PS
02	NOV 2011	DELETED CADWELDING & PARTS LIST	SO			
Rev No.	Date	Revision Particulars	dwn	ckd	des	app

Drawn By: S.O.	Checked By:	Designed By:	Design Approved By: D.THOMPSON
Scale: N.T.S.	Date: (yyyy/mm/dd) 2011/11/04	Pole ID:	



Hydro One Networks Inc.

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.

Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

TEMPORARY TERMINATION OF UNDERGROUND CABLE BY
CONTRACTOR FOR FUTURE CONNECTION
TO HYDRO ONE OVERHEAD LINE

Drawing No.

DU-03-213-0500

Rev. No.

03

A4 (210 x 297)

millimetres

0 10

50

Sheet Number: **1**