







NOTES:

- 1. ALL DIMENSIONS ARE IN mm UNLESS STATED OTHERWISE.
- 2. CHANNEL MUST BE FIELD DRILLED AND CUT TO LENGTH TO MATCH FOUNDATION OPENING.

REFERENCES:

SECTION 1 - DEFINITIONS
SECTION 3C - CONSTRUCTION GUIDE
SECTION 16 - MATERIALS
SECTION 14 - GROUNDING

dwn	ckd	des	арр

Rev	No.	Date	Revision Particulars			ckd	des	6
	ŀ	ıydı	.	Hydro One Network	(S	In	c.	

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.

nformation contained in this drawing is considered or its intended purpose and shall take necessary m

PARTS LIST				
PART No	MM No	DESC	RIPTION	QTY
1	30031724	BOLT, 1/2" X 1	1/2", GALV.	A/R
2	30001591	WASHER, ROUND,	1/2" GALV.	A/R
3	30002964	NUT, 1/2", W SPR	RING FOR CHANNEL	A/R
4	30002925	CHANNEL, $1-5/8$ "	X 1-5/8", GALV.	A/R
5	30024586	BOLT, SLEEVE AN	CHOR, 1/2" X 3"	2
6	30006394	CONNECTOR, SPLI	T BOLT, CU, 1/2"	1
7	30008041	SUPPORT, CABLE	TERMINATION	A/R
8	30008340	TAPE, BLACK PVC		A/R
A/R = AS REQUIR			RED	

Drawn By:	Checked By:	Designed By:	Design Approved By: G.YAMASHITA
LS	PC	K.SEYMOUR	
Scale: N.T.S.	Date: (yyyy/mm/dd) 07/03/2015	Pole ID:	

PRIMARY CABLE TERMINATIONS CABLE SUPPORT BRACKETS 350-1000 kcmil

Drawing No.	Rev. No
DU-04-504-0500	00

millimetres

 $A4 (210 \times 297)$

50