




FOUNDATION
TOP VIEW



CONCRETE BASE
TOP VIEW



FOUNDATION
FRONT VIEW



FOUNDATION
SIDE VIEW

NOTES:

1. APPROXIMATE MASS OF FOUNDATION IS 2065 kG.
2. CABLE ENTRY OPENINGS: PVC SEALS FOR 10cm (4") DUCTS.
3. 1/2" x 2" UNC PLASTIC THREADED INSERT.
4. 5cm (2") LIFTING HOLE OR SWIFT LIFT SYSTEM.
5. A CONCRETE BASE (PART #2) IS AVAILABLE FOR INSTALLATIONS IN SOIL WITH POOR BEARING CAPACITY.
6. IF ADDITIONAL PORTS ARE SUPPLIED, IT IS PERMITTED, BUT NOT REQUIRED. USE THE APPRICATE PORTS BASED ON THE MINIMUM COVERING REQUIREMENT.

PARTS LIST

| PART No. | MM No. | DESCRIPTION | QTY. |
|--------------------------------|----------|---|------|
| 1 | 30031403 | CONCRETE FOUNDATION – FOR CONVENTIONAL SINGLE PHASE TRANSF. – 48" DEEP, 48 PORTS OR | 1 |
| 2 | 30031405 | CONCRETE BASE – FOR CONVENTIONAL SINGLE PHASE TRANSFORMER | A/R |
| MM# = REFER TO SECTION 16 ONLY | | A/R = AS REQUIRED | |

ALL DIMENSIONS IN MILLIMETRES
UNLESS OTHERWISE STATED

| Rev No. | Date | Revision Particulars | dwn | ckd | des | app |
|---------|------|----------------------|-----|-----|-----|-----|
| | | | | | | |

| | | | |
|-------------------------|---|--------------------------------|--|
| Drawn By: PC | Checked By: M.MATEVSKI | Designed By: X.ZHANG | Design Approved By: M.MATEVSKI |
| Scale: N.T.S. | Date: (yyyy/mm/dd) 2021/10/18 | Pole ID: | |



© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.
Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

**TYPICAL CONCRETE FOUNDATION
CONVENTIONAL 1-PH PAD-MOUNTED TRANSFORMER
48" DEEP FOUNDATION**

Drawing No.
DU-09-201.1-0500

Rev. No.
00