


1. ALL DIMENSIONS ARE IN mm UNLESS STATED OTHERWISE.
2. CONCRETE 28 DAY STRENGTH TO BE 20MPa. MINIMUM HEIGHT TO BE 150mm. THICKNESS MAY VARY DUE TO TERRAIN.
3. CABLE SLEEVES TO BE PVC DUCT CUT FLUSH WITH THE FACE OF THE CONCRETE PAD. UNUSED SLEEVES TO BE SEALED WITH PVC PLUGS OR CONCRETE.
4. POSITION AND NUMBER OF PVC SLEEVES AS REQUIRED. 150mm MINIMUM SEPARATION.

PARTS LIST			
PART No.	MM No.	DESCRIPTION	QTY.
1	30011213	ALUMINUM BASE — 25kVA FOR MICROPAD TRANSFORMER	A/R
MM# = REFER TO SECTION 16 ONLY A/R = AS REQUIRED			

					 <b>Hydro One Networks Inc.</b>		
*	*	*	*	*			
Rev. No.	Issue Date	Revision	Dwn	Approved By	Drawn: S.OORT	Approved: *	Date: JUN.19,2014
			Chk	Date	ALUMINUM BASE - MICROPAD TRANSFORMER		
<p>© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.</p> <p>Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its Intended purpose and shall take necessary measures to prevent disclosure or transmission to outside parties.</p>					Dwg. No. DU-09-601	Rev. 00	