

NOTES:

- KEEP SIGNS AS HIGH AS POSSIBLE ON THE POST FOR VISIBILITY.
 MARKER POST AND SIGNS TO BE LOCATED AS CLOSE TO THE CABLE ENTRY POINT AS PRACTICABLE.
- 2. INSTALL TWO (2) PLATES BACK TO BACK.
- 3. LOCATE PEDESTAL BASE APPROXIMATELY IN THE CENTRE OF THE CONCRETE FOOTING. FOUR (4) BAGS OF CONCRETE (OR EQUIVALENT) ARE REQUIRED TO POUR THE FOOTING.
- 4. LOCATE BASE OF POST WITHIN 1m OF PRIMARY CABLE(S) AND AVOID DAMAGE TO CABLE CONDUIT(S).
- 5. BUILD A MOUND OF CONCRETE SIMILAR TO THE SHAPE SHOWN USING THREE (3) BAGS OF CONCRETE (OR EQUIVALENT). ENSURE ROCK SURFACE IS FREE OF LOOSE DEBRIS OR VEGETATION PRIOR TO APPLYING THE CONCRETE.

PARTS LIST								
PART No.	MM No.	DESCRIPTION						
1	10000425	SIGN, STEEL STAKE, U/G CABLE, 1-1/2" PIPE x 60", 6" x 4" SUPPORT						
2	30024552	SIGN, "WARNING STAY CLEAR — HIGH VOLTAG CABLE", AL, 34cm x 45cm						
		U BOLT, 3/8", WITH WASHER & NUT	2					
4 30035711 CONCRETE								
MM#	= REFER	TO SECTION 16 ONLY A/R = AS REQUIRED						

ALL DIMENSIONS IN CENTIMETRES UNLESS OTHERWISE STATED

							_
01	SEPT 2023	ORIGINAL DU-06-401-R2 AND DU-06-401A-R2 ARE NOW SUPERSEDED BY THIS NEW DRAWING/REVISION. CHANGED TO SECTION 2. GENERAL UPDATES TO NEW DRAWING & NUMBERING FORMAT.	PC	ММ	SJ	ММ	
Rev No.	Date	Revision Particulars		ckd	des	арр	ŀ

ММ	Drawn By: PC	Checked By: M.MATEVSKI		Design Approved By: M.MATEVSKI P.Eng.
	N.T.S.	Date: (yyyy/mm/dd) 2020/04/22	Pole ID: PC	
nnr				

SUBMARINE CABLE "WARNING" SIGN INSTALLATION

hydro G

Hydro One Networks Inc.

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.

information contained in this drawing is considered to be confidential. Recipients shall only use the drawing or its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

millimetres

DU2-131-0500

50

Rev. No.

 $A4 (210 \times 297)$

10

Sheet Number: