

**NOTES:**

1. GROUND CT SECONDARY AT TEST SWITCH.
2. REFER TO SECTION RM-16 FOR WIRE INFORMATION.
3. USE GROUNDING STUD FOR CT SECONDARY GROUNDING FROM TEST SWITCH.
4. SECONDARY CONDUCTORS SHALL USE TIE WRAPS FOR WIRE MANAGEMENT AND HELD BELOW PRIMARY CONDUCTORS OR BAR TYPE CTS WHERE SHOWN.
5. FRONT PANEL COVER TO INCLUDE WARNING LABEL "NOT EQUIPPED WITH AUTO SHORTING DEVICE".
6. LINE SIDE TERMINATION: DOUBLE 1/2" STUDS TO ACCOMMODATE COMPRESSION LUGS FOR UNDERGROUND SERVICE. (MAXIMUM 500MCM SINGLE OR 250MCM PARALLEL RUN).  
250MCM COMPRESSION LUG: 30006405  
500MCM COMPRESSION LUG: 30032559

01	DEC 2021	ORIGINAL RM7-203-0500 NOW SUPERSEDED BY THIS NEW DRAWING/REVISION.	PC	MK	MK	MK
Rev. No.	Date	Revision Particulars	dwn	ckd	des	app

**Hydro One Networks Inc.**

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.

Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

Drawn By: <b>PC</b>	Checked By: <b>M.SKRELA</b>	Designed By: <b>M.SKRELA</b>	Design Approved By: <b>M.SKRELA</b>
Scale: <b>N.T.S.</b>	Date: (yyyy/mm/dd) <b>2021/012/08</b>	Pole ID:	

Title:  
**U/G INTEGRATED METER-BASE, 1 X 3W BAR CT 1PH, 3W, 120/240V, CONSTRUCTION CWD UP TO 400A, FULL MULTIPLIER**

Drawing No.

**RM7-303-0500**

Rev. No.

**01**

A4 (210 x 297)

millimetres

0 10

50

Sheet Number:

/