



NOTES:

1. GROUND CT SECONDARY AT TEST SWITCH.
2. REFER TO RM-16 FOR WIRE INFORMATION.
3. GROUNDING STUD, USE FOR CT SECONDARY GROUNDING FROM TEST SWITCH.
4. USE TIE WRAPS FOR WIRE MANAGEMENT.
5. FRONT PANEL COVER TO INCLUDE WARNING LABEL "NOT EQUIPPED WITH AUTO SHORTING DEVICE"
6. CT SHORTING LINK LOCATION MAY VARY BY MANUFACTURER. REFER TO D2 INSERT.
7. ENSURE METER ENCLOSURE IS LOCKED USING A PADLOCK AND METER SEAL.
8. IF CONTRACTOR INSTALLS OWN GROUND BONDING WIRE AT METER-BASE, REMOVE WIRE AND FILL WITH KNOCK-OUT FILLER.
9. PAD-MOUNT CONFIGURATION SHOWN. IF OVER-HEAD OPTION IS USED ROUTE CABLE BUNDLE AND G10 THROUGH TOP FITTING
10. FOR 10 POSITION TEST SWITCH REFER TO INSERT D1. 10 POSITION METER-BASE REQUIRES A LARGER MOUNTING BRACKET WHICH IS SUPPLIED BY THE VENDOR.

TITLE BLOCK REV 02 - AUGUST 2014

01	DEC 2021	ORIGINAL RM7-19C-0500 NOW SUPERSEDED BY THIS NEW DRAWING/REVISION.	PC	MK	MK	MK
Rev. No.	Date	Revision Particulars	dwn	ckd	des	app

hydro one **Hydro One Networks Inc.**

© Copyright Hydro One Networks Inc. All rights reserved. This drawing may not be reproduced or copied, in whole or in part, in any printed, mechanical, electronic, film, or other distribution and storage media or used in any information storage or retrieval system outside of Hydro One Networks Inc., without the written consent of Hydro One Networks Inc.

Information contained in this drawing is considered to be confidential. Recipients shall only use the drawing for its intended purpose and shall take necessary measures to prevent disclosure or transmittal to outside parties.

Drawn By: PC	Checked By: M.SKRELA	Designed By: M.SKRELA	Design Approved By: M.SKRELA
------------------------	--------------------------------	---------------------------------	--

Scale: N.T.S.	Date: (yyyy/mm/dd) 2021/12/08	Pole ID:
-------------------------	---	----------

Title:
**SOCKET METER-BASE ENCLOSURE
1PH, 3W, 120/240V, CONSTRUCTION CWD**

Drawing No. **RM7-309-0500**

Rev. No. **01**