

# Declaration of Commissioning Compliance

(For projects that meet Hydro One's Simplified Small Projects requirements)



Hydro One Project ID#:

To Whom it May Concern,

The customer and their professional engineer (P.Eng.) acknowledge the following:

- Customer connection meets the threshold of Simplified Small Projects
- Facility is designed as outlined in the current Hydro One Distributed Generation Technical Interconnection Requirements – Interconnections at Voltages 50kV and Below (TIR) and applicable bulletins
- Commissioning the facility and documentation of the commissioning test results must meet Hydro One's TIR Section 2.9.2 and 2.9.3
- The "as-built" facility is consistent with the most recently submitted, reviewed, and accepted documents with Hydro One, including, but not limited to single line diagram, Simplified CIA application.
- The distributed energy resource (DER) facility design and operation meets the minimum standards for DER facilities connected to a distribution system, as per the Distribution System Code.
- The equipment and installation meet CSA and/or other applicable electrical safety standards.
- Electrical Safety Authority (ESA) has issued a Grid Connection Authorization (Code Article 2-012), and the document has been submitted to Hydro One.
- A Hydro One representative has witnessed operation of the disconnect switch being used to meet Hydro One's TIR Section 2.1.7 and the DER Disconnect Switch Witness Confirmation form has been submitted
- Where an inverter(s) is used, the following have been submitted:
  - Manufacturer Certificate of Compliance (demonstrating compliance with CSA 22.3 No. 9-2020; or CSA 22.2 No. 107.1 and marked compliant to UL1741SA or UL1741SB or later) by an accredited certification or evaluation agency
  - Manufacturer Inverter Derating Letter (for derated inverters)
  - For projects using multiple three-phase inverters or multiple single-phase inverters, compliance with TIR Section 2.3.6 (iii) is demonstrated through a manufacturer letter of compliance (submitted to Hydro One) or customer field testing
- Customer must retain the documentation of commissioning test results for a period of seven (7) years.

Sincerely,

Date:

**P. Eng. Stamp**

(Please include date and signature)