

SLD CHECKLIST I The legal name of the facility owner, facility address/location, project purpose, Hydro One assigned project ID, and revision history should be included in the title block . See attached table for remaining important items. Image: Note, please do not include the hex markers on the official SLD submitted to Hydro One Networks. They are shown here for illustration only

NOTES:

 Colour code of the revenue metering instrument transformers secondary wiring shall match the overhead phase conductors
 Compliant with Settlements & Revenue Metering SLD Requirements Revision 1.5.1

DISCLAIMER: This sample SLD is intended to be informative. It is intended to illustrate some of the information that must be shown on the SLD submitted to HONI. All design decisions must be made by the proponent and meet the minimum requirement set forth in the TIR. The proponent is expected to design their facility to meet the minimum requirements of the Hydro One Micro TIR. It is the responsibility of the proponent to ensure that any other applicable regulations and design standards are followed.

01	Re	vised as per	r HONI comments			18/11/2020		
00		Initial SLD fo	or HONI review			13/07/2020		
NO		REVISI	ON/ISS)N/ISSUE			DATE	
PROJE	ст:	Customer N Customer A Customer A Project Pur HONI Proje Other Info	ustomer Name ustomer Address Line 1 ustomer Address Line 2 roject Purpose IONI Project ID: #12,345 Other Info					
ABC Inc. LOGO		ABC Inc.						
DWG NAME: MicroDER with Emergency Backup Gen Sample SLD						eration		
DATE: YYYY/MM/DD			DRAWN:		СН	CHECKED:		
	2025/02	./23 S.H		lughes		A. Chowdury		
DWG NO:			SHEET NO		NO:	REV N	۱0:	
DG12345			D	1 of 1		01		