

**HYDROGEOLOGIC & HYDROLOGIC  
ASSESSMENT REPORT  
CLARINGTON TRANSFORMER  
STATION**



Prepared for:  
Hydro One Networks Inc.  
483 Bay Street  
South Tower, 4th Floor  
Toronto, ON M5G 2P5

Prepared by:  
Stantec Consulting Ltd.  
300 – 675 Cochrane Drive  
Markham, ON L3R 0B8

Project No.:160900764  
March 10, 2014

# Sign-off Sheet

This document entitled HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION was prepared by Stantec Consulting Ltd. for the account of Hydro One Networks Inc. The material in it reflects Stantec's best judgment in light of the information available to it at the time of preparation. Any use which a third party makes of this report, or any reliance on or decisions made based on it, are the responsibilities of such third parties. Stantec Consulting Ltd. accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

## HYDROGEOLOGICAL COMPONENTS

Prepared by  original signed and stamped  
(signature)

**Angela Ducharme, B.Sc., EPT**  
**Environmental Scientist**

Reviewed by  original signed and stamped  
(signature)

**Lesley Veale, M.Sc., P.Geo**  
**Hydrogeologist**

Reviewed by  original signed and stamped  
(signature)

**J. Brant Gill, H.B.Sc., P.Geo.**  
**Senior Hydrogeologist**

## HYDROLOGIC COMPONENTS

Prepared by  original signed and stamped  
(signature)

**Trevor Fraser, B.Eng.**  
**Water Resources EIT**

Reviewed by  original signed and stamped  
(signature)

**Scott Robertson, P.Eng.**  
**Associate, Water Resources Project Manager**

**HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT  
CLARINGTON TRANSFORMER STATION**

**Table of Contents**

**1.0 INTRODUCTION .....1.1**

1.1 PROJECT AREA ..... 1.1

1.2 OBJECTIVES..... 1.2

1.3 REPORT FORMAT ..... 1.2

**2.0 SETTING.....2.1**

2.1 GENERAL ENVIRONMENTAL FEATURES ..... 2.1

2.2 PHYSIOGRAPHY ..... 2.1

    2.2.1 Oak Ridges Moraine ..... 2.1

2.3 GEOLOGY / HYDROGEOLOGY ..... 2.2

    2.3.1 Bedrock..... 2.2

    2.3.2 Surficial Geology..... 2.2

    2.3.3 Overburden Stratigraphy ..... 2.3

    2.3.4 Groundwater Levels ..... 2.5

    2.3.5 Aquifer Vulnerability and Groundwater Recharge ..... 2.6

    2.3.6 Summary ..... 2.7

2.4 HYDROLOGY ..... 2.8

    2.4.1 Hydrologic Model Development ..... 2.9

**3.0 SITE DEVELOPMENT AND IMPACT ASSESSMENT .....3.1**

3.1 HYDROGEOLOGY ..... 3.2

3.2 HYDROLOGY ..... 3.3

**4.0 GROUNDWATER AND SURFACE WATER MONITORING PROGRAM .....4.1**

4.1 OBJECTIVES..... 4.1

4.2 MONITORING PROGRAM SCOPE ..... 4.1

4.3 MONITORING INSTALLATIONS..... 4.2

    4.3.1 Site Monitoring Wells..... 4.3

    4.3.2 Private Well Monitoring ..... 4.4

4.4 SURFACE WATER MONITORING ..... 4.5

4.5 WATER QUALITY ANALYSES ..... 4.5

4.6 MONITORING SCHEDULE..... 4.5

4.7 REPORTING ..... 4.6

**5.0 CONCLUSIONS AND RECOMMENDATIONS.....5.1**

**6.0 REFERENCES.....6.1**

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

## LIST OF TABLES

Table 1	Design Rainfall Parameters for Burketon McLaughlin Gauge .....	2.9
Table 2	Existing Conditions Hydrologic Model Results.....	2.10
Table 3	Monitoring Schedule .....	4.6

## LIST OF APPENDICES

<b>APPENDIX A</b>	<b>FIGURES .....</b>	<b>A.1</b>
<b>APPENDIX B</b>	<b>BOREHOLE LOGS.....</b>	<b>B.1</b>
<b>APPENDIX C</b>	<b>WATER WELL RECORDS .....</b>	<b>C.1</b>
<b>APPENDIX D</b>	<b>HYDROLOGY .....</b>	<b>D.1</b>

## LIST OF FIGURES

Figure 1	Site Location
Figure 2	Site Plan
Figure 3	Schematic of Oak Ridges Moraine
Figure 4	Regional Surficial Geology
Figure 5	Project Surficial Geology
Figure 6	Cross-Section A-A'
Figure 7	Cross-Section B-B'
Figure 8	Drainage Catchments and At-Surface Soils
Figure 9	Drainage Catchments and Aerial Imagery
Figure 10	Groundwater and Surface Water Monitoring Locations



# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Introduction  
March 10, 2014

## 1.0 Introduction

---

Stantec Consulting Ltd. (Stantec) was retained by Hydro One Networks Inc. (Hydro One) to complete a hydrogeologic and hydrologic assessment related to the development of the 500-230 kV Clarington auto-transformer Station on the Hydro One property ('*Project Area*') located in the Regional Municipality of Durham, in the Municipality of Clarington, on Part Lots 33, 34, and 35, Concession Road #7. The *Project Area* and the extents of the transformer station itself, hereinafter referred to as the '*Site*', are shown on Figures 1 and 2 in Appendix A.

This hydrogeologic and hydrologic assessment involved a review and consolidation of available literature and technical information for the *Project Area* that was collected during the Class EA process; including three (3) geotechnical investigations completed within the *Project Area*. This report also addresses the request by the Central Lake Ontario Conservation Authority (CLOCA) for a consolidated hydrogeologic and hydrologic assessment report of the *Project Area*.

Some of the information presented in this Hydrogeologic and Hydrologic Assessment Report has been summarized and included in the Project's Class EA Environmental Study Report (ESR) that was filed with the MOE in January 2014.

### 1.1 PROJECT AREA

The *Project Area* comprises a total area of approximately 63 ha, which includes the smaller limits of the '*Site*'. The *Site* encompasses approximately 17 ha within which grading will occur and drainage infrastructure and transformers will be installed, and is entirely located within the *Project Area* (Appendix A, Figure 2).

The extent of the area considered in this assessment includes the *Project Area* described above, and relies on the reports of detailed geotechnical investigations completed within the limits of the *Project Area*. However, because of the regional scale of some of the natural environment features that are identified within and in relative proximity to the *Project Area*, this assessment considers the form and function of these specific key regional features as well. As a result, the natural environment features discussed throughout this report are of both regional and local importance, as they specifically relate to the hydrogeology and hydrology of the *Project Area*. As such, fixed boundaries defining the lateral limits of this assessment are not shown on any figures appended to this report.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Introduction  
March 10, 2014

## 1.2 OBJECTIVES

The objective of the following hydrogeologic and hydrologic assessment report prepared by Stantec is to with the following key objectives:

1. Compile the hydrogeologic and hydrologic data collected during the Class EA process, as requested by CLOCA;
2. Provide a technical summary of current geologic/hydrogeologic and hydrologic conditions across the Project Area and related surroundings that were established during the Class EA process; and,
3. Summarize previous assessments, based on the available information assessed, regarding whether the natural function of hydrogeologic and hydrologic features within the *Project Area* would be adversely impacted by the development, and assess potential adverse impacts to human and natural environment receptors. In the event that adverse impacts are anticipated, recommend mitigative strategies.

## 1.3 REPORT FORMAT

The following report is arranged into six (6) sections, including this introduction. Section 2 provides a description of geologic, hydrogeologic, and hydrologic conditions that characterize the *Project Area* and the *Site*, with Section 3 presenting the *Site* development activities and an assessment of potential hydrogeologic and hydrologic impacts. Section 4 presents the recommended groundwater and surface water monitoring program. Section 5 provides the conclusions and recommendations of the report, while Section 6 provides a list of references. All figures referenced in this report are presented in Appendix A. Borehole Logs and nearby Ministry of the Environment (MOE) Water Well Records (WWR) are presented in Appendices B and C, respectively. Supporting information related to hydrologic analyses is included within Appendix D.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Setting  
March 10, 2014

## 2.0 Setting

---

### 2.1 GENERAL ENVIRONMENTAL FEATURES

The Project Area falls within the planning area of the Region of Durham and the Municipality of Clarington, Part Lots 33, 34 and 35, Concession 7 (Figure 2). The upper tier regional plan identifies the *Project Area* as Countryside Area, and Natural Linkage Area and Natural Heritage Systems as per the Oak Ridges Moraine Conservation Plan (ORMCP) (Ministry of Municipal Affairs and Housing (MMAH), 2002) and Greenbelt Plan (MMAH, 2005) and also designates the *Project Area* as Prime Agricultural land.

Land throughout the *Project Area* is hilly but generally slopes from north to south. Within the *Project Area*, land predominantly slopes from northeast to southwest, directing surface runoff toward the watercourses at the western and southern portions of the Project Area. Ground surface elevation within the *Project Area* ranges from 235 m above mean sea level (AMSL) to 270 m AMSL.

### 2.2 PHYSIOGRAPHY

On a regional scale, the *Project Area* is occupied by the physiographic region defined by Chapman and Putnam (1984) as the South Slope, characterized by till plains with long, thin drumlins pointing upslope. The core of the Oak Ridges Moraine physiographic region is located approximately 6 km to the north of the *Project Area*. Recent planning mapping and land use characterization indicates that the *Project Area* is located within the southern edge of the of the Oak Ridges Moraine administrative planning boundary (Figure 1). In the vicinity of the *Project Area*, the Oak Ridges Moraine administrative planning boundary is delineated approximately by the 245 m elevation contour interval, rather than by site-specific geologic or hydrogeologic characteristics.

#### 2.2.1 Oak Ridges Moraine

The Oak Ridges Moraine is a terminal moraine composed mainly of sands and gravels, with till layers present throughout the moraine. The Oak Ridges Moraine covers an area of 1,900 km<sup>2</sup> and extends from approximately Caledon, Ontario to north of Cobourg, Ontario and forms a regional topographic high. The Oak Ridges Moraine consists of quaternary deposits up to 200 m thick, grouped into the following five (5) general classifications as generally described by Geological Survey of Canada (2001) and presented from oldest to youngest:

- Lower Deposits which directly overlie the bedrock and consist of interbedded layers of sand, silt, clay and till material. These deposits include the Thorncliffe Formation, Sunnybrook/Port Hope Till, Scarborough Formation, Don Formation, York Till and lower sediments;
- Newmarket Till described as a sandy till with some gravel extending up to 50 m in thickness;

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Setting

March 10, 2014

- A regional unconformity that forms the upper drumlinized and channelized surface of the Newmarket Till. Tunnel channels oriented in a north–northeast to south-southwest direction extend through the Newmarket Till and may extend to the bedrock. The channels may be 10's of km long, < 4 km wide and up to 150 m deep. The channels primarily contain sandy sediments related to the Oak Ridges Moraine sediment but may also contain gravel material;
- Oakridge's Moraine Sediments described as interbedded silt and fine sand with local sandy gravel material; and,
- Halton Till or Kettleby Till overly portions of the Oak Ridge's Moraine and are predominantly composed of clayey silt to silt till with interbedded sand and silt material.

Groundwater recharge occurs within the surficial sand and gravel deposits of the Oakridge's Moraine Sediments and is discharged within seeps and springs toward the lower slopes of the moraine.

An interpretive schematic of the Oak Ridges Moraine is presented on Figure 3. As shown on the figure, the core of the moraine is largely the result of glaciofluvial deposition; the flanks of the moraine reflect glaciolacustrine sedimentation and till deposits. The *Project Area* is located on the southern extent of the moraine as shown on Figure 4. As previously discussed, the *Project Area* is located within the Oak Ridges Moraine administrative planning boundary; however, the *Project Area* is approximately 5 km south of where Oak Ridge's Moraine Sediments are exposed at ground surface, and approximately 6 km south of the core deposits.

### 2.3 GEOLOGY / HYDROGEOLOGY

The following sections detail the geology and hydrogeology within both the study area and the *Project Area*.

#### 2.3.1 Bedrock

The bedrock underlying the *Project Area* consists of the Upper Ordovician Blue Mountain Formation (OGS, 1991) composed of blue grey non-calcareous shales. The top of bedrock occurs at an elevation of 60 m to 70 m AMSL at the Lake Ontario shoreline to 150 m AMSL at the topographic highs of the Oak Ridges Moraine (Singer et al., 2003). As previous stated, ground surface elevation within the *Project Area* ranges from 235 m AMSL to 270 m AMSL and bedrock will not be a factor for the development.

#### 2.3.2 Surficial Geology

Surficial geology mapping, shown in Figures 4 and 5, presents the regional-scale surficial geology with respect to the Oak Ridges Moraine as well as the local-scale surficial geology within the *Project Area*, respectively.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Setting  
March 10, 2014

The regional surficial geology mapping indicates that the coarse sand and gravel material associated with the core groundwater recharge zone within the Oak Ridges Moraine is located approximately 6 km north of the *Project Area* (Figure 4). The *Project Area* is located along the southern flank of the Oak Ridges Moraine, with surficial deposits primarily mapped as Newmarket Till, a silty to sandy till (Figure 5). Intermittent deposits of Halton Till, a silty to clayey till, were noted within the *Project Area* as well as modern alluvial deposits associated with local watercourses.

### 2.3.3 Overburden Stratigraphy

A review of nearby MOE WWR in the local study area (Figure 2) indicated that the overburden is primarily reported as stony clay material extending from near surface up to 104 m below ground surface (BGS) (160 m AMSL). Bedrock was not encountered at any of the nearby MOE WWR locations. MOE WWR indicated intermittent water-bearing sand and gravel lenses at various depths within the overburden, with the lenses ranging between 0.3 m and 5.8 m thick.

As previously stated, the topography within the *Project Area* is hilly. For ease of evaluation and comparison of MOE WWR data, the water level and stratigraphic data are presented as elevation (m AMSL) to account for changes in topography. When appropriate for discussion, the data are also presented as depth (m BGS).

There are twenty (20) MOE WWR located within 500 m of the *Project Area* installed to total depths of between 5.2 m and 108 m BGS. For ease of discussion in the report, the wells are grouped together based on depth. This grouping is for discussion purposes only, and is not interpreted to be representative of specific aquifers, but rather wells that are completed within sandy material at similar elevations. The noted well groups are as follows:

- Three (3) shallow wells completed at total elevations of 241 m AMSL to 248 m AMSL (depths of 5 m BGS to 14 m BGS). These wells are interpreted to be installed within discrete intermittent sand and gravel lenses up to 0.6 m thick with no significant continuous aquifer noted. These wells include MOE Well Record Nos. 1909285 and 1904535, located to the northeast of the *Project Area*; and Well No. 7128981, located south of the *Project Area* (Figure 2). The reported well installation details were as follows:
  - Well No. 1909285 – Clay to sandy clay material to 13.7 m BGS underlain by sand to 14.3 m BGS (246.1 m AMSL);
  - Well No. 1904535 – Stony clay material to 5.2 m BGS (245.4 m AMSL) with a gravel lens at 2.4 to 2.7 m BGS; and,
  - Well No. 7128981 – Sandy clay, silt and silty clay to 11.4 m BGS (240.5 m AMSL).
- Eight (8) intermediate wells completed at total elevations of 204 m AMSL to 226 m AMSL (depths of 8 m BGS to 22 m BGS). The overburden material was primarily described as clayey material overlying a screened aquifer material. The aquifer material is interpreted as a discrete intermittent sand and gravel lens(es), with no significant continuous intermediate aquifer noted across the *Project Area*; and,

## HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Setting  
March 10, 2014

- Nine (9) deep wells completed at total elevations of 160 m AMSL to 189 m AMSL (depths of 49 m BGS to 108 m BGS). The overburden was primarily described as clayey material overlying the screened aquifer material. The available water well records in the area are not adequate to confirm the presence of a continuous aquifer; however, based on regional interpretation, these deep wells may be intersecting the upper portion of the Thorncliffe Formation.

Cross Section A-A' (Figure 6) presents the interpreted overburden stratigraphy across the *Project Area*; indicating the predominant till or aquitard material throughout the majority of the overburden, with intermittent sand and gravel deposits at various depths. The locations of nearby private wells are also shown on the cross-section; including examples of nearby off-site shallow, intermediate, and deep private wells.

Reports of geotechnical investigations completed within the *Project Area* to further characterize the shallow stratigraphy were reviewed, including Geo-Canada Ltd. (2007), exp (2012), and Inspec-Sol (2013). These geotechnical investigations included drilling numerous boreholes and installing four (4) monitoring wells across the *Project Area*. The geotechnical borehole and monitoring well locations are shown on Figure 2.

In 2007, Geo-Canada Ltd. completed a geotechnical investigation within the general *Project Area*. The report indicated that the overburden material within the northeast portion of the *development area* was characterized by 5.5 m of sandy silt till, overlying 2.8 m of very dense, saturated silty fine sand/fine sandy silt, followed by 5.7 m of sandy silt till to the depth of the borehole (Stantec, 2008).

More recently, geotechnical boreholes and monitoring wells were completed throughout the *Project Area* to document shallow overburden conditions (exp, 2012; Inspec-Sol, 2013). A total of twenty-nine (29) boreholes were advanced within the *Project Area* to depths between 11 m BGS and 16 m BGS, with total depths ranging in elevation from 228 m AMSL to 245 m AMSL. A total of four (4) boreholes were completed as monitoring wells, including BH7A, BH2-12, BH4-12 and BH11-12 (Figure 2). Borehole logs indicate sandy silt till as the dominant stratigraphic unit across the *Project Area* within the depth of investigation, with occasional intermittent lenses of silty sand material, typically between 0.5 m and 3 m thick.

The borehole logs were consistent with conditions presented by MOE WWR and Ontario Geological Survey (OGS) mapping. The interpreted shallow stratigraphy within the *Project Area* is shown in the cross sections presented on Figures 6 and 7. The figures were compiled using stratigraphic data from boreholes, monitoring wells, and nearby MOE WWR, and present both shallow and deep geological stratigraphy. The shallow overburden material within the *Project Area* is predominantly composed of relatively low permeability dense Newmarket Till (silt till) with discrete layers of silty sand, clayey silt, and sand and gravel material.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Setting  
March 10, 2014

### 2.3.4 Groundwater Levels

Groundwater elevations within the *Project Area* were evaluated based on data from nearby MOE WWR and available monitoring wells. For the nearby MOE WWR, the following groundwater levels were presented on the original well logs recorded between 1954 to 2010:

- Three (3) shallow wells indicated static groundwater levels of 2.1 m to 2.4 m BGS (248.1 m AMSL to 258.3 m AMSL);
- Eight (8) intermediate wells indicated static groundwater levels of 5.5 m to 9.1 m BGS (218 m AMSL to 234 m AMSL); and,
- Nine (9) deep wells indicated static groundwater levels of 19 m to 49 m BGS (204 m AMSL to 222 m AMSL).

As described in Section 2.3.3, the nearby shallow and intermediate depth wells are all completed within intermittent silty sand, and sand and gravel material. Some of the deep wells may be installed within the top of the Thornccliffe Formation. The available water level data generally indicates a vertical hydraulic stratification within the *Project Area* with downward gradient within the overburden material. Downward flow is controlled and restricted by the fine textured, low permeability Newmarket Till, as such, minimal groundwater recharge is expected.

Permeability is the ability of the material to allow water to flow through it. A high permeability material, such as sand and gravel, acts as an aquifer allowing water to easily flow through the material. A low permeability material, such as clay or silt till (as is the Newmarket Till), acts as an aquitard, impeding the flow of groundwater. This low permeable till material within the *Project Area* extends from ground surface up to at least 104 m BGS (160 m AMSL), with intermittent discrete water bearing silty sand and gravel lenses.

Groundwater levels were also measured in open boreholes and monitoring wells as part of the drilling activities completed by exp and Inspec-Sol. Groundwater levels measured in open boreholes during drilling operations may not have yet equilibrated, and may not be representative of static conditions. For example, borehole BH2-12 was completed within silt till material and a water level of 14.85 m BGS was noted within the borehole immediately following drilling. A monitoring well was then installed within this borehole and the well was allowed to equilibrate. A static groundwater level of 0.16 m BGS was measured 5 days after well installation. Based on this potential underestimate of groundwater levels based on data from the open boreholes, groundwater levels from the open boreholes are only presented on the borehole logs in Appendix B but are not discussed in this report.



# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Setting  
March 10, 2014

Groundwater levels were measured at the four (4) monitoring wells within the *Project Area* by exp (May 2012, Inspec-Sol (November 2012), and Stantec (September and December 2013) with the following results:

- The monitoring well at BH11-12 was screened across silt and sand material at 13.7 m BGS to 14.8 m BGS. Artesian conditions were noted at BH11-12 with the groundwater level ranging from 0.9 m above ground surface (AGS) in November 2012 and December 2013 to 0.3 m below ground surface in September 2013 (254.5 m to 253.3 m AMSL). This level indicates the groundwater level or pressure within the screened silt and sand material, and does not necessarily indicate that water is naturally discharging at ground surface at this specific location;
- Groundwater levels recorded at BH7A varied between 1.4 m BGS in December 2013 and 2.4 m BGS in May 2012 and September 2013 (251.8 to 250.8 m AMSL) and indicate potential seasonal fluctuations in groundwater levels at this well;
- Groundwater levels recorded at BH2-12 varied between 0.2 m BGS in November 2012, 1.9 m BGS in September 2013, and 0.9 m BGS in December 2013 (246.0 to 244.3 m AMSL), located within the center and southern portions of the *Site*, respectively; and,
- Groundwater levels recorded at BH4-12 were dry upon installation in November 2012, 9.6 m BGS in September 2013, and 9.0 m BGS in December 2013 suggest the well has responded very slowly from installation, and that the screened interval is installed within soil with low hydraulic conductivity.

These results are representative of pre-construction groundwater levels within the *Project Area*; indicating a general groundwater flow direction from northeast to southwest, and consistent with topography. As previously stated, based on the fine textured, low permeability Newmarket Till present across the *Project Area*, minimal groundwater recharge is expected.

There is anecdotal evidence that groundwater seepage may be occurring at some locations within the *Project Area*. Site visits in June, July, September, November, and December 2013 found no evidence of groundwater seepage within the *Project Area*; indicating that groundwater seepage, if present, may occur in spring months following recharge from snow melt. Overland runoff has been observed following rain events within the *Project Area*, as would be anticipated, given the low permeability surficial till present.

Available water level data from monitoring wells and MOE WWR are presented on Figure 6 and Figure 7. Water levels in Figure 6 indicate the general northeast to southwest groundwater flow direction.

### 2.3.5 Aquifer Vulnerability and Groundwater Recharge

A review of aquifer vulnerability and groundwater recharge zones was completed as part of the source water assessment for the Central Lake Ontario Source Water Protection Area completed by CLOCA (2012).



# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Setting  
March 10, 2014

Mapping indicated that the entire *Site* and majority of *Project Area* are considered low aquifer vulnerability. The mapping indicated high aquifer vulnerability at the eastern extent of the *Project Area*, which is likely related to alluvial deposits along the seasonal stream. This high vulnerability area is outside of the *Site* boundaries.

CLOCA (2012) mapping also indicated that the *Project Area* and *development area* were not mapped as a significant groundwater recharge areas. This description is consistent with both OGS mapping and available borehole logs; which primarily indicated clayey material or silt till at ground surface, with occasional intermittent discrete lenses of silty sand material at depth.

### 2.3.6 Summary

The *Project Area* is located within the South Slope physiographic region, along the southern boundary of the Oak Ridges Moraine planning administrative boundary, with surficial deposits of Newmarket Till and isolated deposits of Halton Till. Alluvial deposits associated with watercourse erosion and sediment deposition were also mapped at surface along Farewell Creek and Harmony Creek and their tributaries. The overburden in the vicinity of the *Project Area* primarily consists of till material (Newmarket Till) or fine grained material with low permeability; extending from ground surface up to 104 m BGS (160 m AMSL), with intermittent discrete water bearing silty sand lenses.

A review by CLOCA indicated that the *Project Area* is not considered a significant recharge area and, due to the low permeability fine grained surficial material, the entire *Site* and majority of *Project Area* are considered low aquifer vulnerability.

The shallow stratigraphy within the *Site* consists of sandy silt till with occasional intermittent discrete lenses of silty sand material typically between 0.5 m and 3 m thick. Groundwater levels within the shallow overburden are expected to range from 254.5 m AMSL (BH11-12) to 246.0 m AMSL (BH2-12). The groundwater flow direction within the shallow overburden is from northeast to southwest, generally consistent with topography. There was no evidence to confirm the presence of shallow groundwater discharge conditions were occurring during the summer months in 2013; however, based on anecdotal evidence, shallow groundwater seepage may occur at select locations with the *Project Area* during spring months, possibly within the southern portion of the *Project Area*.

The deeper overburden stratigraphy within the *Project Area* predominantly consists of Newmarket Till or aquitard material, with intermittent silty sand and gravel deposits at various depths. Nearby private wells are installed within these intermittent sand lenses, as encountered, at varying depths. The range in well installation depth suggests that a significant extensive sand aquifer is not located within the vicinity of the *Project Area*. The degree to which the discrete shallow and intermediate depth sand lenses may be hydraulically connected is not known at this time. . At all wells, clayey material was noted overlying the screened aquifer material. Low permeability clayey material typically acts as a confining unit, minimizing recharge / impacts from ground surface to the water supply.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Setting  
March 10, 2014

### 2.4 HYDROLOGY

The delineation of surface water subwatershed boundaries and identification of major flow paths were completed using Ontario Base Maps (OBM) with 5 m topographic contour intervals. Site-specific topographic survey information, as provided by Hydro One, is consistent with drainage divides within the *Project Area*, as mapped using the OBM data. Generally, the subwatershed terrain for the external contributing drainage areas and for the *Project Area* exhibits moderate relief, with typical slopes in the 5-10% range. The topographic range within the *Project Area* varies from a high point of approximately 270 m AMSL at the northern boundary of the property, to a low of approximately 235 m AMSL at the southwest discharge location. The delineation of existing conditions drainage catchments and graphical information relating to other parameters of interest (soil type, topography, aerial imagery) are provided on Figures 8 and 9.

Under existing conditions, there are four (4) points of defined surface water flow from the *Project Area* boundaries, including two (2) intermittent watercourses at the west and east property limits; a tributary to Harmony Creek (main tributary and south branch) and a tributary to Farewell Creek, respectively (Figure 8). Two (2) low-lying surficial drainage features with no defined watercourse attributes (i.e., bed and banks) flow off-site to the south generally in the middle of the property, confluencing immediately downstream of the *Project Area*. Two (2) small wetland pockets are found within the *Project Area*; one coinciding with the upper portion of the south branch of the Harmony Creek tributary immediately north of the *Site*, and another found along the riparian areas of Farewell Creek, east of the *Site* near Langmaid Road (Figure 9).

The existing conditions drainage system has been delineated with four (4) subcatchments, as shown on Figures 8 and 9, and summarized as follows:

- Catchment 100: 24 ha draining to the east-to-west tributary, identified as Reaches 1-4 and 1-5 in the *Natural Heritage Existing Conditions Report* (Stantec, August 22, 2012), bordering the north limits of the developing area and combining with the main Harmony Creek tributary from Catchment 101 at Key Point A;
- Catchment 101: 78 ha draining to the main tributary of Harmony Creek flowing north-to-south at the west limits of the *Project Area*, combining with the east-west tributary described above at Key Point A, and discharging from the property at Key Point B;
- Catchment 102: 142 ha draining to the tributary of Farewell Creek crossing the east limits of the *Project Area*, discharging at Key Point C; and,
- Catchment 103: 23 ha catchment, predominantly contained within the south-central portion of the *Project Area*, draining to the two low-lying surficial drains discharging at the south property boundary at Key Point D.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Setting  
March 10, 2014

Land uses within the majority of the tributary subwatershed consist of cropped agricultural land with some small woodlots. At-surface soil conditions within the overall drainage catchment are based on data from Agriculture and Agri-Food Canada soils reports for the Durham Region and indicate predominant coverage of Bondhead Loam and Muck (Hydrologic Soil Type B) (Figure 8). The Bondhead Loam was derived from the underlying till material.

## 2.4.1 Hydrologic Model Development

A hydrologic model was created to provide a quantitative estimate of the flows to and across the *Project Area*, using the Stormwater Management Hydrologic Model (SWMHYMO) software package and return-period rainfall events (1:2-year, 1:5-year, and 1:100-year). Design rainfall events were derived from Intensity-Duration-Frequency (IDF) data applicable to the Burketon McLaughlin rainfall gauge, located approximately 7 km from the *Project Area*. Utilizing a Soil Conservation Service (SCS) statistical rainfall distribution, a variety of storm durations (6 and 24-hour) were developed to understand hydrologic characteristics under a range of conditions. Table 1 presents a summary of the input rainfall event depths and durations.

**Table 1 Design Rainfall Parameters for Burketon McLaughlin Gauge**

Return Period	6-hr Storm Event Depth (mm)	24-hr Storm Event Depth (mm)
2-year	37.9 mm	47.1 mm
5-year	50.0 mm	59.2 mm
100-year	83.1 mm	92.4 mm

To reflect *Project Area* and Region-specific hydrologic characteristics, some modification to “standard” modeling assumptions were incorporated. Typically, standard modeling subroutines are used for hydrologic model development, utilizing default calibration parameters in the determination of rainfall-runoff relationships. In the *Project Area*, however, the CLOCA provides detailed recommendations for model development, requiring the consideration of non-default parameters. For example, the default initial abstraction (IA) value in SWMHYMO, identifying that initial portion of the rainfall event that is ‘lost’ to incidental storage or use (e.g., intercepted by vegetation, at-ground depressions storage, etc.) is 1.5 mm, whereas CLOCA’s recommended value for crops is 7.0 mm. Details of the input parameters for the hydrologic model are included in Appendix D.

Table 2 presents the results of the peak flow rates under the existing conditions model.

**HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT  
CLARINGTON TRANSFORMER STATION**

Setting  
March 10, 2014

**Table 2 Existing Conditions Hydrologic Model Results**

Key Flow Point / Subcatchment Outlet	Storm Duration (hrs)	Storm Event Return-Period					
		2-yr		5-yr		100-yr	
		Peak Flow (m <sup>3</sup> /s)	Runoff Volume (m <sup>3</sup> )	Peak Flow (m <sup>3</sup> /s)	Runoff Volume (m <sup>3</sup> )	Peak Flow (m <sup>3</sup> /s)	Runoff Volume (m <sup>3</sup> )
A / 100	6	0.25	1,700	0.46	3,020	1.22	7,700
B / 100+101		0.93	7,670	1.69	13,560	4.41	34,290
C / 102		1.06	10,760	1.90	19,170	4.92	48,370
D / 103		0.33	1,760	0.61	3,110	1.59	7,830
Key Flow Point / Subcatchment Outlet	Storm Duration (hrs)	Storm Event Return-Period					
		2-yr		5-yr		100-yr	
		Peak Flow (m <sup>3</sup> /s)	Runoff Volume (m <sup>3</sup> )	Peak Flow (m <sup>3</sup> /s)	Runoff Volume (m <sup>3</sup> )	Peak Flow (m <sup>3</sup> /s)	Runoff Volume (m <sup>3</sup> )
A / 100	24	0.29	2,680	0.46	4,190	1.06	9,250
B / 100+101		1.07	12,040	1.71	18,740	3.86	40,970
C / 102		1.21	17,040	1.93	26,470	4.34	57,740
D / 103		0.39	2,760	0.61	4,300	1.38	9,350

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Site Development and Impact Assessment  
March 10, 2014

### 3.0 Site Development and Impact Assessment

---

Development of the *Site* is understood to involve the construction of above ground switchyard infrastructure, small buildings, and access roads. The specific construction activities pertaining to the hydrogeologic and hydrologic assessment are summarized as follows:

- Of the total *Project Area* of approximately 63 ha, it is understood that the switchyard infrastructure and small buildings will be located within the *Site* boundaries, covering roughly 17 ha. The *Site* is shown on Figure 2;
- Aside from internal access roads and relatively small concrete bases necessary to support specific infrastructure components, the switchyard is to be predominantly constructed upon a sub base of granular materials (depth depending on soil conditions) with a top layer consisting of 400 – 450 mm depth of ¾" crushed stone, required due to the grounding system installed below grade;
- The development involves grading within the *Site* boundaries from an existing ground surface of approximately 248 m AMSL to 259 m AMSL to a more level area ranging from 253 m AMSL to 254 m AMSL. Depending on the specific location within the *Site*, the grading ranges from placing up to 5 m of fill material to the excavation of up to 6 m of native overburden material. In general, excavation will be completed at the eastern extent of the *Site*, with the fill to be placed at the western extent of the *Site* to create a generally level grade for the transformer station;
- A perforated and solid pipe stormwater conveyance system underlying the granular base will be installed to remove at-surface water and convey water percolating through the granular top layers away from the core switchyard / transformer for discharge northward to the south branch of the Harmony Creek tributary;
- The piped drainage system is designed to route stormflow to a single discharge point at the north limits of the *Project Area*; and,
- Specific spills containment measures will be incorporated at the two transformer locations, in the form of concrete containment pits from which effluent will discharge to holding tanks acting as an oil-water separator, with sufficient storage volume provided to contain 100% of the transformer oil volume plus a 100-year, 24-hour storm. Clean water discharged from the oil-water separator unit will be drained to the piped drainage conveyance system.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Site Development and Impact Assessment  
March 10, 2014

### 3.1 HYDROGEOLOGY

As detailed above, development of the *Site* involves placing up to 5 m of fill material at the western extent of the *Site* and the excavation of up to 6 m of native overburden material at the eastern extent of the *Site*.

Based on the water level data from BH11-12, groundwater at the northern extent of the *Site* may be approximately 255 m AMSL. The transformer station's graded ground surface of 253 m AMSL will be approximately 2 m below the interpreted static groundwater level from November 2012. This static water level is likely a seasonal low or near seasonal low following minimal precipitation during summer 2012.

The current ground surface elevation and the *Site*'s graded ground surface are presented on Figures 6 and 7. As shown on these figures, the grading is entirely within fine grained material, however, it is anticipated that *Site* grading may extend below the shallow static groundwater level within the east side of the *Site*.

It is expected that any excavation within the eastern portion of the *Site* will result in some shallow groundwater seepage. Groundwater seepage would be collected as part of the storm water collection system around the perimeter of the *Site*. Given the extent of fine grained material within the *Project Area*, the extent of seepage is anticipated to be minimal; however, additional seepage may be present in the event that a localized shallow sand seam is encountered.

The transformer station construction within the *Site* primarily involves grading of fine textured silt till material. Based on the geology and general depth of excavation, no significant changes to groundwater flow / conditions are expected due to the grading, construction, and development scenario. It is anticipated that shallow groundwater flow will remain in a northeast to southwest direction.

The existing interpreted shallow groundwater flow direction is to the southwest towards the tributary of Harmony Creek. Depending on seasonal groundwater elevations and local sediments, shallow groundwater discharge within the *Site* boundaries has been anecdotally reported within local seeps or within the creek tributaries. However, *Site* field investigations have not confirmed these anecdotal reports. Given that no significant impact is anticipated to the overall groundwater regime, no significant impacts are anticipated to the natural heritage features (creeks and wetlands) that may be influenced seasonally by shallow groundwater flow. Furthermore, any groundwater seepage collected by the perimeter collection system resulting from *Site* regrading will be directed via the perimeter collection system to the same tributary of Harmony Creek.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Site Development and Impact Assessment  
March 10, 2014

As discussed in Section 2.3.3, MOE water well records indicate some nearby private wells are installed within intermittent sand lenses at varying depths ranging from 5.2 m BGS to 108 m BGS, with water-bearing sand and gravel lenses surrounded by lower permeability till. Based on available data, a significant, continuous aquifer was not noted within the local study area. Regional mapping suggests that deep wells may be installed within the top of the Thorncliffe Formation; however, this could not be confirmed based on available data. At all wells, clayey material was noted overlying the screened aquifer material. This clayey material will act as a hydraulic confining unit, minimizing recharge and/or adverse impacts from ground surface to the shallow or intermediate groundwater supply. No adverse impacts due to construction of the transformer station to the underlying Thorncliffe Aquifer are anticipated.

Based on available data, no adverse impacts to nearby private wells or local creeks are anticipated due to *Site* development. Hydraulic testing of on-*Site* monitoring wells and water quality testing of selected nearby residential wells will be completed as a due diligence measure to monitor groundwater conditions and to confirm the assessments presented in this report. The recommended Groundwater and Surface Water Monitoring Program is presented in Section 4.

### 3.2 HYDROLOGY

The *Site* drainage design for the project is currently in the detailed design phase, and will be subject to Environmental Compliance Approval (ECA) for Drainage from the MOE. In terms of assessing the potential impacts on the existing hydrologic condition (surface water) and receiving environs, the following conclusions have been drawn based on current *Site* drainage plans:

- The installation of free-draining granular material at-surface would not, in and of itself, result in significant alterations to surface water response to rainfall events from those experienced under existing conditions;
- However, the introduction of an engineered drainage system (grading and tile drainage) will likely result in discharge of runoff at higher peak rates and volumes to the south branch of the Harmony Creek tributary (north of the *Site*) than experienced under existing conditions, particularly for small, frequent events. Conversely, re-directing drainage away from the two, low-lying surficial drains south of the *Site* will reduce both peak flows and volumes to these systems;
- The net impact of this drainage system is not considered to represent a negative impact on the natural environment and could arguably improve conditions within the north and west reaches, providing a more consistent condition of fish habitat and seasonally moist wetland pockets. As such, there are no significant negative surface water impacts anticipated to the natural heritage features as a result of the proposal;
- Alterations within the remaining 36 ha of the *Project Area* outside of the *Site*, including the construction of new towers and access road(s), are also anticipated to result in only minor hydrologic impacts, typically mitigated through the creation of vegetated (grassed) conveyance systems (i.e., ditches); and,

## HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Site Development and Impact Assessment  
March 10, 2014

- As mentioned in the existing conditions analysis, there are three (3) watercourses located within the *Project Area*, none of which will be directly impacted by the core switchyard / transformer station infrastructure, but crossings of the watercourses will be required as part of the access road system. Any crossings should be designed to manage the peak flows / volumes as presented within the existing conditions hydrologic synopsis.



# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Groundwater and Surface Water Monitoring Program  
March 10, 2014

## 4.0 Groundwater and Surface Water Monitoring Program

---

### 4.1 OBJECTIVES

The following Groundwater and Surface Water Monitoring Program has three primary objectives: to fulfill Hydro One's commitment to implement a pre, during, and post transformer station construction groundwater and surface water monitoring program; to refine our understanding of the physical and chemical characteristics of the shallow and intermediate depth groundwater systems at the *Site*; and to establish a pre-construction baseline of groundwater conditions, including seasonal variations of groundwater quality, quantity, and surface water / groundwater interaction. The monitoring data collected will provide the technical foundation on which to assess whether adverse impacts occurred during or post construction.

### 4.2 MONITORING PROGRAM SCOPE

The Groundwater and Surface Water Monitoring Program includes several key tasks, including installing new groundwater monitoring wells (completed in Fall 2013), implementing a private well monitoring program, surface water monitoring, decommissioning of geotechnical monitoring wells (completed Fall 2013), water level and water quality monitoring, and preparing annual monitoring summary reports through the duration of the monitoring program.

Complementing the groundwater monitoring program, surface water features located on the north (wetland), west (creek), and south (drainage swale) sides of the *Site* will be monitored. Background water levels within three newly installed shallow piezometers (mini shallow wells) will be recorded prior to construction of the transformer station, and compared to monitoring results recorded during and post construction. The monitoring data collected will provide the technical foundation on which to further characterize our understanding of the shallow groundwater system, to assess whether adverse impacts occurred during or post construction, and to provide guidance for appropriate mitigation, if needed.

Owners of private wells on properties immediately adjacent to the east and south of the *Site* will be able to have the water level and water quality in their wells monitored prior to, during, and post construction of the transformer station. A baseline of seasonal normal groundwater levels and groundwater quality will be established prior to construction of the transformer station. Once construction of the transformer station begins, the well monitoring program will continue with observations compared to baseline conditions, allowing for an assessment of potential impacts on the natural environment and of the efficacy of the engineered containment structures and water treatment systems to be installed.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Groundwater and Surface Water Monitoring Program  
March 10, 2014

Groundwater and surface water data collected prior to construction of the transformer station will help define the relationship between the shallow and intermediate depth groundwater systems at the Site and how they interact with each other; providing a baseline to which monitoring data collected during construction and post construction will be compared. Specifically, the Groundwater and Surface Water Monitoring Program will allow for quantification of the following hydrogeological characteristics of the site:

- Refinement of Site geologic stratigraphy;
- Seasonal shallow and intermediate groundwater water levels across the site;
- Seasonal shallow and intermediate groundwater chemistry;
- Vertical groundwater gradients (identify areas of upward, neutral, or downward groundwater movement) between surface water and shallow groundwater system, and shallow and intermediate depth groundwater systems;
- Shallow and intermediate depth hydraulic conductivity, including variations in hydraulic conductivity associated with the different geologic materials identified during previous and recent drilling programs;
- Continuous (hourly) groundwater level monitoring to allow for observation and calculation of seasonal variations in surface water, groundwater, and private wells; and,
- Potential changes in shallow groundwater elevation associated with the cut portion (east side) of the grading area, including the potential radius of groundwater influence, and potential for private well interference.

The hydrogeologic conditions presented in the Project ESR will be confirmed through the analyses and interpretation of groundwater and surface water data collected prior to construction of the transformer station. The monitoring program will continue during and post construction of the transformer station in order to confirm that the mitigation measures and engineered containment structures designed to protect the natural form and function of the surface water system, shallow and intermediate groundwater systems, and the adjacent private water wells are functioning as designed.

This monitoring program will also be adaptive. Changes to the monitoring program and/or laboratory analyses may be implemented, as determined by Hydro One and its environmental consultant, depending on the monitoring results and interpretations derived from them.

### 4.3 MONITORING INSTALLATIONS

The Groundwater and Surface Water Monitoring Program takes into consideration potential adverse impacts of the project on the natural environment in the absence of implementing any mitigations measures (containment structures, water treatment, etc.). These include the introduction of chemical substances and changes to the natural form and function of the shallow and intermediate depth groundwater and surface water systems. As a result, the depths of the monitoring wells, monitoring frequency, and selected water quality analyses of the entire monitoring program have been selected with detection of potential changes to these receptors as their primary objective.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Groundwater and Surface Water Monitoring Program  
March 10, 2014

### 4.3.1 Site Monitoring Wells

The groundwater monitoring wells installed at the *Site* during the previous geotechnical investigations were all installed at an intermediate depth (screened between approximately 11 m and 15 m depth). These monitoring wells were located where excavations for footings or foundations are planned, and as a result, needed to be decommissioned prior to construction of these foundations.

In the Fall of 2013, this monitoring program was initiated by installing pairs of new monitoring wells on each side of the *Site* (Figure 1). The new intermediate depth (approximately 10 m to 15 m depth) wells have been paired with shallow depth wells (approximately 1 m to 3 m depth) intended to intersect the elevation of the shallow water table. By installing pairs of shallow and intermediate depth wells, changes in groundwater levels, groundwater chemistry and vertical hydraulic gradients (upward or downward movement of groundwater) will be able to be measured and monitored seasonally prior to, during, and post construction of the transformer station.

Drive point piezometers (shallow mini wells) have also been installed within *Site* surface water features in order to monitor seasonal shallow groundwater and surface water levels within the wetland (north side), creek (west side) and drainage swale (south side) features found on-*Site*.

The new groundwater monitoring wells were installed according to the MOE Water Resource Act (O. Reg. 903). A licensed well drilling contractor was retained and has completed the following:

- Installation of three (3) stream/wetland drive-point piezometers;
- Drilling and installation of four (4) shallow and intermediate depth pairs of groundwater monitoring wells (8 wells in total); advanced to depth of approximately 1 to 3 metres and 10 to 15 metres, respectively;
- Complete grouting (sealing) of outer well annulus;
- Installation of protective and lockable well casing; and,
- Decommissioning of former geotechnical wells according to the MOE Water Resource Act (O. Reg. 903).

Upon completing installation of the new monitoring wells in December 2013, the water level in several wells were observed to have recovered slowly, with some not recovering sufficiently after several days to allow for a collection of water quality samples. Monitoring of the new wells will continue with the completion of a water level monitoring event in Winter 2014, noting if any wells are frozen.

In Spring 2014, the new wells will be further developed, hydraulically tested (slug testing) to confirm estimates presented in the Project ESR, and sampled for groundwater quality. Selected representative soil samples obtained and preserved during drilling will be submitted for laboratory sieve grain size analyses.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Groundwater and Surface Water Monitoring Program  
March 10, 2014

### 4.3.2 Private Well Monitoring

A review of the MOE water well record database indicates that there are approximately 10 wells registered with the MOE on properties immediately to the east and south of the *Site*. The private well monitoring program will include providing notification to all potential groundwater users immediately adjacent to the *Site*, informing the property and/or well owners of the transformer station construction schedule, and the parameters of the private well monitoring program. The notification information will provide the details of the monitoring program, and include appropriate project contact information for Hydro One regarding construction concerns. During the door-to-door site visits, Stantec will also make note of and attempt to contact well owners that may not appear in the MOE's records for the purpose of offering participation in the private well monitoring program.

Participation in the private well monitoring program will only be completed with the owner's authorization, and will include water quality sampling and water level monitoring, depending on well accessibility. Water level monitoring involves installing an automated well water level logger (pressure transducer), which can only be completed at accessible wells by a licensed well contractor. The automated loggers will monitor 'continuous' water levels (at 5 to 60 minute intervals) from Spring 2014 until two years following completion of construction. The loggers would be removed at the end of the monitoring program.

Private well water quality samples will be collected from a raw water tap (prior to any treatment or filtration), where available. If no raw water tap is present, a sample may be collected directly from the well, depending on well accessibility and well owner authorization. After purging water from the well, the samples will be collected directly into laboratory supplied sample containers. The samples will not be field filtered and will be submitted for general chemistry, turbidity, metals, hydrocarbons (F1-F4 and BTEX), and bacteriological analyses. To supplement and provide quality assurance, temperature, conductivity, and pH data will be collected in the field at the time of sampling.

Individual private well analytical results will be presented in a letter to each resident following each sampling event along with the available water level data. Private well data will remain confidential, and is not permitted to be shared with the general public. However, monitoring reports for data collected on-*Site* will be prepared annually and made available to the public by Hydro One.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Groundwater and Surface Water Monitoring Program  
March 10, 2014

### 4.4 SURFACE WATER MONITORING

A Stantec terrestrial ecologist will monitor the *Site* prior to transformer station construction to confirm the presence or absence of groundwater seeps within the *Project Area*, identifying notable indicator parameters and plant species. Ecological monitoring will continue annually during construction of the transformer station, and for two years following completion of construction. Surface water levels and water quality samples will be collected from three (3) surface water monitoring locations (at piezometer installation locations) and submitted for laboratory analyses following the monitoring schedule discussed below.

### 4.5 WATER QUALITY ANALYSES

Groundwater water quality samples from each of the new on-*Site* monitoring wells and participating private wells will be collected according to laboratory protocols, preserved, and submitted for laboratory analyses (general chemistry, metals, and hydrocarbons (F1-F4 and BTEX)) to Maxxam Analytics, an accredited laboratory. Well water quality parameter analyses will be compared to Ontario Drinking Water Quality Standards (ODWQS).

Surface water quality samples will be collected from each of the three new surface water monitoring locations adjacent to the new piezometer installations (when surface water is present) according to laboratory protocols, preserved, and submitted for laboratory analyses (general chemistry, metals, and hydrocarbons (F1-F4 and BTEX)) to Maxxam Analytics. Surface water quality parameter analyses will be compared to Provincial Water Quality Objectives (PWQO).

A water quality parameter list is included in Appendix A.

### 4.6 MONITORING SCHEDULE

The Groundwater and Surface Water Monitoring Program schedule frequency is designed to record groundwater levels continuously with the use of automated pressure transducers, and to seasonally (quarterly) collect groundwater and surface water quality samples for laboratory analyses for the first year of monitoring in order to establish potential seasonal variations in groundwater levels and chemistry. Table 3 presents the program water quality sampling schedule. Following the first year of quarterly (seasonal) monitoring, the schedule will change to semi-annual monitoring (spring and fall). Upon completion of construction, monitoring of groundwater, surface water, and private wells will continue semi-annually for two years.

For scheduling purposes, it is anticipated that quarterly seasonal monitoring will take place from Fall 2013 to Summer 2014; semi-annual (construction) monitoring will continue from Fall 2014 through to Fall 2017; and semi-annual post-construction monitoring will extend for 2 years following completion of construction. Presently construction is anticipated to be completed in Fall 2017, with this monitoring program continuing until Fall 2019.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Groundwater and Surface Water Monitoring Program  
March 10, 2014

**Table 3 Monitoring Schedule**

Pre-Construction and Construction Monitoring Schedule											
2013				2014				2015			
Winter	Spring	Summer	Fall	Winter	Spring	Summer	Fall	Winter	Spring	Summer	Fall
			X	X	X	X	X		X		X
2016				2017							
Winter	Spring	Summer	Fall	Winter	Spring	Summer	Fall				
	X		X		X		X				
Post-Construction Monitoring Schedule											
2018				2019							
Winter	Spring	Summer	Fall	Winter	Spring	Summer	Fall				
	X		X		X		X				

## 4.7 REPORTING

A *Baseline Conditions Report* will be prepared following the Fall 2014 monitoring event summarizing the *Site* baseline groundwater and surface water conditions prior to construction of the transformer station.

Subsequent annual monitoring program summary reports will be prepared following the Fall monitoring and sampling events. The reports will present all on-Site groundwater and surface water monitoring data and a general summary of private well water level and water quality data. Private well owners will be provided with the data (water level and water quality) from their own individual well only. In the event an exceedence of the ODWQS is received from the laboratory, the private well owner will be advised of the exceedence immediately upon receipt and review of the laboratory data.

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Conclusions and Recommendations  
March 10, 2014

## 5.0 Conclusions and Recommendations

---

Based on the background information reviewed, and hydrogeologic and hydrologic information compiled and summarized herein and in the Project ESR, it is concluded that development of the *Site* should not result in any associated negative impacts on receiving surface water or groundwater systems including to the natural environment (creeks and wetlands) or adjacent private property infrastructure (i.e., water supply wells). It is understood that pre-, during- and post-construction monitoring programs to field verify these conclusions will be implemented.

The following specific conclusions are provided:

- The Clarington Transmission Station is located within the southern boundary of the area delineated by the Oak Ridges Moraine Conservation Plan;
- Stratigraphy within the *Project Area* consists of thick silt till overburden, which is representative of the Newmarket Till with pockets of Halton Till at surface. The till material is considered an aquitard and will impede surface water recharge or groundwater discharge within the *Project Area*. Occasional sand lenses were noted at variable depths and adjacent private wells are installed within these sand lenses;
- CLOCA (2012) mapping indicated that the *Site* is considered low aquifer vulnerability and not an area of significant recharge;
- Shallow groundwater within the *Project Area* flows in the general direction of surficial topography, from northeast to southwest. Shallow groundwater seepage may be occurring in select locations of the *Project Area*, specifically to the southern drains;
- Development of the *Site* includes approximately 5 to 6 m of cut and fill grading of fine textured material consisting of silt till material with excavation at the eastern extent of the *Site* with the fill to be placed at the western extent of the *Site*. The excavation within the eastern portion of the *Site* will result in some shallow groundwater seepage; however, given the fine grained material, the extent of seepage is expected to be minimal. Any seepage would be collected as part of the storm water collection system and discharge to the south branch of the Harmony Creek tributary. . No significant changes to groundwater flow / conditions are expected due to *Site* grading, construction, and development scenario. It is expected that groundwater flow will remain in a northeast to southwest direction;

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT

## CLARINGTON TRANSFORMER STATION

Conclusions and Recommendations

March 10, 2014

- The majority of nearby private wells are installed within discrete sand deposits, significantly deeper than the *Site* development activity. Available stratigraphy does not indicate the presence of direct hydraulic connection between surficial activities within the *Site* boundaries to the nearby private wells. The degree to which the discrete sand lenses may be hydraulically connected is not known at this time. The deep private wells may be installed within the top of the Thorncliffe Formation; however, this was not confirmed based on available records. The range in well installation and depth suggests that a significant sand aquifer is not located in the vicinity of the *Project Area*. The *Site* development is not expected to significantly impact groundwater flow or quality conditions or affect nearby private wells;
- The net impact on local hydrology is expected to be negligible, and possibly result in an improvement in the surface water receiving systems in Harmony Creek tributary; and,
- The Groundwater and Surface Water Monitoring Program presented in Section 4.0 will fulfill the environmental monitoring commitments made by Hydro One in the Project's ESR by establishing background hydrogeological conditions and by providing a monitoring program that will identify and monitor the natural form and function of the shallow and intermediate depth groundwater system during and post construction.

As proper due diligence, the following monitoring recommendation is proposed:

- Implement the Groundwater and Surface Water Monitoring Program discussed in Section 4.0 of this report to confirm the findings of this assessment and to mitigate potential adverse impacts to the shallow groundwater system and private water well users.



# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

References  
March 10, 2014

## 6.0 References

---

- Chapman, L.J. and D.F. Putnam, 1984. The Physiography of Southern Ontario. Ontario Geological Survey, Special Volume 2, 270 pp.
- CLOCA, 2012. Approved Assessment Report, Central Lake Ontario Source Protection Area. Chapter 4 – Assessing Vulnerability of Drinking Water Sources. January 18, 2012.
- exp Services Inc. 2012. Geotechnical Report – Clarington TS, Municipality of Clarington. Project No. BAR-00025036-A0, June 19, 2012.
- Hydro One Networks Inc., 2008. Enfield Transformer Station, Class Environmental Assessment, Final Environmental Study Report. August 2008.
- Hydro One Networks Inc., 2012. Clarington Transformer Station, Class Environmental Assessment, Draft Environmental Study Report. Project No. 590-CLEA-12-11, November 2012.
- Inspec-Sol Inc. 2013. Geotechnical Investigation – Clarington Transformer Station (TS). Report T040774a1, January 23, 2013.
- Geological Survey of Canada, 2001. Regional three-dimensional stratigraphic modeling of the Oak Ridges Moraine area, Southern Ontario.
- Ontario Geological Survey (OGS). 2003. Surficial Geology of Southern Ontario.
- Ontario Ministry of Municipal Affairs and Housing (MMAH). 2002. Oak Ridges Moraine Conservation Plan (ORMCP).
- Ontario Ministry of Municipal Affairs and Housing (MMAH). 2005. Greenbelt Plan. February 29, 2005. 57 pp.
- Singer, S.N., C.K. Cheng and M.G. Scafe. 2003. The Hydrogeology of Southern Ontario. 2<sup>nd</sup> edition. Ministry of the Environment, Hydrogeology of Ontario Series (Report 1). April 2003.
- Stantec Consulting Ltd., 2008. Hydro One Proposed Enfield Transformer Station – Environmental Baseline. Project No. 1609-60217. Prepared for Hydro One Networks Inc., March 2008.



# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION


Appendix A Figures

March 10, 2014

## Appendix A Figures



\\cd1220-102\Work\_group\01609\active\60960745\drawing\MXD\Hydrogeology\HydroG\_Assess\160960745\_HG\_Fig01\_SiteLocation.mxd  
 Revised: 2013-03-26 By: ccoughlan



March 2013  
160960745



**Legend**

- Project Area
- Highway
- Major Road
- Local Road
- Watercourse
- Utility Line
- Municipal Boundary
- Greenbelt - Natural Heritage System
- Greenbelt - Protected Countryside
- Oak Ridges Moraine
- Waterbody

**Notes**

1. Coordinate System: NAD 1983 UTM Zone 17N
2. Base features produced under license with the Ontario Ministry of Natural Resources © Queen's Printer for Ontario, 2012.

Client/Project

Hydro One Networks Inc.  
Hydrogeologic & Hydrologic Assessment Report  
Clarington, Ontario

Figure No.

1

Title

**Project Location**





- ### Legend
- Monitoring Well (Inspec-Sol, 2012)
  - Monitoring Well (EXP, 2012)
  - Borehole (Inspec-Sol, 2012)
  - Borehole (EXP, 2012)
  - MOE Water Well Record
  - Project Area
  - Proposed Development Area
  - Cross-Section Location
  - Topographic Contour (mAMSL)
  - Watercourse
  - Waterbody

- ### Notes
1. Coordinate System: NAD 1983 UTM Zone 17N
  2. Base features produced under license with the Ontario Ministry of Natural Resources © Queen's Printer for Ontario, 2012.
  3. Orthoimagery © First Base Solutions, 2012.
  4. Topography derived from the MNR Digital Elevation Model - Version 2.0.0 - Provincial Tiled Dataset (DEM) © Queen's Printer for Ontario, 2006.




**Stantec**

April 2013  
160960745


Client/Project  
Hydro One Networks Inc.  
Hydrogeologic & Hydrologic Assessment Report  
Clarington, Ontario

Figure No.  
2

Title  
**Project Site Plan**







March 2013  
160960745



**Stantec**


Client/Project  
Hydro One Networks Inc.  
Hydrogeologic and Hydrologic  
Assessment Report  
Clarington, Ontario

Figure No.

3

Title

**Schematic of  
Oak Ridges Moraine**



### Legend

- Project
- Proposed Development
- Watercourse
- Waterbody
- Oak Ridges Moraine
- Waterbody

#### Surficial Geology

- 20: Organic deposits
- 19: Modern alluvial deposits
- 12: Older alluvial deposits
- 9c: Coarse-textured glaciolacustrine deposits (Foreshore-basinal deposits)
- 8a: Fine-textured glaciolacustrine deposits (Massive-well laminated)
- 6: Ice-contact stratified deposits
- 5b: Stone-poor, carbonate-derived silty to sandy till (Newmarket Till)
- 5d: Glaciolacustrine-derived silty to clayey till (Halton Till)

- ### Notes
1. Coordinate System: NAD 1983 UTM Zone 17N
  2. Base features produced under license with the Ontario Ministry of Natural Resources © Queen's Printer for Ontario, 2012.
  3. Surficial geology produced by the Ontario Geological Survey 2003. Surficial geology of Southern Ontario; Ontario Geological Survey, MRD 128.




April 2013  
160960745

Client/Project  
Hydro One Networks Inc.  
Hydrogeologic & Hydrologic Assessment Report  
Clarington, Ontario

Figure No.  
4

Title  
**Regional Surficial Geology**





**Legend**

- Monitoring Well (Inspec-Sol, 2012)
- Monitoring Well (EXP, 2012)
- Borehole (Inspec-Sol, 2012)
- Borehole (EXP, 2012)
- MOE Water Well Record
- Project
- Proposed Development
- Watercourse
- Oak Ridges Moraine
- Waterbody
- Surficial Geology**
- 20: Organic deposits
- 19: Modern alluvial deposits
- 9c: Coarse-textured glaciolacustrine deposits (Foreshore-basinal deposits)
- 6: Ice-contact stratified deposits
- 5b: Stone-poor, carbonate-derived silty to sandy till (Newmarket Till)
- 5d: Glaciolacustrine-derived silty to clayey till (Halton Till)

**Notes**

1. Coordinate System: NAD 1983 UTM Zone 17N
2. Base features produced under license with the Ontario Ministry of Natural Resources © Queen's Printer for Ontario, 2012.
3. Surficial geology produced by the Ontario Geological Survey 2003. Surficial geology of Southern Ontario; Ontario Geological Survey, MRD 128.



**Stantec**


April 2013  
160960745

Client/Project  
Hydro One Networks Inc.  
Hydrogeologic & Hydrologic Assessment Report  
Clarington, Ontario

Figure No.  
5

Title  
**Project Area Surficial Geology**

\\cf122p-102\work\_group\1609\active\160960745\drawing\MXD\Hydrogeology\HydroG\_Assess\160960745\_HG\_Fig06\_xsecA.mxd  
 Revised: 2013-04-11 By: cooghlan



**Legend**

- Well ID (Offset)
- Stratigraphy
- Water Level
- Well Screen
- Surface Water
- Crossings
- Ground Surface
- Proposed Grading
- Silt Till (Newmarket Till)
- Modern Alluvial Deposits
- Sandy Silt to Silty Sand

**Notes**

1. Water level data as presented in MOE WWR or borehole log.


Client/Project  
 Hydro One Networks Inc.  
 Hydrogeologic & Hydrologic Assessment Report  
 Clarington, Ontario

Figure No.  
**6**

Title  
**Cross-Section A-A'**



\\cf122p-102\work\_group\01609\active\160960745\drawing\MXD\Hydrogeology\HydroG\_A\assess\160960745\_HG\_Fig07\_xseeBB.mxd  
Revised: 2013-04-11 By: cooghlan



April 2013  
160960745



**Legend**

- 2807874 (OS m) Well ID (Offset)
- Sand Stratigraphy
- Water Level
- Well Screen

- Ground Surface
- Proposed Grading
- Silt Till (Newmarket Till)
- Sandy Silt to Silty Sand

**Notes**

1. Water level data as presented on borehole log.

Client/Project


Hydro One Networks Inc.  
Hydrogeologic & Hydrologic Assessment Report  
Clarington, Ontario

Figure No.

7

Title

**Cross-Section B-B'**



### Legend

- Project Area
- Key Flow Points
- Drainage Catchment
- Road
- Topographic Contour (mAMSL)
- Watercourse
- Waterbody
- Soil Type**
- Bottom Land
- Bondhead Loam
- Lyons Loam
- Muck
- Smithfield Clay Loam

- ### Notes
1. Coordinate System: NAD 1983 UTM Zone 17N
  2. Base features produced under license with the Ontario Ministry of Natural Resources © Queen's Printer for Ontario, 2012.
  3. Soils data provided by Agriculture and Agri-Food Canada, Region of Durham.




Client/Project  
 Hydro One Networks Inc.  
 Hydrogeologic & Hydrologic Assessment Report  
 Clarington, Ontario

Figure No.  
 8

Title  
**Drainage Catchments  
 and At-Surface Soils**





**Legend**

- Project Area
- Key Flow Points
- Drainage Catchment
- Topographic Contour (mAMSL)
- Watercourse

- Notes**
1. Coordinate System: NAD 1983 UTM Zone 17N
  2. Base features produced under license with the Ontario Ministry of Natural Resources © Queen's Printer for Ontario, 2012.
  3. Orthoimagery © First Base Solutions, 2008.




April 2013  
160960745

Client/Project  
Hydro One Networks Inc.  
Hydrogeologic & Hydrologic Assessment Report  
Clarington, Ontario

Figure No.  
9









Title  
**Drainage Catchments and  
Aerial Imagery**







**Legend**

-  Monitoring Well (Stantec, 2013)
-  Piezometer (Stantec, 2013)
-  Existing Power Feature
-  New Infrastructure
-  Topographic Contour (mAMSL)
-  Watercourse
-  Project Area
-  Clarington TS Site

**Notes**

1. Coordinate System: NAD 1983 UTM Zone 17N
2. Base features produced under license with the Ontario Ministry of Natural Resources © Queen's Printer for Ontario, 2012.
3. Orthoimagery © First Base Solutions, 2012.



**Stantec**

February 2014  
160960745

Client/Project  
Hydro One Networks Inc.  
Hydrogeologic & Hydrologic Assessment Report  
Clarington, Ontario

Figure No.  
10

Title  
**Groundwater & Surface Water  
Monitoring Locations**



# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Appendix B Borehole Logs  
March 10, 2014

## Appendix B Borehole Logs








# Log of Borehole BH1

Project No. BAR-00025036-A0

Figure No. 2

Project: Clarington TS

Sheet No. 2 of 2



BARRIEG BOREHOLE LOGS.GPJ NEW.GDT 6/18/12



exp. Services Inc.  
 561 Bryne Drive, Unit D  
 Barrie, ON L4N 9Y3  
 t: +1.705.734.6222  
 f: +1.705.734.6224

Borehole data requires interpretation assistance from **Exp** before use by others.  
 See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	14.3	14.4





# Log of Borehole BH2

Project No. BAR-00025036-A0

Figure No. 3

Project: Clarington TS

Sheet No. 2 of 2

LWG	SOIL LOGS	Soil Description	ELEV. m	DEPTH m	N Value				Combustible Vapour Reading (ppm)			SOIL SAMPLE	Sample Number	
					20	40	60	80	250	500	750			
					Shear Strength kPa				Natural Moisture Content % Atterberg Limits (% Dry Weight)					
			242.90	10		100	200			10	20	30		
				11		50 for 127 mm				X				SA10
			241.3			70 for 102 mm								SA11
		<b>AUGER REFUSAL ON PROBABLE BOULDER</b>												

Draft

BARRIEG\_BOREHOLE LOGS.GPJ NEW.GDT 6/18/12



**exp. Services Inc.**  
 561 Bryne Drive, Unit D  
 Barrie, ON L4N 9Y3  
 t: +1.705.734.6222  
 f: +1.705.734.6224

Borehole data requires interpretation assistance from **Exp** before use by others.  
 See Figures 1A and 1B for Notes on Sample Descriptions.


Time	Water Level (m)	Depth to Cave (m)
Upon Completion	0.8	1.4

# Log of Borehole BH3

Project No. BAR-00025036-A0  
 Project: Clarington TS  
 City/  
 Municipality: Municipality of Clarington, Ontario  
 Location: \_\_\_\_\_  
 Date Drilled: May 15th & 16th, 2012  
 Drill Type: Hollow Stem Augers  
 Datum: \_\_\_\_\_

Figure No. 4  
 Sheet No. 1 of 2

- Auger Sample
- SPT (N) Value
- Dynamic Cone Test
- Shelby Tube
- Field Vane Test
- Combustible Vapour Reading
- Natural Moisture
- Plastic and Liquid Limit
- Undrained Triaxial at % Strain at Failure
- Penetrometer



BARRIEG BOREHOLE LOGS GPJ\_NEW/GDT 6/18/12

Continued Next Page



exp. Services Inc.  
 561 Bryne Drive, Unit D  
 Barrie, ON L4N 9Y3  
 t: +1.705.734.6222  
 f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.  
 See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	12.5	14.3

# Log of Borehole BH3

Project No. BAR-00025036-A0

Figure No. 4

Project: Clarington TS

Sheet No. 2 of 2

GWL	SOIL LOG	Soil Description	ELEV. m	DEPTH m	N Value				Combustible Vapour Reading (ppm)			Sample Number
					Shear Strength				Natural Moisture Content % Atterberg Limits (% Dry Weight)			
					20	40	60	80	250	500	750	
			246.97	10								
			245.2	11			72		X			SA10
		<b>SILT TILL:</b> Some Sand, Trace to Some Clay, Trace Gravel, Grey, Moist [Very Dense]										
			244.47	12			73		X			SA11
			243.7	13								
		<b>SANDY SILT TILL:</b> Trace to Some Gravel, Occasional Wet Seams, Grey, Damp to Moist [Very Dense]					68		X			SA12
			241.3	15				94 for 254 mm	X			SA13
		<b>END OF BOREHOLE</b>										

BARRIEG\_BOREHOLE LOGS.GPJ, NEW.GDT 6/18/12



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	12.5	14.3

# Log of Borehole BH4

Project No. BAR-00025036-A0

Figure No. 5

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 25, 2012

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading

Natural Moisture

Plastic and Liquid Limit


Undrained Triaxial at

% Strain at Failure

Penetrometer

Drill Type: Hollow Stem Augers

Datum: \_\_\_\_\_



BARRIEG\_BOREHOLE\_LOGS.GPJ\_NEW.GDT 6/18/12

Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.

See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	Dry	15.6



# Log of Borehole BH4

Project No. BAR-00025036-A0

Figure No. 5

Project: Clarington TS

Sheet No. 2 of 2

GWL	SYMBOL	Soil Description	ELEV. m	DEPTH m	N Value				Combustible Vapour Reading (ppm)			SAMPLE NUMBER	Sample Number	
					20	40	60	80	250	500	750			
			242.01	10										
		<b>CLAYEY SILT TILL:</b> Some Sand, Trace Gravel, Occasional Wet Sand Seams, Grey, Moist [Hard]	241.8			47				X			SA10	
				11										
			239.5	12		59				X			SA11	
		<b>SANDY SILT TILL:</b> Some Clay, Some Gravel, Grey, Moist to Damp [Very Dense] Boulder		13										
				14		81				X			SA12	
				15										
			236.4			33				X			SA13	
		<b>CLAYEY SILT TILL:</b> Trace Gravel, Grey, Moist [Hard] END OF BOREHOLE	236.3											

BARRIEG BOREHOLE LOGS.GPJ NEW.GDT 6/18/12



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires  
interpretation assistance from  
Exp before use by others.

See Figures 1A and 1B for  
Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	Dry	15.6



# Log of Borehole BH5

Project No. BAR-00025036-A0

Figure No. 6

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 15, 2012

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading


Natural Moisture

Plastic and Liquid Limit

Undrained Triaxial at

% Strain at Failure

Penetrometer



BARRIEG\_BOREHOLE LOGS.GPJ NEW.GDT 6/18/12

Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.

See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	3.8	6.1



# Log of Borehole BH6

Project No. BAR-00025036-A0

Figure No. 7

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 28, 2012

Auger Sample

Combustible Vapour Reading

SPT (N) Value

Natural Moisture

Dynamic Cone Test

Plastic and Liquid Limit

Shelby Tube

Undrained Triaxial at


Drill Type: Hollow Stem Augers

Datum: \_\_\_\_\_

Field Vane Test

% Strain at Failure

Penetrometer



Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	2.9	5.8



# Log of Borehole BH6

Project No. BAR-00025036-A0

Figure No. 7

Project: Clarington TS

Sheet No. 2 of 2

GWL	SOIL SYMBOL	Soil Description	ELEV. m	DEPTH m	N Value				Combustible Vapour Reading (ppm)			Sample Number	
					20	40	60	80	250	500	750		
			245.73	10									
			244.0	11									
		<b>SILTY SAND/SANDY SILT:</b> Grey, Wet to Saturated [Very Dense]				50 for 102 mm				X			SA10
			241.9	12									
		<b>SANDY SILT TILL:</b> Some Gravel, Grey, Moist to Very Moist [Very Dense]				50 for 127 mm				X			SA11
			240.4	13									
						50 for 76 mm				X			SA12
			240.4	14									
		<b>END OF BOREHOLE</b>				50 for 102 mm				X			SA13

BARRIEG\_BOREHOLE\_LOGS.GPJ NEW.GDT 6/18/12



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	2.9	5.8

# Log of Borehole BH7A

Project No. BAR-00025036-A0

Figure No. 8

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 24th & 25th, 2012

Auger Sample

Combustible Vapour Reading

SPT (N) Value

Natural Moisture

Dynamic Cone Test

Plastic and Liquid Limit

Shelby Tube

Undrained Triaxial at


Drill Type: Hollow Stem Augers

Field Vane Test

% Strain at Failure

Datum: \_\_\_\_\_

Penetrometer



Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	4.9	5.3
May 28, 2012	1.5	
May 29, 2012	2.4	
June 6, 2012	1.6	

# Log of Borehole BH7A

Project No. BAR-00025036-A0

Figure No. 8

Project: Clarington TS

Sheet No. 2 of 2

GWL	SYMBOL	Soil Description	ELEV. m	DEPTH m	N Value				Combustible Vapour Reading (ppm)			SAMPLE NO.	Sample Number	
					20	40	60	80	250	500	750			
					Shear Strength kPa				Natural Moisture Content % Atterberg Limits (% Dry Weight)					
		Boulder -----	243.20	10										
				11		50 for 127 mm				X				SA10
				12										
				13		50 for 102 mm				X				SA11
				14										
				15		50 for 127 mm								SA12
				16										
			237.9			50 for 102 mm				X				SA13
		END OF BOREHOLE												
		NOTE: Borehole was relocated 3 times due to boulders at various depths.												

BARRIEG BOREHOLE LOGS.GPJ NEW.GDT 6/18/12



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from **Exp** before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	4.9	5.3
May 28, 2012	1.5	
May 29, 2012	2.4	
June 6, 2012	1.6	



# Log of Borehole BH7B

Project No. BAR-00025036-A0

Figure No. 9

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 25, 2012

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading

Natural Moisture


Plastic and Liquid Limit

Undrained Triaxial at

% Strain at Failure

Penetrometer

Datum: \_\_\_\_\_



BARRIEG BOREHOLE LOGS.GPJ NEW.GDT 6/18/12

Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.

See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	3.8	7.5





# Log of Borehole BH7C

Project No. BAR-00025036-A0

Figure No. 10

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 30, 2012

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading

Natural Moisture


Plastic and Liquid Limit

Undrained Triaxial at

% Strain at Failure

Penetrometer

Datum: \_\_\_\_\_



BARRIEG BOREHOLE LOGS GPJ NEW GDT 6/18/12

Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	14.8	15.2

# Log of Borehole BH7C

Project No. BAR-00025036-A0

Figure No. 10

Project: Clarington TS

Sheet No. 2 of 2

GWL	SYMBOL	Soil Description	ELEV. m	DEPTH m	N Value				Combustible Vapour Reading (ppm)			SAMPLE NUMBER
					Shear Strength kPa				Natural Moisture Content % Atterberg Limits (% Dry Weight)			
					20	40	60	80	250	500	750	
		Boulders	242.29 242.1	10								
		SANDY SILT TILL: Trace to Some Gravel, Trace to Some Clay, Grey, Moist to Very Moist [Very Dense]		11		44			X			SA10
		Wet Sand Seams		12			73		X			SA11
				13								
				14		46			X			SA12
			237.49	15								
			236.6	16		44			X			SA13
		END OF BOREHOLE										

BARRIEG BOREHOLE LOGS GPJ NEW/GDT 6/18/12



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.

See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	14.8	15.2

# Log of Borehole BH7D

Project No. BAR-00025036-A0  
 Project: Clarington TS  
 City/  
 Municipality: Municipality of Clarington, Ontario

Figure No. 11  
 Sheet No. 1 of 2

Location: \_\_\_\_\_  
 Date Drilled: May 25, 2012  
 Drill Type: Hollow Stem Augers  
 Datum: \_\_\_\_\_

- |                   |     |   |    |
|-------------------|-----|---|----|
| Auger Sample      | ☒   | Combustible Vapour Reading                | □  |
| SPT (N) Value     | ○ ☒ | Natural Moisture                          | ×  |
| Dynamic Cone Test | —   | Plastic and Liquid Limit                  | —○ |
| Shelby Tube       | ■   | Undrained Triaxial at % Strain at Failure | ⊕  |
| Field Vane Test   | ⊕   | Penetrometer                              | ▲  |

SYMBOL	Soil Description	ELEV. m	N Value		Combustible Vapour Reading (ppm)			SAMPLES	Sample Number
			20	40	250	500	750		
	<b>TOPSOIL: Sandy Silt, Dark Brown, Moist</b>	254.43							
	[Loose]	254.1							
	<b>SANDY SILT: Trace Clay, Topsoil Inclusions, Dark Brown to Brown, Moist</b>	253.7							
	[Loose]								
	<b>SANDY SILT TILL: Some Gravel, Brown to Grey, Moist to Damp</b>								
	[Compact to Very Dense]								
	<b>Cobbles and Boulders</b>								
		250.43							
	<b>Boulders</b>								
		248.8							
	<b>SILTY SAND AND GRAVEL: Grey, Very Moist</b>								
	[Dense]								
		247.3							
	<b>SILTY SAND: Trace to With Gravel, Grey, Very Moist</b>								
	[Very Dense]								

BARRIEG\_BOREHOLE\_LOGS.GPJ NEW.GDT 6/18/12

Continued Next Page



Borehole data requires interpretation assistance from **Exp** before use by others.  
 See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	4.0	4.7



# Log of Borehole BH7D

Project No. BAR-00025036-A0

Figure No. 11

Project: Clarington TS

Sheet No. 2 of 2

GWL	SYMBOL	Soil Description	ELEV. m	DEPTH m	N Value				Combustible Vapour Reading (ppm)			SAMPLE NO.	Sample Number	
					20	40	60	80	250	500	750			
					Shear Strength kPa				Natural Moisture Content % Atterberg Limits (% Dry Weight)					
			244.43	10										
				11		50 for 102 mm				X				SA10
				12		50 for 127 mm				X				SA11
		Boulders	241.2	13										
		SANDY SILT TILL: Some Gravel, Grey, Damp [Very Dense]		14		50 for 127 mm				X				SA12
		END OF BOREHOLE	239.1	15		50 for 127 mm				X				SA13

BARRIEG BOREHOLE LOGS GPJ NEW GDT 6/18/12

Draft



**exp. Services Inc.**  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from **Exp** before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	4.0	4.7

# Log of Borehole BH8

Project No. BAR-00025036-A0

Figure No. 12

Project: Clarington TS

Sheet No. 1 of 1

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 22, 2012

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading

Natural Moisture


Plastic and Liquid Limit

Undrained Triaxial at

% Strain at Failure

Penetrometer

Datum: \_\_\_\_\_



BARRIEG BOREHOLE LOGS GPJ, NEW, GDT 6/18/12



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	4.3	4.4

# Log of Borehole BH9

Project No. BAR-00025036-A0

Figure No. 13

Project: Clarington TS  
 City/  
 Municipality: Municipality of Clarington, Ontario

Sheet No. 1 of 2

Location: \_\_\_\_\_

Date Drilled: May 18, 2012

Drill Type: Hollow Stem Augers

Datum: \_\_\_\_\_

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading


Natural Moisture

Plastic and Liquid Limit

Undrained Triaxial at

% Strain at Failure

Penetrometer



Continued Next Page



exp. Services Inc.  
 561 Bryne Drive, Unit D  
 Barrie, ON L4N 9Y3  
 t: +1.705.734.6222  
 f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.

See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	2.0	3.6



# Log of Borehole BH9

Project No. BAR-00025036-A0

Figure No. 13

Project: Clarington TS

Sheet No. 2 of 2

SYMBOL L W G	Soil Description	ELEV. m 232.49 232.3	DEPTH m 10 11 12 13 14 15	N Value				Combustible Vapour Reading (ppm)			SAMPLES	Sample Number
				Shear Strength kPa				Natural Moisture Content % Atterberg Limits (% Dry Weight)				
				20	40	60	80	250	500	750		
	<b>SANDY SILT TILL: Some Gravel, Trace Clay, Grey, Damp to Moist</b>  [Very Dense]											
				56				X				SA10
						94		X				SA11
				72				X				SA12
				51				X				SA13
	<b>END OF BOREHOLE</b>	226.8										

BARRIEG BOREHOLE LOGS.GPJ NEW.GDT 6/18/12



**exp. Services Inc.**  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from **Exp** before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	2.0	3.6

# Log of Borehole BH10

Project No. BAR-00025036-A0

Figure No. 14

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 22, 2012

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading

Natural Moisture

Plastic and Liquid Limit

Undrained Triaxial at

% Strain at Failure

Penetrometer

Datum: \_\_\_\_\_

SYMBOL	Soil Description	ELEV. m	DEPTH (m)	N Value				Combustible Vapour Reading (ppm)			SAMPLES	Sample Number	
				20	40	60	80	250	500	750			
	<b>TOPSOIL: Sandy Silt, Dark Brown, Damp</b>	249.87	0										
	<b>SANDY SILT: Topsoil Inclusions, Brown, Moist</b>	249.5	0.5						X				SA1
	[Loose]		1						X				SA2
	<b>SANDY SILT TILL: Trace to Some Gravel, Brown to Grey, Damp to Moist</b>	248.4	2			50 for 127 mm			X				SA3
	[Very Dense]		2.5			50 for 127 mm			X				SA4
			3			50 for 127 mm			X				SA5
	Boulders		4			50 for 50 mm			X				SA6
	Boulders		5										
	Boulders		6			50 for 76 mm			X				SA7
			7										
	Boulders		8			50 for 127 mm			X				SA8
			9			50 for 102 mm			X				SA9
			10										

BARRIEG BOREHOLE LOGS.GPJ NEW.GDT 6/18/12

Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from **Exp** before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	Dry	15.5

# Log of Borehole BH10

Project No. BAR-00025036-A0

Figure No. 14

Project: Clarington TS

Sheet No. 2 of 2

GWL	SYMBOL	Soil Description	ELEV. m	DEPTH m	N Value				Combustible Vapour Reading (ppm)			SAMPLE NUMBER
					20	40	60	80	250	500	750	
			239.87	10	Shear Strength kPa				Natural Moisture Content % Atterberg Limits (% Dry Weight)			
					100				10	20	30	
				11		50 for 102 mm			X			SA10
				12								
				13		50 for 127 mm			X			SA11
			236.6	14				78	X			SA12
				15								
			234.2					95 for 254 mm	X			SA13
		<b>END OF BOREHOLE</b>										
		<b>NOTE:</b> Auger refusal at 5.2 metres; Borehole was moved 0.9 metres west of original location and re-drilled										

BARRIEG BOREHOLE LOGS.GPJ NEW.GDT 6/18/12



**exp. Services Inc.**  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from **Exp** before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	Dry	15.5



# Log of Borehole BH11

Project No. BAR-00025036-A0

Figure No. 15

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 30, 2012

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading

Natural Moisture


Plastic and Liquid Limit

Undrained Triaxial at

% Strain at Failure

Penetrometer

Datum: \_\_\_\_\_



BARRIEG\_BOREHOLE LOGS.GPJ NEW/GDT 6/18/12

Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.

See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	14.8	15.2

# Log of Borehole BH11

Project No. BAR-00025036-A0

Figure No. 15

Project: Clarington TS

Sheet No. 2 of 2

L W G	Soil Description	ELEV. m	D E P T H m	N Value				Combustible Vapour Reading (ppm)			S A M P L E S	Sample Number		
				Shear Strength kPa				Natural Moisture Content % Atterberg Limits (% Dry Weight)						
				20	40	60	80	250	500	750				
		242.71	10		100		200			10	20	30		
	<b>CLAYEY SILT TILL: Some Sand, Some Gravel, Grey, Moist to Wet</b> [Hard]	241.7	11		41				X					SA10
			12		33				X					SA11
			13											
			14		43				X					SA12
	<b>SANDY SILT TILL: Trace to Some Gravel, Trace to Some Clay, Moist to Very Moist</b> [Dense]	237.91	15		38				X					SA13
	<b>END OF BOREHOLE</b>	237.0												
	NOTE: Auger refusal at 5.6 metres; Borehole was moved 0.9 metres west of original location and re-drilled													

BARRIEG\_BOREHOLE LOGS.GPJ NEW.GDT 6/18/12



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires  
interpretation assistance from  
Exp before use by others.  
See Figures 1A and 1B for  
Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	14.8	15.2



# Log of Borehole BH12A

Project No. BAR-00025036-A0

Figure No. 16

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 23, 2012

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading

Natural Moisture


Plastic and Liquid Limit

Undrained Triaxial at

% Strain at Failure

Penetrometer

Datum: \_\_\_\_\_



BARRIEG BOREHOLE LOGS.GPJ NEW.GDT 6/18/12

Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.

See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	2.3	2.3

# Log of Borehole BH12A

Project No. BAR-00025036-A0

Figure No. 16

Project: Clarington TS

Sheet No. 2 of 2

G W L	S Y M B O L	Soil Description	ELEV. m	D E P T H m	N Value				Combustible Vapour Reading (ppm)			S A M P L E S	Sample Number
					Shear Strength kPa				Natural Moisture Content % Atterberg Limits (% Dry Weight)				
					20	40	60	80	250	500	750		
			247.10	10									
		Wet Seams		11		50 for 102 mm				X			SA10
				12		50 for 127 mm				X			SA11
		Boulders		13									
				14		50 for 127 mm							SA12
		Boulders		15									
		END OF BOREHOLE	241.7			50 for 127 mm				X			SA13

BARRIEG BOREHOLE LOGS.GPJ NEW/GDT 6/18/12

Draft



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from exp before use by others.  
See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	2.3	2.3

# Log of Borehole BH12B

Project No. BAR-00025036-A0

Figure No. 17

Project: Clarington TS

Sheet No. 1 of 2

City/  
Municipality: Municipality of Clarington, Ontario

Location: \_\_\_\_\_

Date Drilled: May 31, 2012

Auger Sample

SPT (N) Value

Dynamic Cone Test

Shelby Tube

Field Vane Test

Combustible Vapour Reading

Natural Moisture


Plastic and Liquid Limit

Undrained Triaxial at

% Strain at Failure

Penetrometer

Datum: \_\_\_\_\_



BARRIEG BOREHOLE LOGS.GPJ, NEW.GDT 6/18/12

Continued Next Page



exp. Services Inc.  
561 Bryne Drive, Unit D  
Barrie, ON L4N 9Y3  
t: +1.705.734.6222  
f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.

See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	4.6	5.18



# Log of Borehole BH12B

Project No. BAR-00025036-A0

Figure No. 17

Project: Clarington TS

Sheet No. 2 of 2

Soil Description	ELEV. m	DEPTH m	N Value				Combustible Vapour Reading (ppm)			Sample Number
			Shear Strength kPa				Natural Moisture Content % Atterberg Limits (% Dry Weight)			
			20	40	60	80	250	500	750	
<b>SAND AND SILT: Grey, Wet</b> [Very Dense]	229.50	10								
	229.3									
		11		50 for 127 mm				X		SA10
		12								
		13		51				X		SA11
	226.2									
<b>SANDY SILT TILL: Some Gravel, Grey, Very Moist</b> [Very Dense]		14		50 for 102 mm				X		SA12
		15								
		15		50 for 127 mm				X		SA13
END OF BOREHOLE	224.1									

BARRIEG\_BOREHOLE LOGS.GPJ NEW.GDT 6/18/12

Draft



exp. Services Inc.  
 561 Bryne Drive, Unit D  
 Barrie, ON L4N 9Y3  
 t: +1.705.734.6222  
 f: +1.705.734.6224

Borehole data requires interpretation assistance from Exp before use by others.  
 See Figures 1A and 1B for Notes on Sample Descriptions.

Time	Water Level (m)	Depth to Cave (m)
Upon Completion	4.6	5.18



BOREHOLE No.: BH1-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 12, 2012 DATE (FINISH): November 13, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ⊞ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)		
										Field	Lab	w <sub>p</sub>	w <sub>L</sub>	U <sub>c</sub>	U <sub>L</sub>	10	20	30
GROUND SURFACE																		
1	0.12		TOPSOIL : 120 mm	☒	SS-1	92	34	1-1-2-3	3									
2			FILL : SILT and CLAY, trace gravel, trace topsoil and rootlets, brown, moist to very moist, soft	☒	SS-2	92	12	4-6-11-14	17									
3	0.76		NATIVE : SANDY CLAYEY SILT TILL to SANDY SILTY CLAY TILL, trace to some gravel, oxidized seams, greyish brown, moist to very moist, very stiff to hard	☒	SS-3	100	9	16-33-36-37	69									
4	1.0			☒	SS-4	82	6	31-34-50/125mm	100									
5	1.52		SANDY SILTY CLAY TILL, trace gravel, grey, moist, hard	☒	SS-5	67	5	50/75mm	100									
6	2.0		Cobble fragments	☒	SS-6	67	6	50/75mm	100									
7	2.29			☒	SS-7	100	5	50/125mm	100									
8				☒	SS-8	80	8	40-45-50/75mm	100									
9	3.0			☒	SS-9	91	11	30-50/	100									
10																		
11																		
12																		
13	4.0																	
14																		
15	5.0																	
16																		
17																		
18																		
19	6.0																	
20																		
21																		
22																		
23	7.0																	
24																		
25																		
26	8.0																	
27																		
28																		
29	9.0																	
30																		

SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/20/12

WL2.9  
11/13/2012





BOREHOLE No.: BH1-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 12, 2012 DATE (FINISH): November 13, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)			
										△ Field	□ Lab	w <sub>p</sub>	w <sub>L</sub>	10	20	30	40	50	60
Feet	Metres		GROUND SURFACE			%			N										
32								125mm											
33	10.0																		
34																			
35																			
36	11.0			☒	SS-10	100	8	16-24-50/ 100mm	100	○								●	
37																			
38																			
39																			
40	12.0																		
41				☒	SS-11	100	8	33-44-50/ 125mm	100	○									●
42																			
43	13.0																		
44																			
45																			
46	14.0			☒	SS-12	100	9	26-47-50/ 75mm	100	○									●
47																			
48																			
49	15.0																		
50																			
51	15.67			☒	SS-13	88	9	26-37-50/ 125mm	100	○									●
52	16.0		<b>END OF BOREHOLE</b>																
53			NOTE :																
54			End of Borehole at 15.67 m bgs																
55			Water level at 2.88 m bgs upon completion																
56	17.0		Borehole caved to 14.8 m depth																
57			bgs denotes below ground surface																
58																			
59	18.0																		
60																			
61																			
62																			

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ\_INSPEC\_SOL.GDT\_12/20/12



BOREHOLE No.: BH2-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station


LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 14, 2012 DATE (FINISH): November 14, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL



SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ INSPEC\_SOL.GDT 12/20/12

WLO.2  
11/19/2012  
0.3 m

Bentonite Seal

22-27-27-35



**BOREHOLE No.:** BH2-12  
**ELEVATION:** \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

**CLIENT:** Hydro One Networks Inc.

**PROJECT:** Geotechnical Investigation - Clarington Transformer Station

**LOCATION:** Townline Road North and Concession Road #7, Clarington, Ontario

**DESCRIBED BY:** R. Khabbaznia **CHECKED BY:** F. Bagheri

**DATE (START):** November 14, 2012 **DATE (FINISH):** November 14, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)		Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)		△ Field	□ Lab	
	Feet	Metres									w <sub>p</sub>	w <sub>L</sub>	10	20	30	40	50	60	70	80	90
				GROUND SURFACE			%			N											
32					☒	SS-9	92	--		54											
33	10.0																				
34																					
35																					
36	11.0					☒	SS-10	88	--	23-40-50/ 125mm	100										
37																					
38																					
39																					
40	12.0																				
41						☒	SS-11	100	--	26-36-50/ 125mm	100										
42																					
43	13.0																				
44																					
45																					
46	14.0				☒	SS-12	100	--	14-25-26-30	51											
47																					
48																					
49	15.0																				
50																					
51	15.85				☒	SS-13	100	--	16-24-34-47	58											
52	16.0																				
53																					
54																					
55																					
56	17.0																				
57																					
58																					
59	18.0																				
60																					
61																					
62																					

**END OF BOREHOLE**

NOTE :  
 End of Borehole at 15.85 m bgs  
 Water level at 14.85 m bgs upon completion  
 Water level at 0.16 m bgs on November 19, 2012  
 A monitoring well installed at 15.21 m depth  
 bgs denotes below ground surface  
 Sa, Gr, Si and Cl denote Sand, Gravel, Silt and Clay respectively

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ\_INSPEC\_SOL.GDT\_12/20/12



BOREHOLE No.: BH3-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station


LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 6, 2012 DATE (FINISH): November 7, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL



SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ\_INSPEC\_SOL.GDT 12/20/12

WL6.5  
11/7/2012



BOREHOLE No.: BH3-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 6, 2012 DATE (FINISH): November 7, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth		Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)	Water content (%)	Atterberg limits (%)	"N" Value (blows / 12 in.-30 cm)	Field	Lab					
Feet	Metres					%					w <sub>p</sub>	w <sub>L</sub>		△	□					
				GROUND SURFACE				150mm	N		10	20	30	40	50	60	70	80	90	
32																				
	10.0																			
33																				
34																				
35																				
36	11.0				SS-10	100	7	14-24-20-35	44											
37																				
38																				
39																				
40	12.0																			
41					SS-11	87	8	27-45-45-50/ 125mm	100											
42	12.96			Possible boulder																
43	13.0																			
44				<b>END OF BOREHOLE</b>																
45				NOTE :																
46	14.0			End of Borehole at 12.96 m bgs due to auger refusal																
47				Water level at 6.50 m bgs upon completion																
48				bgs denotes below ground surface																
49	15.0																			
50																				
51																				
52	16.0																			
53																				
54																				
55																				
56	17.0																			
57																				
58																				
59	18.0																			
60																				
61																				
62																				

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ INSPEC\_SOL.GDT 12/20/12





BOREHOLE No.: BH4-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 5, 2012 DATE (FINISH): November 5, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		△ Field						
										w <sub>p</sub>	w <sub>L</sub>	□ Lab						
GROUND SURFACE																		
0.10			TOPSOIL : 100 mm			%			N	10	20	30	40	50	60	70	80	90
1	0.10		FILL : SILT and CLAY, trace gravel, trace topsoil and rootlets, brown, moist, firm	☒	SS-1	100	9	1-2-2-4	4	●								
2	0.76		NATIVE : SANDY CLAYEY SILT TILL, trace gravel, cobble fragments, brown, moist, very stiff to hard	☒	SS-2	92	9	6-8-15-20	23	○								
3	1.0			☒	SS-3	100	7	17-28-44-50/125mm	72	○								
4			Greyish brown	☒	SS-4	91	5	35-50/125mm	100	○								
5	2.0			☒	SS-5	50	5	50/150mm	100	○								
6			Cobble/boulder (inferred) Auger grinding at 3.66 m bgs															
7	3.0			☒	SS-6	80	5	48-50/75mm	100	○								
8	3.66																	
9	4.0		Grey	☒	SS-7	78	6	35-45-50/150mm	100	○								
10	4.57																	
11	5.0		Auger grinding at 6.1 m bgs	☒	SS-8	100	5	20-30-45-50/150mm	75	○								
12	6.0																	
13	7.0			☒														
14	8.0			☒														
15	9.0			☒														
16				☒														
17				☒														
18				☒														
19				☒														
20				☒														
21				☒														
22				☒														
23				☒														
24				☒														
25				☒														
26				☒														
27				☒														
28				☒														
29				☒														
30				☒														

SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12

Bentonite Grout  
0.6 m

Bentonite Seal

20-32-42-48



BOREHOLE No.: BH4-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 5, 2012 DATE (FINISH): November 5, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		△ Field
										w <sub>p</sub>	w <sub>L</sub>	□ Lab
GROUND SURFACE												
32				☒	SS-9	100	6		74			
33	10.0											
34												
35												
36	11.0			☒	SS-10	100	6	14-25-30-50/ 125mm	100			
37												
38												
39												
40	12.0											
41				☒	SS-11	83	7	22-50/ 150mm	100			
42												
43	13.0											
44												
45			Auger grinding at 13.72 m bgs									
46	14.0			☒	SS-12	88	6	24-41-50/ 125mm	100			
47												
48												
49	15.0											
50			Cobble fragments									
51	15.49			☒	SS-13	80	8	21-50/ 100mm	100			
52			<b>END OF BOREHOLE</b>									
53	16.0		NOTE :									
54			End of Borehole at 15.49 m bgs									
55			Borehole open and dry upon completion									
56	17.0		Borehole dry on November 19, 2012									
57			Monitoring well installed at 15.49 m bgs									
58			bgs denotes below ground surface									
59	18.0											
60												
61												
62												

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ\_INSPEC\_SOL.GDT\_12/19/12

11.8 m Sand

Screen

15.5 m



BOREHOLE No.: BH5-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station


LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 15, 2012 DATE (FINISH): November 15, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL



SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12



BOREHOLE No.: BH5-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 15, 2012 DATE (FINISH): November 15, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth		Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)	Water content (%)	Atterberg limits (%)	"N" Value (blows / 12 in.-30 cm)	Field	Lab							
Feet	Metres			GROUND SURFACE			%			N		w <sub>p</sub>	w <sub>L</sub>		10	20	30	40	50	60	70	80	90
32					☒	SS-9	33	7		43													
33	10.0																						
34																							
35																							
36	11.0				☒	SS-10	58	8	10-17-40-48	57													
37																							
38																							
39																							
40	12.0																						
41					☒	SS-11	73	10	20-50/125mm	100													
42																							
43	13.0																						
44																							
45																							
46	14.0																						
47																							
48																							
49	15.0																						
50																							
51	15.49				☒	SS-12	80	10	25-50/100mm	100													
52																							
53	16.0																						
54																							
55																							
56	17.0																						
57																							
58																							
59	18.0																						
60																							
61																							
62																							

**END OF BOREHOLE**

NOTE :  
 End of Borehole at 15.49 m bgs  
 Borehole open and dry upon completion  
 bgs denotes below ground surface

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ\_INSPEC\_SOL.GDT 12/19/12





BOREHOLE No.: BH6-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 6, 2012 DATE (FINISH): November 6, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)			
										Field	Lab	w <sub>p</sub>	w <sub>L</sub>	U <sub>c</sub>	U <sub>L</sub>	10	20	30	40
GROUND SURFACE										N									
0.08			TOPSOIL : 80 mm			%													
1			FILL : SILTY CLAY, trace to some gravel, trace topsoil and rootlets, brown, moist, firm to stiff	☒	SS-1	100	25	1-2-3-2	5										
2			Brown to grey	☒	SS-2A	--	13	--	11										
3	0.86			☒	SS-2B	58	7	1-2-9-17	11										
4	1.0		NATIVE : SANDY CLAYEY SILT TILL, trace to some gravel, cobble fragments, brownish grey, hard	☒	SS-3	100	7	21-36-50/125mm	100										
5	1.52			☒	SS-4	80	6	36-50/100mm	100										
6	2.0			☒	SS-5	80	6	48-50/100mm	100										
7				☒	SS-6	80	8	48-50/100mm	100										
8				Grey	☒	SS-7	91	6	35-50/125mm	100									
9			Cobble fragments	☒	SS-8	100	6	50/25mm	100										
10	3.0			☒	SS-9	100	7	21-30-50/	100										
11			Auger grinding at 7.32 m to 7.62 m bgs																
12																			
13	4.0																		
14																			
15	4.57																		
16	5.0																		
17																			
18																			
19																			
20	6.0																		
21	6.10																		
22																			
23	7.0																		
24	7.32																		
25																			
26	8.0																		
27																			
28																			
29	9.0																		
30																			

SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/20/12



BOREHOLE No.: BH6-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 6, 2012 DATE (FINISH): November 6, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth		Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)	Water content (%)	Atterberg limits (%)	"N" Value (blows / 12 in.-30 cm)	Field	Lab
Feet	Metres						%			N		w <sub>p</sub>	w <sub>L</sub>		△	□
				GROUND SURFACE												
32									125mm							
33	10.0															
34																
35																
36	11.0				☒	SS-10	100	6	27-50/ 75mm	100	○			●		
37																
38																
39																
40	12.0															
41					☒	SS-11	75	6	28-45-50/ 100mm	100	○			●		
42																
43	13.0															
44																
45	13.72			Some gravel, cobble fragments												
46	14.0				☒	SS-12	100	5	25-30-50/ 150mm	100	○			●		
47																
48																
49	15.0															
50																
51	15.55				☒	SS-13	83	6	26-50/ 150mm	100	○			●		
52	16.0			<b>END OF BOREHOLE</b>												
53				NOTE : End of Borehole at 15.55 m bgs Borehole open and dry upon completion bgs denotes below ground surface												
54																
55																
56	17.0															
57																
58																
59	18.0															
60																
61																
62																

SOIL LOG WITH GRAPH+WELL. T040774A1.GPJ INSPEC\_SOL.GDT 12/20/12



BOREHOLE No.: BH7-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station


LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 5, 2012 DATE (FINISH): November 5, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL



SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12



BOREHOLE No.: BH7-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 5, 2012 DATE (FINISH): November 5, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		△ Field
									w <sub>p</sub>	w <sub>L</sub>	□ Lab
			GROUND SURFACE		%			N	10 20 30 40 50 60 70 80 90		
32							125mm				
33	10.0										
34											
35											
36	11.0			SS-10	100	8	25-38-50/125mm	100	○		●
37											
38											
39											
40	12.0										
41				SS-11	100	8	28-42-50/125mm	100	○		●
42											
43	13.0										
44											
45											
46	14.0			SS-12	100	7	23-30-38-49	68	○		●
47											
48											
49	15.0										
50											
51											
52	15.85			SS-13	100	8	22-37-48-50	85	○		●
53	16.0										
54											
55											
56	17.0										
57											
58											
59	18.0										
60											
61											
62											

**END OF BOREHOLE**

NOTE :  
 End of Borehole at 15.85 m bgs  
 Water level at 15.2 m bgs upon completion  
 bgs denotes below ground surface

WL 15.2  
 11/5/2012

SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12





BOREHOLE No.: BH8-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station


LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 15, 2012 DATE (FINISH): November 15, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL



SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/20/12



BOREHOLE No.: BH8-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 15, 2012 DATE (FINISH): November 15, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)		
										△ Field	□ Lab	w <sub>p</sub>	w <sub>L</sub>	U <sub>c</sub>	U <sub>L</sub>	10	20	30
Feet	Metres		GROUND SURFACE			%				N								
32																		
33	10.0																	
34																		
35																		
36	11.0			☒	SS-10	55	10	30-50/ 125mm	100	○								
37																		
38																		
39																		
40	12.20		Auger grinding	☒	SS-11	100	10	50/ 150mm	100	○								
41																		
42																		
43	13.0																	
44																		
45																		
46	14.0			☒	SS-12	91	9	44-50/ 125mm	100	○								
47																		
48																		
49	15.0																	
50																		
51	15.67			☒	SS-13	88	8	22-45-50/ 125mm	100	○								
52	16.0		<b>END OF BOREHOLE</b>															
53			NOTE :															
54			End of Borehole at 15.67 m bgs															
55			Borehole open and dry upon completion															
56	17.0		Sa, Gr, Si and Cl denote Sand, Gravel, Silt and Clay respectively															
57			bgs denotes below ground surface															
58																		
59	18.0																	
60																		
61																		
62																		

SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/20/12



BOREHOLE No.: BH9-12

ELEVATION:

BOREHOLE REPORT

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 9, 2012 DATE (FINISH): November 12, 2012

LEGEND

- SS - SPLIT SPOON
- ST - SHELBY TUBE
- AU - AUGER PROBE
- WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)				△ Field							
									w <sub>p</sub>	w <sub>L</sub>	Atterberg limits (%)		□ Lab							
Feet	Metres	GROUND SURFACE							N	10	20	30	40	50	60	70	80	90		
1	0.12	<p>TOPSOIL : 120 mm</p> <p>FILL : SANDY CLAYEY SILT, trace gravel, trace topsoil and rootlets, brown, moist, soft</p> <p>NATIVE : SANDY CLAYEY SILT TILL to SANDY SILTY CLAY TILL, trace to some gravel, cobble fragments, oxidized seams, brownish grey, moist to very moist, stiff</p> <p>Hard, grey</p> <p>Auger grinding</p>	SS-1	83	30	1-1-2-2	3													
2	0.76		SS-2	100	11	2-6-6-11	12													
3	1.0		SS-3	92	11	4-5-8-7	13													
4	2.0		SS-4	67	9	4-7-9-9	16													
5	3.0		SS-5	84	7	10-12-20-50/25mm	32													
6	3.05																			
7	4.0																			
8	3.81																			
9	4.0																			
10	5.0																			
11	6.0																			
12	3.81																			
13	4.0																			
14	5.0																			
15	6.0																			
16	5.0																			
17	7.0																			
18	6.0																			
19	7.0																			
20	6.0																			
21	7.0																			
22	6.0																			
23	7.0																			
24	6.0																			
25	7.0																			
26	8.0																			
27	8.0																			
28	9.0																			
29	9.0																			
30	9.0																			

SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12



BOREHOLE No.: BH9-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 9, 2012 DATE (FINISH): November 12, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)		Field	Lab	
										w <sub>p</sub>	w <sub>L</sub>	U <sub>c</sub>	U <sub>L</sub>	10	20	30	40	50	60	70
Feet	Metres		GROUND SURFACE			%			N											
32				☒	SS-9	92	8		80											
33	10.0																			
34																				
35	10.67		Sand seams																	
36	11.0			☒	SS-10	100	6	10-20-25-24	45	○										
37																				
38																				
39	12.0																			
40																				
41				☒	SS-11	100	7	11-16-22-32	48	○										
42																				
43	13.0																			
44																				
45																				
46	14.0			☒	SS-12	100	7	15-22-28-37	50	○										
47																				
48																				
49	15.0																			
50																				
51				☒	SS-13	100	8	16-23-25-42	58	○										
52	15.85																			
53	16.0		<b>END OF BOREHOLE</b>																	
54			NOTE :																	
55			End of Borehole at 15.85 m bgs																	
56	17.0		Water level at 14.45 m bgs upon completion																	
57			bgs denotes below ground surface																	
58																				
59	18.0																			
60																				
61																				
62																				

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12

WL14.5  
11/12/2012





**BOREHOLE No.:** BH10-12  
**ELEVATION:** \_\_\_\_\_


**BOREHOLE REPORT**

Page: 1 of 2

**CLIENT:** Hydro One Networks Inc.  
**PROJECT:** Geotechnical Investigation - Clarington Transformer Station  
**LOCATION:** Townline Road North and Concession Road #7, Clarington, Ontario  
**DESCRIBED BY:** R. Khabbaznia      **CHECKED BY:** F. Bagheri  
**DATE (START):** November 7, 2012      **DATE (FINISH):** November 7, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ⊓ AU - AUGER PROBE
- ▼ - WATER LEVEL



SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12



BOREHOLE No.: BH10-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 7, 2012 DATE (FINISH): November 7, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)		
										△ Field	□ Lab	w <sub>p</sub>	w <sub>L</sub>	U <sub>c</sub>	U <sub>L</sub>	10	20	30
Feet	Metres		GROUND SURFACE			%			N									
32				☒	SS-9	100	6		40									
33	10.0																	
34																		
35																		
36	11.0			☒	SS-10	100	6	9-12-13-22	25									
37																		
38																		
39																		
40	12.0																	
41				☒	SS-11	100	7	10-14-18-23	32									
42																		
43	13.0																	
44																		
45																		
46	14.0			☒	SS-12	100	7	16-18-21-33	39									
47																		
48																		
49	15.0																	
50																		
51				☒	SS-13	100	6	11-24-27-37	51									
52	15.85																	
53	16.0																	
54																		
55																		
56	17.0																	
57																		
58																		
59	18.0																	
60																		
61																		
62																		

**END OF BOREHOLE**

NOTE :  
 End of Borehole at 15.85 m bgs  
 Borehole open and dry upon completion  
 bgs denotes below ground surface

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ\_INSPEC\_SOL.GDT 12/19/12



BOREHOLE No.: BH11-12

ELEVATION: \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station


LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 8, 2012 DATE (FINISH): November 9, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL



SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/20/12



**BOREHOLE No.:** BH11-12  
**ELEVATION:** \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

**CLIENT:** Hydro One Networks Inc.

**PROJECT:** Geotechnical Investigation - Clarington Transformer Station

**LOCATION:** Townline Road North and Concession Road #7, Clarington, Ontario

**DESCRIBED BY:** R. Khabbaznia **CHECKED BY:** F. Bagheri


**DATE (START):** November 8, 2012 **DATE (FINISH):** November 9, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth		Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)	Water content (%)	Atterberg limits (%)	"N" Value (blows / 12 in.-30 cm)	Field	Lab
Feet	Metres						%			N				10 20 30 40 50 60 70 80 90		
				GROUND SURFACE												
32																
	10.0															
35		10.67		Auger grinding	☒	SS-10	100	11	50/125mm	100						
36		11.0														
37																
38																
39		12.0														
40																
41																
42																
43		13.0														
44																
45		13.72														
46		14.0		SILT and SAND, trace to some gravel, grey, very moist to saturated, compact to very dense	☒	SS-12	67	17	3-5-15-18	20						
47																
48																
49		15.0														
50																
51		15.49		Very dense	☒	SS-13	100	15	40-50/100mm	100						
52		16.0		<b>END OF BOREHOLE</b>												
53				NOTE :												
54				End of Borehole at 15.49 m bgs												
55				A 50 mm diameter monitoring well installed at 14.80 m bgs												
56				Water level at 3.12 m bgs upon completion												
57		17.0		Water level at 0.91 m above ground level on November 19, 2012												
58				bgs denotes below ground surface												
59		18.0														
60																
61																
62																

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ\_INSPEC\_SOL.GDT 12/20/12







**BOREHOLE No.:** BH12-12  
**ELEVATION:** \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

**CLIENT:** Hydro One Networks Inc.

**PROJECT:** Geotechnical Investigation - Clarington Transformer Station

**LOCATION:** Townline Road North and Concession Road #7, Clarington, Ontario

**DESCRIBED BY:** R. Khabbaznia **CHECKED BY:** F. Bagheri

**DATE (START):** November 7, 2012 **DATE (FINISH):** November 8, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)		
										Field	Lab	w <sub>p</sub>	w <sub>L</sub>	U <sub>c</sub>	U <sub>L</sub>	10	20	30
GROUND SURFACE																		
0.12			TOPSOIL : 120 mm															
1			FILL : SANDY SILTY CLAY, trace gravel, topsoil/organics and rootlets, dark brown, very moist, soft		SS-1	100	29	2-2-2-3	4									
2																		
3	0.76		Sand layer, brown, wet, stiff		SS-2	33	15	2-7-8-4	15									
4	1.0																	
5	1.52		NATIVE : SANDY CLAYEY SILT to SANDY SILTY CLAY TILL, some gravel, oxidized seams, brown, moist to very moist, stiff		SS-3	67	12	2-5-6-9	11									
6	2.0																	
7	2.29		Cobble fragments, brownish grey, hard		SS-4	100	9	10-33-50/125mm	100									
8																		
9																		
10	3.0		Grey, sand pockets, very stiff		SS-5	86	19	10-12-17-23	29									
11	3.05																	
12																		
13	4.0																	
14																		
15	4.57		Hard		SS-6	100	10	50/100mm	100									
16	5.0																	
17																		
18																		
19																		
20	6.0		Auger grinding		SS-7	67	10	40-50/75mm	100									
21																		
22																		
23	7.0																	
24																		
25																		
26	8.0																	
27																		
28																		
29	9.0																	
30			Sand pockets, cobble fragments		SS-9	91	12	20-50/	100									

SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12



**BOREHOLE No.:** BH12-12  
**ELEVATION:** \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

**CLIENT:** Hydro One Networks Inc.

**PROJECT:** Geotechnical Investigation - Clarington Transformer Station

**LOCATION:** Townline Road North and Concession Road #7, Clarington, Ontario

**DESCRIBED BY:** R. Khabbaznia **CHECKED BY:** F. Bagheri

**DATE (START):** November 7, 2012 **DATE (FINISH):** November 8, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)		
										Field	Lab	w <sub>p</sub>	w <sub>L</sub>	10	20	30	40	50
			GROUND SURFACE			%			N									
32								125mm										
33	10.0																	
34																		
35				☒	SS-10	100	14	50/125mm	100									
36	11.0																	
37																		
38																		
39																		
40	12.0		Stone fragments	☒	SS-11	100	10	50/125mm	100									
41																		
42																		
43	13.0																	
44																		
45			Auger grinding	☒	SS-12	100	9	50/125mm	100									
46	14.0																	
47																		
48																		
49	15.0																	
50	15.37			☒	SS-13	60	11	50/125mm	100									
51			<b>END OF BOREHOLE</b>															
52			NOTE :															
53			End of Borehole at 15.37 m bgs															
54			Water level at 15.02 m bgs upon completion															
55			bgs denotes below ground surface															
56	17.0																	
57																		
58																		
59	18.0																	
60																		
61																		
62																		

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ\_INSPEC\_SOL.GDT 12/19/12

WL 15.0  
11/8/2012



**BOREHOLE No.:** BH13-12  
**ELEVATION:** \_\_\_\_\_

**BOREHOLE REPORT**

Page: 1 of 2

**CLIENT:** Hydro One Networks Inc.

**PROJECT:** Geotechnical Investigation - Clarington Transformer Station


**LOCATION:** Townline Road North and Concession Road #7, Clarington, Ontario

**DESCRIBED BY:** R. Khabbaznia **CHECKED BY:** F. Bagheri

**DATE (START):** November 13, 2012 **DATE (FINISH):** November 13, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ⊞ AU - AUGER PROBE
- ▼ - WATER LEVEL



SOIL LOG WITH GRAPH+WELL T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12



**BOREHOLE No.:** BH13-12  
**ELEVATION:** \_\_\_\_\_

**BOREHOLE REPORT**

Page: 2 of 2

CLIENT: Hydro One Networks Inc.

PROJECT: Geotechnical Investigation - Clarington Transformer Station

LOCATION: Townline Road North and Concession Road #7, Clarington, Ontario

DESCRIBED BY: R. Khabbaznia CHECKED BY: F. Bagheri

DATE (START): November 13, 2012 DATE (FINISH): November 13, 2012

**LEGEND**

- ☒ SS - SPLIT SPOON
- ▨ ST - SHELBY TUBE
- ▮ AU - AUGER PROBE
- ▼ - WATER LEVEL

Depth	Elevation (m)	Stratigraphy	DESCRIPTION OF SOIL AND BEDROCK	State	Type and Number	Recovery	Moisture Content	Blows per 6 in. / 15 cm or RQD	Penetration Index/SCR	Shear test (Cu) Sensitivity (S)		Water content (%)		Atterberg limits (%)		"N" Value (blows / 12 in.-30 cm)		
										Field	Lab	w <sub>p</sub>	w <sub>L</sub>	10	20	30	40	50
Feet	Metres		GROUND SURFACE			%			N									
32								100mm										
33	10.0																	
34	10.21		Auger grinding															
35				☒	SS-10	100	4	50/125mm	100	○								
36	11.0																	
37																		
38																		
39	12.0																	
40				☒	SS-11	100	11	50/125mm	100	○								
41																		
42																		
43	13.0		Clay pockets															
44	13.11		Auger grinding															
45				☒	SS-12	100	10	50/125mm	100	○								
46	14.0																	
47																		
48																		
49	15.0																	
50			Trace sand and gravel, grey, very moist	☒	SS-13	100	8	25-30-47-45	77	○								
51																		
52	15.85																	
53	16.0		<b>END OF BOREHOLE</b>															
54			NOTE :															
55			End of Borehole at 15.85 m bgs															
56	17.0		Water level at 1.08 m bgs upon completion															
57			bgs denotes below ground surface															
58																		
59	18.0																	
60																		
61																		
62																		

SOIL LOG WITH GRAPH+WELL\_T040774A1.GPJ INSPEC\_SOL.GDT 12/19/12





# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Appendix C Water Well Records  
March 10, 2014

## Appendix C Water Well Records



**C1: WELL USE DETAILS**

Well ID	Zone	Easting	Northing	Well Type	Well Use	Date Constructed
1901742	17	673953	4872757	Water Supply	Livestock	3/2/1954
1902984	17	674155	4872223	Water Supply	Domestic	11/11/1970
1903352	17	673715	4872773	Water Supply	Domestic	2/18/1972
1903511	17	674165	4872313	Water Supply	Domestic	6/6/1972
1903520	17	674055	4872093	Water Supply	Domestic	12/29/1972
1904535	17	673575	4872943	Water Supply	Domestic	11/1/1976
1905014	17	673295	4873063	Water Supply	Domestic	10/16/1977
1905307	17	674115	4872323	Water Supply	Domestic	4/27/1979
1907905	17	673381	4872974	Water Supply	Domestic	9/1/1986
1909285	17	673454	4873111	Water Supply	Domestic	7/29/1988
1910299	17	673699	4872803	Water Supply	Domestic	11/22/1989
1912514	17	673672	4872041	Water Supply	Domestic	7/20/1995
1912622	17	673412	4872031	Water Supply	Domestic	10/26/1995
4600450	17	672430	4871780	Water Supply	Livestock	5/18/1959
4600451	17	672589	4871849	Water Supply	Domestic	11/16/1959
1916307	17	673452	4873111	Water Supply	Domestic	9/26/2002
1918378	17	672999	4872014	Water Supply	Domestic	6/19/2006
7102525	17	672820	4871777	Observation Well	Monitoring	12/19/2007
7128981	17	673438	4872158	Water Supply	unknown	1/1/2009
7157947	17	673849	4872145	Water Supply	Domestic	11/19/2010

**C2: WELL STRATIGRAPHY**

Well ID	Zone	Easting	Northing	Ground Elev. (m AMSL)	Formation Top (m BGS)	Formation Base (m BGS)	Formation Top (m AMSL)	Formation Base (m AMSL)	Primary Material	Secondary Material	Tertiary Material	Material Colour
1901742	17	673953	4872757	248.19	68.58	68.88	179.61	179.30	GRAVEL	-	-	
1902984	17	674155	4872223	231.64	6.10	10.36	225.55	221.28	MEDIUM SAND	STONES	GRAVEL	BROWN
1903352	17	673715	4872773	241.42	13.72	15.24	227.70	226.18	GRAVEL	SAND	-	BROWN
1903511	17	674165	4872313	233.15	8.84	9.75	224.31	223.39	COARSE SAND	-	-	GREY
1903520	17	674055	4872093	228.62	7.62	8.23	221.00	220.39	SAND	GRAVEL	-	GREY
1904535	17	673575	4872943	250.57	2.44	2.74	248.13	247.83	GRAVEL	WATER-BEARING	-	
1905014	17	673295	4873063	269.46	96.93	97.54	172.53	171.92	GRAVEL	-	-	BLUE
1905307	17	674115	4872323	234.16	56.39	58.22	177.77	175.95	SAND	GRAVEL	LOOSE	BROWN
1907905	17	673381	4872974	268.39	104.24	108.20	164.15	160.19	MEDIUM SAND	FINE SAND	-	GREY
1909285	17	673454	4873111	260.39	13.72	14.33	246.67	246.06	SAND	WATER-BEARING	-	GREY
1910299	17	673699	4872803	242.56	64.62	65.84	177.94	176.72	COARSE SAND	WATER-BEARING	LOOSE	BROWN
1912514	17	673672	4872041	241.07	57.91	60.96	183.16	180.11	GRAVEL	SAND	-	GREY
1912622	17	673412	4872031	251.31	65.23	67.06	186.09	184.26	SAND	GRAVEL	-	BROWN
4600450	17	672430	4871780	232.87	13.41	19.20	219.46	213.67	GRAVEL	COARSE SAND	MEDIUM SAND	
4600451	17	672589	4871849	226.66	21.34	22.56	205.33	204.11	GRAVEL	-	-	
1916307	17	673452	4873111	260.54	70.41	71.63	190.13	188.91	SAND	-	-	GREY
1918378	17	672999	4872014	230.17	47.85	49.07	182.32	181.10	GRAVEL	WATER-BEARING	-	BROWN
7102525	17	672820	4871777	221.51	10.70	13.72	210.81	207.79	SAND	SILTY	CLAY	GREY
7128981	17	673438	4872158	251.91	7.62	11.43	244.29	240.48	CLAY	SILT	STONES	GREY
7157947	17	673849	4872145	-	17.68	18.90	-	-	MEDIUM SAND	-	LOOSE	BROWN



**C3: WELL SCREEN DETAILS**

Well ID	Zone	Easting	Northing	Ground Elev. (m AMSL)	Screen Top (m BGS)	Screen Bottom (m BGS)	Screen Top (m AMSL)	Screen Bottom (m AMSL)
1901742	17	673953	4872757	248.19	-	-	-	-
1902984	17	674155	4872223	231.64	-	-	-	-
1903352	17	673715	4872773	241.42	-	-	-	-
1903511	17	674165	4872313	233.15	-	-	-	-
1903520	17	674055	4872093	228.62	-	-	-	-
1904535	17	673575	4872943	250.57	-	-	-	-
1905014	17	673295	4873063	269.46	-	-	-	-
1905307	17	674115	4872323	234.16	55.17	56.39	178.99	177.77
1907905	17	673381	4872974	268.39	106.98	108.20	161.41	160.19
1909285	17	673454	4873111	260.39	-	-	-	-
1910299	17	673699	4872803	242.56	64.62	65.84	177.94	176.72
1912514	17	673672	4872041	241.07	59.74	60.96	181.33	180.11
1912622	17	673412	4872031	251.31	65.84	67.06	185.48	184.26
4600450	17	672430	4871780	232.87	17.98	19.20	214.89	213.67
4600451	17	672589	4871849	226.66	-	-	-	-
1916307	17	673452	4873111	260.54	70.41	71.63	190.13	188.91
1918378	17	672999	4872014	230.17	47.85	49.07	182.32	181.10
7102525	17	672820	4871777	221.51	-	-	-	-
7128981	17	673438	4872158	251.91	-	-	-	-
7157947	17	673849	4872145	-	17.68	18.90	-	-

**C4: WATER LEVEL DATA**

Well ID	Zone	Easting	Northing	Ground Elev. (m AMSL)	Static Water Level (m BGS)	Static Water Elev. (m BGS)	Date Constructed
1901742	17	673953	4872757	248.19	44.20	203.99	3/2/1954
1902984	17	674155	4872223	231.64	8.53	223.11	11/11/1970
1903352	17	673715	4872773	241.42	7.32	234.10	2/18/1972
1903511	17	674165	4872313	233.15	3.35	229.79	6/6/1972
1903520	17	674055	4872093	228.62	7.62	221.00	12/29/1972
1904535	17	673575	4872943	250.57	2.44	248.13	11/1/1976
1905014	17	673295	4873063	269.46	49.38	220.08	10/16/1977
1905307	17	674115	4872323	234.16	27.43	206.73	4/27/1979
1907905	17	673381	4872974	268.39	46.33	222.06	9/1/1986
1909285	17	673454	4873111	260.39	2.13	258.26	7/29/1988
1910299	17	673699	4872803	242.56	28.96	213.60	11/22/1989
1912514	17	673672	4872041	241.07	32.00	209.06	7/20/1995
1912622	17	673412	4872031	251.31	38.40	212.91	10/26/1995
4600450	17	672430	4871780	232.87	5.49	227.38	5/18/1959
4600451	17	672589	4871849	226.66	9.14	217.52	11/16/1959
1916307	17	673452	4873111	260.54	38.10	222.44	9/26/2002
1918378	17	672999	4872014	230.17	19.20	210.97	6/19/2006
7102525	17	672820	4871777	221.51	-	-	12/19/2007
7128981	17	673438	4872158	251.91	-	-	1/1/2009
7157947	17	673849	4872145	-	-	-	11/19/2010

# HYDROGEOLOGIC & HYDROLOGIC ASSESSMENT REPORT CLARINGTON TRANSFORMER STATION

Appendix D Hydrology  
March 10, 2014

## Appendix D Hydrology



Existing Conditions

Soil Type  
 Loam/Muck

Hydrologic Soil Group  
 B

TABLE OF CURVE NUMBERS (CN's)									Source
Land Use	Hydrologic Soil Type								
	A	AB	B	BC	C	CD	D		
Meadow "Good"	30	44	58	64.5	71	74.5	78	MTO	
Woodlot "Fair"	36	48	60	66.5	73	76	79	MTO	
Lawns "Good"	39	50	61	67.5	74	77	80	USDA	
Pasture/Range	58	61.5	65	70.5	76	78.5	81	MTO	
Crop	66	70	74	78	82	84	86	MTO	
Gravel	76	80.5	85	87	89	90	91	Chin	
Bare Soil (Fallow)	77	81.5	86	88.5	91	92.5	94	MTO	
Impervious	98	98	98	98	98	98	98	MTO	

MTO - Ministry of Transportation Ontario Drainage Manual (1997), Design Chart 1.09-Soil/Land Use Curve Numbers

USDA - United States Department of Agriculture (2004), National Engineering Handbook, Part 630 Hydrology,

Chapter 9 Hydrologic Soil Cover Complexes

Chin - Water-Resources Engineering (2000), David A. Chin, Table 6.13 Curve Numbers for Various Urban Land Uses

HYDROLOGIC SOIL TYPE (%) - Existing Conditions								
Catchment	Hydrologic Soil Type							TOTAL
	A	AB	B	BC	C	CD	D	
100			100					100
101			100					100
102			100					100
103			100					100

LAND USE (%) - Existing Conditions									
Catchment	Meadow	Woodlot	Lawns	Pasture Range	Crop	Gravel	Bare Soil	Impervious	Total
100		20.0			80				100.0
101		10.0			90				100.0
102		5.0			95				100.0
103		5.0			95				100.0

CURVE NUMBER (CN) - Existing Conditions										
Catchment	Meadow	Woodlot	Lawns	Pasture Range	Crop	Gravel	Bare Soil	Impervious	Weighted CN w/ imp area	Weighted CN w/o imp area
100		12.0			59.2				71	71
101		6.0			66.6				73	73
102		3.0			70.3				73	73
103		3.0			70.3				73	73

Notes:

AMC II assumed

Hydrological Soil Groups taken from MTO Drainage Manual

\*\* Catchments with impervious greater than 20% - only pervious portions used for CN calculation



Hydro One Networks Inc. Clarington - 1609-60745  
 SWMHYMO Parameters

Existing Conditions

Catchment Number	Outlet	SWMHYMO Command	Area (ha)	CN	TIMP	XIMP	Rise (m)	Length (m)	Slope (%)	Tc (hrs)	Tp (hrs)
100		DESIGN NASHYD	24	71			35	990	3.5	1.01	0.61
101		DESIGN NASHYD	77	73			55	1760	3.1	1.41	0.85
102		DESIGN NASHYD	142	73			50	1980	2.5	1.82	1.09
103		DESIGN NASHYD	23	73			25	575	4.3	0.72	0.43

**Notes:**

TIMP

XIMP

Time of Concentration calculated using the SCS Lag Equation  
 (For areas greater than 100 ha)

Time of Concentration calculated using the Airport Method  
 (For areas less than 100 ha)

Time to Peak

CN calculated for pervious areas only for CALIB STANDHYD. CN is a weighed average for CALIB NASHYD

Total percent impervious

Percent impervious directly connected

$$T_c = [259L^{0.8} [(1000 / CN) - 9]^{0.7}] / [1900S^{0.5}]$$

Where: L = Length of Overland Flow (m)

CN = SCS Curve Number

S = Slope (%)

$$T_c = [3.26 (1.1-C) L^{0.5}] / S^{0.33}$$

Where: C = Runoff Coefficient = 0.2 for undeveloped area;

L = Length of Overland Flow (m)

S = Slope (%)

$$T_p = 0.6T_c$$

```

00001> 2 Metric units
00002> #*****
00003> # Project Name : Hydro One - Clarington Transformer Station
00004> # Project Number: 1609-60745
00005> # Date : May 15, 2012
00006> # Modeller : T. Fraser
00007> # Revised : June 5, 2012 by S. Robertson]
00008> # Company : Stantec Consulting Ltd. (Kitchener)
00009> # License # : 4730904
00010> #
00011> # This hydrologic analysis was prepared to determine the flows to and across
00012> # the site in this part of the Harmony Creek Watershed.
00013> #
00014> #*****
00015> START TZERO=[0.0]hrs or date, METOUT=[2], NSTORM=[1], NRUN=[1]
00016> * ["bm2yr.6h"] <--storm filename, one per line for NSTORM time
00017> #-----
00018> READ STORM STORM_FILENAME=["STORM.001"]
00019> #-----
00020> # Existing Conditions
00021> #-----
00022> # Catchment 100 - North-central portion of Site tributary to Key Point A
00023> #-----
00024> CALIB NASHYD ID=[1], NHYD=["100"], DT=[5]min, AREA=[24](ha),
00025> DWF=[0](cms), CN/C=[71], IA=[7.0](mm),
00026> N=[3], TP=[0.61]hrs,
00027> RAINFALL=[ , , , ](mm/hr), END=-1
00028> #-----
00029> # Catchment 101 - West end of site, western edge of Harmony Cr watershed
00030> #-----
00031> CALIB NASHYD ID=[2], NHYD=["101"], DT=[5]min, AREA=[78](ha),
00032> DWF=[0](cms), CN/C=[73], IA=[7.0](mm),
00033> N=[3], TP=[0.85]hrs,
00034> RAINFALL=[ , , , ](mm/hr), END=-1
00035> #-----
00036> # Sum of Catchments 100 and 101 (Key Point B)
00037> #-----
00038> ADD HYD IDsum=[3], NHYD=["ADD1"], IDs to add=[1+2]
00039> #-----
00040> # Catchment 102 - East catchment, drains to southeast end of site (Key Pt C)
00041> #-----
00042> CALIB NASHYD ID=[4], NHYD=["102"], DT=[5]min, AREA=[142](ha),
00043> DWF=[0](cms), CN/C=[73], IA=[7.0](mm),
00044> N=[3], TP=[1.09]hrs,
00045> RAINFALL=[ , , , ](mm/hr), END=-1
00046> #-----
00047> # Catchment 103 - South portion of site, discharging off-site at Key Point D
00048> #-----
00049> CALIB NASHYD ID=[5], NHYD=["103"], DT=[5]min, AREA=[23](ha),
00050> DWF=[0](cms), CN/C=[73], IA=[7.0](mm),
00051> N=[3], TP=[0.43]hrs,
00052> RAINFALL=[ , , , ](mm/hr), END=-1
00053> #-----
00054> START TZERO=[0.0], METOUT=[2], NSTORM=[1], NRUN=[2]
00055> # ["bm5yr.6h"] <--storm filename, one per line for NSTORM tim
00056> #-----
00057> START TZERO=[0.0], METOUT=[2], NSTORM=[1], NRUN=[3]
00058> # ["bm100yr.6h"] <--storm filename, one per line for NSTORM t
00059> #-----
00060> START TZERO=[0.0], METOUT=[2], NSTORM=[1], NRUN=[7]
00061> # ["bm2yr.24h"] <--storm filename, one per line for NSTORM ti
00062> #-----
00063> START TZERO=[0.0], METOUT=[2], NSTORM=[1], NRUN=[8]
00064> # ["bm5yr.24h"] <--storm filename, one per line for NSTORM ti
00065> #-----
00066> START TZERO=[0.0], METOUT=[2], NSTORM=[1], NRUN=[9]
00067> # ["bm100yr.24h"] <--storm filename, one per line for NSTORM
00068> #-----
00069> FINISH
00070>

```

```

00001>-----
00002>
00003> SSSS W W M M H H Y Y M M O O 999 999 -----
00004> S W W W M M M M H H Y Y M M M O O 9 9 9 9
00005> SSSS W W M M M H H H H Y Y M M M O O ## 9 9 9 9 Ver 4.05
00006> S W W M M H H H Y Y M M O O 9999 9999 Sept 2011
00007> SSSS W W M M H H Y Y M M O O 9 9 9 9
00008> ***** # 4730904 *****
00009> StormWater Management Hydrologic Model 999 999 -----
00010>
00011> *****
00012> ***** SWMHYMO Ver/4.05 *****
00013> ***** A single event and continuous hydrologic simulation model *****
00014> ***** based on the principles of HYMO and its successors *****
00015> ***** OTHYMO-83 and OTHYMO-89. *****
00016> *****
00017> ***** Distributed by: J.F. Sabourin and Associates Inc. *****
00018> ***** Ottawa, Ontario: (613) 836-3884 *****
00019> ***** Gatineau, Quebec: (819) 243-6858 *****
00020> ***** E-Mail: swmhyo@jfssa.com *****
00021> *****
00022> *****
00023> *****
00024> ***** Licensed user: Stantec Consulting Ltd. (Kitchener) *****
00025> ***** Kitchener SERIAL#:4730904 *****
00026> *****
00027> *****
00028> *****
00029> ***** PROGRAM ARRAY DIMENSIONS *****
00030> ***** Maximum value for ID numbers : 10 *****
00031> ***** Max. number of rainfall points: 105408 *****
00032> ***** Max. number of flow points : 105408 *****
00033> *****
00034> *****
00035> ***** DESCRIPTION SUMMARY TABLE HEADERS (units depend on METOUT in START) *****
00036> *****
00037> ***** ID: Hydrograph Identification numbers, (1-10). *****
00038> ***** NHYD: Hydrograph reference numbers, (6 digits or characters). *****
00039> ***** AREA: Drainage area associated with hydrograph, (ac.) or (ha.). *****
00040> ***** QPEAK: Peak flow of simulated hydrograph, (ft3/s) or (m3/s). *****
00041> ***** TpeakDate_hh:mm is the date and time of the peak flow. *****
00042> ***** R.V.: Runoff Volume of simulated hydrograph, (in) or (mm). *****
00043> ***** R.C.: Runoff Coefficient of simulated hydrograph, (ratio). *****
00044> ***** *: see WARNING or NOTE message printed at end of run. *****
00045> ***** **: see ERROR message printed at end of run. *****
00046> *****
00047> *****
00048> *****
00049> ::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::
00050>
00051> *****
00052> *****
00053> ***** SUMMARY OUTPUT *****
00054> *****
00055> * DATE: 2012-06-06 TIME: 11:28:01 RUN COUNTER: 000104 *
00056> *****
00057> * Input filename: C:\SWMHYMO\HONIex.dat *
00058> * Output filename: C:\SWMHYMO\HONIex.out *
00059> * Summary filename: C:\SWMHYMO\HONIex.sum *
00060> * User comments: *
00061> * 1: *
00062> * 2: *
00063> * 3: *
00064> *****
00065> *****
00066> *****
00067> # *****
00068> # Project Name: Hydro One - Clarington Transformer Station
00069> # Project Number: 1609-60745
00070> # Date: May 15, 2012
00071> # Modeller: T. Fraser
00072> # Revised: June 5, 2012 by S. Robertson]
00073> # Company: Stantec Consulting Ltd. (Kitchener)
00074> # License #: 4730904
00075> #
00076> # This hydrologic analysis was prepared to determine the flows to and across
00077> # the Site in this part of the Harmony Creek Watershed.
00078> #
00079> # *****
00080> RUN:COMMAND#
00081> 001:0001-----
00082> START
00083> [TZERO = .00 hrs on 0]
00084> [METOUT= 2 (1=imperial, 2=metric output)]
00085> [NSTORM= 1 ]
00086> [NRUN = 1 ]
00087> 001:0002-----
00088> READ STORM
00089> Filename = STORM.001
00090> Comment =
00091> [SDT=15.00:SDUR= 6.00:PTOT= 37.90]
00092> # Existing Conditions
00093> # Catchment 100 - North-central portion of Site tributary to Key Point A
00094> 001:0003-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00095> CALIB NASHYD 01:100 24.00 .252 No_date 3:40 7.09
00096> [CN= 71.0: N= 3.00]
00097> [Tp= .61:DT= 5.00]
00098> # Catchment 101 - West end of site, western edge of Harmony Cr watershed
00099> 001:0004-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00100> CALIB NASHYD 02:101 78.00 .697 No_date 3:55 7.65
00101> [CN= 73.0: N= 3.00]
00102> [Tp= .85:DT= 5.00]
00103> # Sum of Catchments 100 and 101 (Key Point B)
00104> 001:0005-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00105> ADD HYD 01:100 24.00 .252 No_date 3:40 7.09
00106> + 02:101 78.00 .697 No_date 3:55 7.65
00107> [DT= 5.00] SUM= 03:ADD1 102.00 .931 No_date 3:50 7.52
00108> # Catchment 102 - East catchment, drains to southeast end of site (Key Pt C)
00109> 001:0006-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00110> CALIB NASHYD 04:102 142.00 1.057 No_date 4:15 7.65
00111> [CN= 73.0: N= 3.00]
00112> [Tp= 1.09:DT= 5.00]
00113> # Catchment 103 - South portion of site, discharging off-site at Key Point D
00114> 001:0007-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00115> CALIB NASHYD 05:103 23.00 .331 No_date 3:25 7.65
00116> [CN= 73.0: N= 3.00]
00117> [Tp= .43:DT= 5.00]
00118> ** END OF RUN : 1
00119> *****
00120> *****
00121> *****
00122> *****
00123> *****
00124> *****
00125> *****
00126> RUN:COMMAND#
00127> 002:0001-----
00128> START
00129> [TZERO = .00 hrs on 0]
00130> [METOUT= 2 (1=imperial, 2=metric output)]
00131> [NSTORM= 1 ]
00132> [NRUN = 2 ]
00133> *****
00134> # Project Name: Hydro One - Clarington Transformer Station
00135> # Project Number: 1609-60745

```

```

00136> # Date: May 15, 2012
00137> # Modeller: T. Fraser
00138> # Revised: June 5, 2012 by S. Robertson]
00139> # Company: Stantec Consulting Ltd. (Kitchener)
00140> # License #: 4730904
00141> #
00142> # This hydrologic analysis was prepared to determine the flows to and across
00143> # the Site in this part of the Harmony Creek Watershed.
00144> #
00145> *****
00146> 002:0002-----
00147> READ STORM
00148> Filename = STORM.001
00149> Comment =
00150> [SDT=15.00:SDUR= 6.00:PTOT= 50.00]
00151> # Existing Conditions
00152> # Catchment 100 - North-central portion of Site tributary to Key Point A
00153> 002:0003-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00154> CALIB NASHYD 01:100 24.00 .460 No_date 3:35 12.60
00155> [CN= 71.0: N= 3.00]
00156> [Tp= .61:DT= 5.00]
00157> # Catchment 101 - West end of site, western edge of Harmony Cr watershed
00158> 002:0004-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00159> CALIB NASHYD 02:101 78.00 1.260 No_date 3:55 13.50
00160> [CN= 73.0: N= 3.00]
00161> [Tp= .85:DT= 5.00]
00162> # Sum of Catchments 100 and 101 (Key Point B)
00163> 002:0005-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00164> ADD HYD 01:100 24.00 .460 No_date 3:35 12.60
00165> + 02:101 78.00 1.260 No_date 3:55 13.50
00166> [DT= 5.00] SUM= 03:ADD1 102.00 1.686 No_date 3:50 13.29
00167> # Catchment 102 - East catchment, drains to southeast end of site (Key Pt C)
00168> 002:0006-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00169> CALIB NASHYD 04:102 142.00 1.902 No_date 4:10 13.50
00170> [CN= 73.0: N= 3.00]
00171> [Tp= 1.09:DT= 5.00]
00172> # Catchment 103 - South portion of site, discharging off-site at Key Point D
00173> 002:0007-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00174> CALIB NASHYD 05:103 23.00 .605 No_date 3:20 13.50
00175> [CN= 73.0: N= 3.00]
00176> [Tp= .43:DT= 5.00]
00177> ** END OF RUN : 2
00178> *****
00179> *****
00180> *****
00181> *****
00182> *****
00183> *****
00184> *****
00185> RUN:COMMAND#
00186> 003:0001-----
00187> START
00188> [TZERO = .00 hrs on 0]
00189> [METOUT= 2 (1=imperial, 2=metric output)]
00190> [NSTORM= 1 ]
00191> [NRUN = 3 ]
00192> *****
00193> # Project Name: Hydro One - Clarington Transformer Station
00194> # Project Number: 1609-60745
00195> # Date: May 15, 2012
00196> # Modeller: T. Fraser
00197> # Revised: June 5, 2012 by S. Robertson]
00198> # Company: Stantec Consulting Ltd. (Kitchener)
00199> # License #: 4730904
00200> #
00201> # This hydrologic analysis was prepared to determine the flows to and across
00202> # the Site in this part of the Harmony Creek Watershed.
00203> #
00204> *****
00205> 003:0002-----
00206> READ STORM
00207> Filename = STORM.001
00208> Comment =
00209> [SDT=15.00:SDUR= 6.00:PTOT= 83.10]
00210> # Existing Conditions
00211> # Catchment 100 - North-central portion of Site tributary to Key Point A
00212> 003:0003-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00213> CALIB NASHYD 01:100 24.00 1.215 No_date 3:35 32.20
00214> [CN= 71.0: N= 3.00]
00215> [Tp= .61:DT= 5.00]
00216> # Catchment 101 - West end of site, western edge of Harmony Cr watershed
00217> 003:0004-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00218> CALIB NASHYD 02:101 78.00 3.276 No_date 3:50 34.06
00219> [CN= 73.0: N= 3.00]
00220> [Tp= .85:DT= 5.00]
00221> # Sum of Catchments 100 and 101 (Key Point B)
00222> 003:0005-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00223> ADD HYD 01:100 24.00 1.215 No_date 3:35 32.20
00224> + 02:101 78.00 3.276 No_date 3:50 34.06
00225> [DT= 5.00] SUM= 03:ADD1 102.00 4.406 No_date 3:45 33.62
00226> # Catchment 102 - East catchment, drains to southeast end of site (Key Pt C)
00227> 003:0006-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00228> CALIB NASHYD 04:102 142.00 4.924 No_date 4:10 34.06
00229> [CN= 73.0: N= 3.00]
00230> [Tp= 1.09:DT= 5.00]
00231> # Catchment 103 - South portion of site, discharging off-site at Key Point D
00232> 003:0007-----ID:NHYD-----AREA---QPEAK-TpeakDate_hh:mm---R.V.-
00233> CALIB NASHYD 05:103 23.00 1.587 No_date 3:20 34.06
00234> [CN= 73.0: N= 3.00]
00235> [Tp= .43:DT= 5.00]
00236> ** END OF RUN : 6
00237> *****
00238> *****
00239> *****
00240> *****
00241> *****
00242> *****
00243> *****
00244> RUN:COMMAND#
00245> 007:0001-----
00246> START
00247> [TZERO = .00 hrs on 0]
00248> [METOUT= 2 (1=imperial, 2=metric output)]
00249> [NSTORM= 1 ]
00250> [NRUN = 7 ]
00251> *****
00252> # Project Name: Hydro One - Clarington Transformer Station
00253> # Project Number: 1609-60745
00254> # Date: May 15, 2012
00255> # Modeller: T. Fraser
00256> # Revised: June 5, 2012 by S. Robertson]
00257> # Company: Stantec Consulting Ltd. (Kitchener)
00258> # License #: 4730904
00259> #
00260> # This hydrologic analysis was prepared to determine the flows to and across
00261> # the Site in this part of the Harmony Creek Watershed.
00262> #
00263> *****
00264> 007:0002-----
00265> READ STORM
00266> Filename = STORM.001
00267> Comment =
00268> [SDT=15.00:SDUR= 24.00:PTOT= 47.10]
00269> # Existing Conditions
00270> # Catchment 100 - North-central portion of Site tributary to Key Point A

```

```

00271> 007:0003-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00272> CALIB NASHYD 01:100 24.00 .290 No_date 12:35 11.18
00273> [CN= 71.0: N= 3.00]
00274> [Tp= .61:DT= 5.00]
00275> # Catchment 101 - West end of site, western edge of Harmony Cr watershed
00276> 007:0004-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00277> CALIB NASHYD 02:101 78.00 .801 No_date 12:50 12.00
00278> [CN= 73.0: N= 3.00]
00279> [Tp= .85:DT= 5.00]
00280> # Sum of Catchments 100 and 101 (Key Point B)
00281> 007:0005-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00282> ADD HYD 01:100 24.00 .290 No_date 12:35 11.18
00283> + 02:101 78.00 .801 No_date 12:50 12.00
00284> [DT= 5.00] SUM= 03:ADD1 102.00 1.071 No_date 12:45 11.80
00285> # Catchment 102 - East catchment, drains to southeast end of site (Key Pt C)
00286> 007:0006-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00287> CALIB NASHYD 04:102 142.00 1.210 No_date 13:10 12.00
00288> [CN= 73.0: N= 3.00]
00289> [Tp= 1.09:DT= 5.00]
00290> # Catchment 103 - South portion of site, discharging off-site at Key Point D
00291> 007:0007-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00292> CALIB NASHYD 05:103 23.00 .386 No_date 12:20 12.00
00293> [CN= 73.0: N= 3.00]
00294> [Tp= .43:DT= 5.00]
00295> ** END OF RUN : 7
00296>
00297> *****
00298>
00299>
00300>
00301>
00302>
00303> RUN:COMMAND#
00304> 008:0001-----
00305> START
00306> [TZERO = .00 hrs on 0]
00307> [METOUT= 2 (1=imperial, 2=metric output)]
00308> [NSTORM= 1 ]
00309> [NRUN = 8 ]
00310> *****
00311> # Project Name : Hydro One - Clarington Trasformer Station
00312> # Project Number: 1609-60745
00313> # Date : May 15, 2012
00314> # Modeller : T. Fraser
00315> # Revised : June 5, 2012 by S. Robertson]
00316> # Company : Stantec Consulting Ltd. (Kitchener)
00317> # License # : 4730904
00318> #
00319> # This hydrologic analysis was prepared to determine the flows to and across
00320> # the Site in this part of the Harmony Creek Watershed.
00321> #
00322> *****
00323> 008:0002-----
00324> READ STORM
00325> Filename = STORM.001
00326> Comment =
00327> [SDT=15.00:SDUR= 24.00:PTOT= 59.20]
00328> # Existing Conditions
00329> # Catchment 100 - North-central portion of Site tributary to Key Point A
00330> 008:0003-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00331> CALIB NASHYD 01:100 24.00 .464 No_date 12:30 17.47
00332> [CN= 71.0: N= 3.00]
00333> [Tp= .61:DT= 5.00]
00334> # Catchment 101 - West end of site, western edge of Harmony Cr watershed
00335> 008:0004-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00336> CALIB NASHYD 02:101 78.00 1.275 No_date 12:50 18.64
00337> [CN= 73.0: N= 3.00]
00338> [Tp= .85:DT= 5.00]
00339> # Sum of Catchments 100 and 101 (Key Point B)
00340> 008:0005-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00341> ADD HYD 01:100 24.00 .464 No_date 12:30 17.47
00342> + 02:101 78.00 1.275 No_date 12:50 18.64
00343> [DT= 5.00] SUM= 03:ADD1 102.00 1.708 No_date 12:45 18.37
00344> # Catchment 102 - East catchment, drains to southeast end of site (Key Pt C)
00345> 008:0006-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00346> CALIB NASHYD 04:102 142.00 1.927 No_date 13:05 18.64
00347> [CN= 73.0: N= 3.00]
00348> [Tp= 1.09:DT= 5.00]
00349> # Catchment 103 - South portion of site, discharging off-site at Key Point D
00350> 008:0007-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00351> CALIB NASHYD 05:103 23.00 .614 No_date 12:20 18.64
00352> [CN= 73.0: N= 3.00]
00353> [Tp= .43:DT= 5.00]
00354> ** END OF RUN : 8
00355>
00356> *****
00357>
00358>
00359>
00360>
00361>
00362> RUN:COMMAND#
00363> 009:0001-----
00364> START
00365> [TZERO = .00 hrs on 0]
00366> [METOUT= 2 (1=imperial, 2=metric output)]
00367> [NSTORM= 1 ]
00368> [NRUN = 9 ]
00369> *****
00370> # Project Name : Hydro One - Clarington Trasformer Station
00371> # Project Number: 1609-60745
00372> # Date : May 15, 2012
00373> # Modeller : T. Fraser
00374> # Revised : June 5, 2012 by S. Robertson]
00375> # Company : Stantec Consulting Ltd. (Kitchener)
00376> # License # : 4730904
00377> #
00378> # This hydrologic analysis was prepared to determine the flows to and across
00379> # the Site in this part of the Harmony Creek Watershed.
00380> #
00381> *****
00382> 009:0002-----
00383> READ STORM
00384> Filename = STORM.001
00385> Comment =
00386> [SDT=15.00:SDUR= 24.00:PTOT= 92.40]
00387> # Existing Conditions
00388> # Catchment 100 - North-central portion of Site tributary to Key Point A
00389> 009:0003-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00390> CALIB NASHYD 01:100 24.00 1.060 No_date 12:30 38.56
00391> [CN= 71.0: N= 3.00]
00392> [Tp= .61:DT= 5.00]
00393> # Catchment 101 - West end of site, western edge of Harmony Cr watershed
00394> 009:0004-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00395> CALIB NASHYD 02:101 78.00 2.867 No_date 12:45 40.66
00396> [CN= 73.0: N= 3.00]
00397> [Tp= .85:DT= 5.00]
00398> # Sum of Catchments 100 and 101 (Key Point B)
00399> 009:0005-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00400> ADD HYD 01:100 24.00 1.060 No_date 12:30 38.56
00401> + 02:101 78.00 2.867 No_date 12:45 40.66
00402> [DT= 5.00] SUM= 03:ADD1 102.00 3.856 No_date 12:40 40.17
00403> # Catchment 102 - East catchment, drains to southeast end of site (Key Pt C)
00404> 009:0006-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00405> CALIB NASHYD 04:102 142.00 4.336 No_date 13:05 40.66

```

```

00406> [CN= 73.0: N= 3.00]
00407> [Tp= 1.09:DT= 5.00]
00408> # Catchment 103 - South portion of site, discharging off-site at Key Point D
00409> 009:0007-----ID:NHYD-----AREA-----QPEAK-TpeakDate_hh:mm-----R.V.-
00410> CALIB NASHYD 05:103 23.00 1.378 No_date 12:20 40.66
00411> [CN= 73.0: N= 3.00]
00412> [Tp= .43:DT= 5.00]
00413> 009:0002-----
00414> FINISH
00415> *****
00416> *****
00417> WARNINGS / ERRORS / NOTES
00418>
00419> Simulation ended on 2012-06-06 at 11:28:10
00420> *****
00421>

```