

WEBSTER Jessica

From: STAITE Patricia
Sent: Friday, March 12, 2010 1:27 PM
To: 'Frechette, Mario (MTO)'
Cc: Boudreau, Kevin (MTO); Wilson, Paul (MTO); Morrisey, John (MTO)
Subject: RE: Notice of Completion of the Draft Environmental Study Report Supply to Essex County Transmission Reinforcement
Categories: SEC

Mario

Thank you for your response. We will apply for the permit as required when we are in the design construction phase of our project.

Patricia Staite

From: Frechette, Mario (MTO) [mailto: Mario.Frechette@ontario.ca]
Sent: Friday, March 12, 2010 9:34 AM
To: STAITE Patricia
Cc: Boudreau, Kevin (MTO); Wilson, Paul (MTO); Morrisey, John (MTO)
Subject: Notice of Completion of the Draft Environmental Study Report Supply to Essex County Transmission Reinforcement

Hi Patricia,

The Ministry of Transportation (MTO) has reviewed the subject Draft Environmental Study Report as per the Public Transportation and Highway Improvement Act and offers the following comments.

- Stage 1: The MTO has no concerns with the proposed Transformer Station on Concession Rd. 6 in the Municipality of Leamington and new double circuit 230 kilovolt transmission line on new corridor.
- Stage 2: An Encroachment permit will be required to cross Hwy 401 with the proposed additional double circuit 230 KV transmission line on the existing transmission corridor between Sandwich Junction and Lauzon TS in the City of Windsor. Details and procedures on the crossing will be required as part of the permit process. A Building and Land Use permit may also be required as part of this project.

Don't hesitate to call if you have any questions.

Regards,

Mario Frechette
Technical Services Officer
Contracts and Operations Office
Operations - London
West Region
Tel: 519 873-4670
Fax: 519 873-4734
E-mail: Mario.Frechette@ontario.ca

7/14/2010