



**Hydro One Networks Inc.**  
483 Bay Street  
Toronto, Ontario  
M5G 2P5

## **NEEDS ASSESSMENT REPORT**

**Toronto Region**

**Date: December 19, 2022**

**Prepared by: Toronto Region Technical Working Group**



**Disclaimer**

This Needs Assessment Report was prepared for the purpose of identifying potential needs in the Toronto Region and to recommend which need: a) does not require further regional coordination and b) identify needs requiring further assessment and/or regional coordination. The results reported in this Needs Assessment are based on the input and information provided by the Technical Working Group (“TWG”) for this region.

The TWG participants, their respective affiliated organizations, and Hydro One Networks Inc. (collectively, “the Authors”) shall not, under any circumstances whatsoever, be liable to each other, to any third party for whom the Needs Assessment Report was prepared (“the Intended Third Parties”) or to any other third party reading or receiving the Needs Assessment Report (“the Other Third Parties”). The Authors, Intended Third Parties and Other Third Parties acknowledge and agree that: (a) the Authors make no representations or warranties (express, implied, statutory or otherwise) as to this document or its contents, including, without limitation, the accuracy or completeness of the information therein; (b) the Authors, Intended Third Parties and Other Third Parties and their respective employees, directors and agents (the “Representatives”) shall be responsible for their respective use of the document and any conclusions derived from its contents; (c) and the Authors will not be liable for any damages resulting from or in any way related to the reliance on, acceptance or use of the document or its contents by the Authors, Intended Third Parties or Other Third Parties or their respective Representatives.

## Executive Summary

<b>REGION</b>	Toronto Region (the “Region”)		
<b>LEAD</b>	Hydro One Networks Inc. (“Hydro One”)		
<b>START DATE</b>	August 23, 2022	<b>END DATE</b>	December 19, 2022
<b>1. INTRODUCTION</b>			
<p>The second Regional Planning (“RP”) cycle for the Toronto Region was completed in March 2020 with the publication of the Regional Infrastructure Plan (“RIP”) report. This is the third RP cycle for this Region, which begins with the Needs Assessment (“NA”) phase. The purpose of this NA is to:</p> <p>a) Identify any new needs and reaffirm needs identified in the previous RP cycle; and</p> <p>b) Recommend which needs:</p> <ol style="list-style-type: none"> <li>i. require further assessment and regional coordination (and hence, proceed to the next phases of RP); and</li> <li>ii. do not require further regional coordination (i.e., can be addressed directly between Hydro One and the impacted Local Distribution Companies (“LDC”) to develop a preferred plan, or no regional investment is required at this time and the need may be reviewed during the next RP cycle).</li> </ol>			
<b>2. REGIONAL ISSUE/TRIGGER</b>			
<p>In accordance with the RP process, the RP cycle should be triggered at least once every five years. Considering these timelines, the third Regional Planning cycle was triggered in August 2022 for the Toronto Region.</p>			
<b>3. SCOPE OF NEEDS ASSESSMENT</b>			
<p>The scope of the Toronto Region NA includes:</p> <ol style="list-style-type: none"> <li>a) Reaffirm and update needs/plans identified in the previous RP cycle;</li> <li>b) Identify any new needs resulting from this assessment;</li> <li>c) Recommend which need(s) require further assessment and regional coordination in the next phases of the RP cycle; and</li> <li>d) Recommend which needs do not require further regional coordination (i.e., can be addressed directly between Hydro One and the impacted LDC(s) to develop a preferred plan, or no regional investment is required at this time and the need may be reviewed during the next RP cycle).</li> </ol> <p>The Technical Working Group (“TWG”) may also identify additional needs during the next phases of the planning process, namely Scoping Assessment (“SA”), Integrated Regional Resource Plan (“IRRP”) and RIP, based on updated information available at that time.</p> <p>The planning horizon for this NA is 10 years.</p>			
<b>4. INPUTS/DATA</b>			
<p>The TWG representatives from LDCs, the Independent Electricity System Operator (“IESO”), and Hydro One provided input and relevant information for the Toronto Region regarding capacity needs, system reliability needs, operational issues, and major high-voltage (“HV”) transmission assets requiring replacement over the planning horizon. The information was based on what was available and provided at the time of the NA, which does not include the impact from the IESO’s “Pathways to Decarbonization” report published on December 15, 2022. The electricity demand and new infrastructure need in the longer term could be substantially higher than anticipated and discussed in this report. This will be further assessed in the next phase of this RP cycle.</p>			

## 5. ASSESSMENT METHODOLOGY

The assessment’s primary objective is to identify the electrical infrastructure needs in the Region over the study period. The assessment methodology includes a review of planning information such as load forecast, conservation and demand management (“CDM”) forecast, available distributed generation (“DG”) information, system reliability and operation issues, and major HV transmission assets requiring replacement.

A technical assessment of needs was undertaken based on:

- a) Station capacity and transmission adequacy;
- b) System reliability and any operational concerns;
- c) Major HV transmission equipment requiring replacement with consideration to “right-sizing”; and
- d) Sensitivity analysis to capture uncertainty in the load forecast as well as variability of demand drivers such as electrification. (which does not consider the impact from the “Pathways to Decarbonization” report published by the IESO on December 15, 2022, but will be assessed in the next phase of this RP cycle)

## 6. NEEDS

Needs that were identified in the last RP cycle with associated projects recently done or currently underway are:

- Second DESN at Horner TS and refurbishment projects at Runnymede TS (T3/T4), Sheppard TS (T3/T4), and Strachan TS (T12) were completed in 2021-2022.
- Copeland MTS phase 2 is expected to be in-service in 2024 to address the station capacity need.
- Bridgman TS transformer replacement (T11/T12/T13/T14) is expected to be done in 2024.
- Fairbank TS transformer replacement (T1/T2/T3/T4) is expected to be completed in 2024.
- Main TS transformer replacement (T3/T4) is expected to be completed in 2024.
- John TS transformer replacement (T5/T6) is expected to be complete in 2025. Transformer T1, T2 and T4 have been replaced in 2019-2021. The condition of transformer T3 and the 115 kV breakers are reviewed and considered in fair condition; no replacement in the near/medium term is needed.
- Circuits C5E/C7E underground cable replacement between Esplanade TS and Terauley TS is underway and expected to be completed in 2026.

Other near/medium-term needs identified in the previous RP cycle and the new near/medium-term needs identified in this NA are:

Identified in the previous RP cycle	Identified in this NA
<p><u>Line Capacity</u> (Refer to section 7.2 for more details)</p> <ul style="list-style-type: none"> <li>Richview to Manby 230 kV Corridor [2026]</li> <li>Manby to Riverside Jct 115 kV Corridor [2026, with a line upgrade expected by 2028]</li> </ul> <p><u>Transformers / Autotransformers Requiring Replacement</u> (Refer to section 7.1 for more details)</p> <ul style="list-style-type: none"> <li>Charles TS: T3/T4 [2026]</li> <li>Duplex TS: T1/T2 [2026]</li> <li>Scarboro TS: T23 [2027]</li> <li>Fairchild TS: T1 [2028]</li> <li>Bermondsey TS: T3/T4 [2029]</li> <li>Manby TS: autotransformers T7, T9, and T12, and step-down transformer T13 [2029-2030]</li> <li>Leslie TS: T1 [2030]</li> </ul> <p><u>Transmission Lines Requiring Replacement</u> (Refer to section 7.1 for more details)</p> <ul style="list-style-type: none"> <li>H1L/H3L/H6LC/H8LC: Leaside Jct. to Bloor St. Jct. 115 kV overhead section [2025]</li> <li>L9C/L12C: Leaside TS to Balfour Jct. 115 kV overhead section [2027]</li> </ul>	<p><u>Transformers / Autotransformers Requiring Replacement</u> (Refer to section 7.1 for more details)</p> <ul style="list-style-type: none"> <li>Strachan TS: T14 &amp; T13/T15 [2025, 2031]</li> <li>Basin TS: T3/T5 [2027]</li> <li>Scarboro TS: T23 [2027]</li> <li>Fairchild TS: T3/T4 [2028]</li> <li>Malvern TS: T3 [2029]</li> <li>Manby TS: T14 [2029]</li> <li>Duplex TS: T3/T4 [2031]</li> </ul> <p><u>Load Restoration</u> (Refer to section 7.4)</p> <ul style="list-style-type: none"> <li>Loss of C14L/C17L</li> <li>Loss of C18R/P22R</li> </ul>

The long-term needs that were identified in the previous RP cycle and this NA are [beyond 2031]:

Identified in the previous RP cycle	Identified in this NA (Potential)
<p><u>Station Capacity</u></p> <ul style="list-style-type: none"> <li>Fairbank TS</li> <li>Sheppard TS</li> <li>Strachan TS</li> <li>Basin TS</li> </ul> <p><u>Transformation Capacity</u></p> <ul style="list-style-type: none"> <li>Manby W TS</li> <li>Leaside TS</li> </ul> <p><u>Line Capacity</u></p> <ul style="list-style-type: none"> <li>Leaside TS to Wiltshire TS 115 kV Corridor</li> </ul>	<p><u>Station Capacity</u></p> <ul style="list-style-type: none"> <li>Glengrove TS</li> <li>Finch TS / Bathurst TS</li> <li>Warden TS</li> </ul> <p><u>Line Capacity</u></p> <ul style="list-style-type: none"> <li>Parkway TS to Richview TS 230 kV Corridor</li> </ul>

**7. RECOMMENDATIONS**

The TWG’s recommendations are as follows:

- a) No further regional coordination is required for the following need:
  - Asset renewal needs for replacing the major HV equipment as listed in the table below. These needs will be addressed directly by Hydro One and THESL to develop a preferred replacement plan giving consideration to “right-sizing”;
- b) Further assessment and regional coordination is required in the next phases of the RP cycle to review and/or develop a preferred plan for the follow needs:
  - The line capacity need for the 115 kV corridor between Manby TS and Riverside Jct. Hydro One will initiate the development work for reconductoring the overhead line section; and
  - The load restoration and long-term needs as listed in the following table.

Further Regional Coordination Not Required	Further Regional Coordination Required
<p><b>Asset Renewal Needs (Stations):</b></p> <ul style="list-style-type: none"> <li>• Strachan T14 &amp; T13/T15</li> <li>• Charles TS: T3/T4</li> <li>• Duplex TS: T1/T2 &amp; T3/T4</li> <li>• Basin TS: T3/T5</li> <li>• Scarboro TS: T23</li> <li>• Fairchild TS: T1 &amp; T3/T4</li> <li>• Bermondsey TS: T3/T4</li> <li>• Malvern TS: T3</li> <li>• Manby TS: T7, T9, T12 autotransformers, T13/T14 step-down transformer</li> <li>• Leslie TS: T1</li> </ul> <p><b>Asset Renewal Needs (Lines):</b></p> <ul style="list-style-type: none"> <li>• 115 kV H1L/H3L/H6LC/H8LC: Leaside Jct. to Bloor St. Jct. overhead section</li> <li>• 115 kV L9C/L12C: Leaside TS to Balfour Jct. overhead section</li> </ul> <p><b>Line Capacity Need:</b></p> <ul style="list-style-type: none"> <li>• 230 kV Richview TS to Manby TS Corridor</li> </ul> <p><b>Station Capacity Need:</b></p> <ul style="list-style-type: none"> <li>• Fairbank TS</li> <li>• Strachan TS</li> </ul>	<p><b>Line Capacity Need:</b></p> <ul style="list-style-type: none"> <li>• 115 kV Manby TS to Riverside Jct. Corridor</li> </ul> <p><b>Load Restoration:</b></p> <ul style="list-style-type: none"> <li>• Loss of C14L/C17L</li> <li>• Loss of C18R/P22R</li> </ul> <p><b>Long-Term Needs:</b></p> <ul style="list-style-type: none"> <li>• Sheppard TS – Station Capacity</li> <li>• Basin TS – Station Capacity</li> <li>• Glengrove TS – Station Capacity</li> <li>• Finch TS / Bathurst TS – Station Capacity</li> <li>• Warden TS – Station Capacity</li> <li>• 230/115kV Manby W Autotransformers – Transformation Capacity</li> <li>• 230/115kV Leaside TS Autotransformers – Transformation Capacity</li> <li>• 230 kV Parkway TS to Richview TS Corridor – Line Capacity</li> <li>• 115kV Leaside TS to Wiltshire TS Corridor – Line Capacity</li> </ul>

This NA assessment does not include or consider the impact from the IESO’s “Pathways to Decarbonization” report published on December 15, 2022. The electricity demand and new infrastructure need in the longer term could be substantially higher than anticipated and discussed in this report. The TWG recommends that this be assessed in the next phase of this RP cycle.

**TABLE OF CONTENTS**

1 Introduction ..... 8

2 Regional Issue/Trigger ..... 8

3 Scope of Needs Assessment ..... 8

4 Regional Description and Connection Configuration ..... 9

5 Inputs and Data..... 10

6 Assessment Methodology ..... 11

7 Needs..... 13

8 Sensitivity Analysis..... 29

9 Recommendations ..... 31

10 References ..... 33

Appendix A-1: Non-Coincident Summer Peak Net Load Forecast (2022 to 2031) ..... 34

Appendix A-2: Coincident Summer Peak Net Load Forecast (2022 to 2031)..... 35

Appendix B: Lists of Step-Down Transformer Stations (Current) ..... 36

Appendix C: Lists of Transmission Circuits..... 39

Appendix D: Acronyms ..... 40

**List of Tables and Figures**

Table 1: Toronto Region TWG Participants ..... 8

Table 2: Near/Medium Term Needs Identified in Previous RIP <sup>(1)</sup> and/or this NA ..... 14

Table 3: Long-Term Needs Identified in Previous RIP and/or this NA..... 15

Table 4: New Major HV Transmission Equipment Replacement Needs Identified in this NA ..... 16

Table 5: Potential Long-Term Capacity Needs to be Further Assessed ..... 25

Table 6: Impact of Sensitivity Analysis on the Identified Capacity Needs ..... 30

Table 7: Summary of Recommendations ..... 31

Figure 1: Toronto Region Map ..... 9

Figure 2: Toronto Region – Single Line Diagram ..... 10

Figure 3: 115 kV Corridor between Manby TS and John TS (overhead section is circled) ..... 25

## 1 INTRODUCTION

The second cycle of the Regional Planning (“RP”) process for the Toronto Region was completed in March 2020 with the publication of the Regional Infrastructure Plan (“RIP”) report.

The purpose of this Needs Assessment (“NA”) is to identify new needs in the region, reaffirm and update needs identified in the previous Toronto RP cycle, and recommend which needs require further assessment and regional coordination and which do not.

This report was prepared by the Toronto Region Technical Working Group (“TWG”), led by Hydro One Networks Inc. Participants of the TWG are listed below in Table 1. The report presents the results of the assessment based on information provided by the Hydro One, the Local Distribution Companies (“LDC”) and the Independent Electricity System Operator (“IESO”).

**Table 1: Toronto Region TWG Participants**

<b>Company</b>
Alectra Utilities Corporation
Elexicon Energy Inc.
Hydro One Networks Inc. (Distribution)
Independent Electricity System Operator (“IESO”)
Toronto Hydro-Electric System Limited (“THESL”)
Hydro One Networks Inc. (Lead Transmitter)

## 2 REGIONAL ISSUE/TRIGGER

In accordance with the RP process, the RP cycle should be triggered at least once every five years. Considering these timelines, the third RP cycle was triggered for the Toronto Region.

## 3 SCOPE OF NEEDS ASSESSMENT

The scope of this NA covers the Toronto Region and includes:

- Reaffirm and update needs/plans identified in the previous RP cycle;
- Identify any new needs resulting from this assessment;
- Recommend which need(s) require further assessment and regional coordination in the next phases of the RP cycle; and



- Recommend which need(s) that do not require further regional coordination (i.e. can be addressed directly between Hydro One and the impacted LDC(s) to develop a preferred plan, or no regional investment is required at this time and the need may be reviewed during the next RP cycle).

The TWG may identify additional needs during the next phases of the RP process, namely Scoping Assessment (“SA”), Integrated Regional Resource Plan (“IRRPP”), and/or RIP based on updated information available at that time.

## 4 REGIONAL DESCRIPTION AND CONNECTION CONFIGURATION

The Toronto Region covers the area roughly bordered geographically by Lake Ontario on the south, Steeles Avenue on the north, Highway 427 on the west and Regional Road 30 on the east. It includes the City of Toronto, which is the largest City in Canada and the fourth largest in North America. Please see Figure 1 for the Toronto Region map. Electrical supply to this Region is provided by thirty-five 230kV and 115kV transmission and step-down stations as shown in Figure 2. The eastern, northern, and western parts of the Region are supplied by seventeen 230/27.6kV step-down transformer stations. The central area is supplied by two 230/115kV autotransformer stations (Leaside TS and Manby TS) and sixteen 115/13.8kV and two 115/27.6kV step-down transformer stations. The region is also supplied locally by Portlands Energy Centre, a 550 MW combined-cycle power generating station. The sum of 2021 non-coincident summer station peak load of the Region was about 4,850 MW.




Figure 1: Toronto Region Map




Figure 2: Toronto Region – Single Line Diagram

## 5 INPUTS AND DATA

TWG participants, including representatives from LDCs, IESO, and Hydro One provided information and input for the Toronto Region NA. The information provided includes the following:

- Load Forecast for all supply stations in the Toronto Region;
- Known capacity and system reliability needs, operational issues, and/or major HV transmission equipment requiring replacement over the study period; and
- Planned/foreseen transmission and distribution investments that are relevant to the Toronto RP process.

The information provided was the most recent information available and provided at the time of the NA phase. With respect to the load forecast information, the OEB Regional Planning Process Advisory Group (RPPAG) recently published a document called “Load Forecast Guideline for Ontario” in October 2022. The objective of this document is to provide guidance to the TWG in the development of the load forecasts used in the various phases of the RP process with a focus on the NA and the IRRP. One of the inputs into the LDC’s load forecast that is called for in this guideline is information from Municipal Energy Plans (MEP) and/or Community Energy Plans (CEP) (in cases where it has been produced by the municipality and the information can be translated by the LDC into the impact on peak demand). Accordingly, the OEB

RPPAG also recently developed a guideline called “Improving the Electricity Planning Process in Ontario: Enhanced Coordination between Municipalities and Entities in the Electricity Sector”, which lists the key MEP/CEP outputs to improve LDC load forecasts going forward. THESL has been closely coordinating with developers, provincial agencies and the City of Toronto on energy plans impacting various sections of the grid across the Toronto region. This NA report is recommending that further engagement be undertaken during the next phase of the RP cycle.

Also, it is important to be noted that, the IESO has just published the “Pathways to Decarbonization” on December 15, 2022, which evaluates a moratorium on the procurement of new natural gas generating stations in Ontario and develops an achievable pathway to decarbonization in the electricity system. It recommends that development work for priority transmission investments be identified to support decarbonization in the RP process. With this increasing focus on decarbonization and electrification, the electricity demand and new infrastructure need in the longer term could be substantially higher than anticipated and discussed in this NA report. The TWG recommends that the “Pathways to Decarbonization” report and its subsequent impact on the need and/or the timing for additional electrical supply facilities in the Toronto Region be considered and assessed in the next phase of this RP cycle.

## 6 ASSESSMENT METHODOLOGY

The following methodology and assumptions are made in this Needs Assessment:

Information gathering included:

- Load forecast: The LDCs provided their load forecast for all the stations supplying their loads in the Toronto Region for the 10-year study period. The IESO provided a Conservation and Demand Management (“CDM”) forecast and Distributed Generation (“DG”) contract information for the Toronto Region. The region’s extreme summer non-coincident peak gross load forecast for each station were prepared by applying the growth rates from the LDC load forecast to the actual 2021 summer peak extreme weather corrected loads. The extreme summer weather correction factor was provided by Hydro One. The net extreme weather summer load forecast was produced by reducing the gross load forecast for each station by the percentage CDM from the IESO for that station. It is to be noted that even though the IESO did not have information on new and contracted DG coming into service within the planning horizon, THESL has assumed the existing DGs are to remain in-service in the base year when developing their load forecast. The extreme summer weather corrected net non-coincident peak and coincident peak load forecasts for the individual stations in the Toronto region are given in Appendices A-1 and A-2;
- Relevant information regarding system reliability and operational issues in the region;
- List of major HV transmission equipment planned and/or identified to be replaced based on asset condition assessment, and relevant for RP purposes. The scope of equipment considered is given in Section 7.1.

A technical assessment of needs was undertaken based on:

- Station capacity and transmission adequacy assessment;
- System reliability and operational considerations;
- Asset renewal for major HV transmission equipment requiring replacement with consideration to “right-sizing”; and
- Sensitivity analysis to capture uncertainty in the load forecast (which does not consider the impact from the “Pathways to Decarbonization” report published by the IESO on December 15, 2022, but will be assessed in the next phase of this RP cycle).

The following other assumptions are made in this report.

- The study period for this NA is 2022-2031.
- Transmission system adequacy is assessed by using coincident peak loads in the area.
- Station capacity adequacy is assessed by comparing the non-coincident peak load with the station’s normal planning supply capacity, assuming a 90% lagging power factor for stations having no low-voltage (LV) capacitor banks and 95% lagging power factor for stations having LV capacitor banks.
- Normal planning supply capacity for transformer stations is determined by the Hydro One summer 10-Day Limited Time Rating (LTR) of a single transformer at that station.
- Adequacy assessment is conducted as per Ontario Resource Transmission Assessment Criteria (ORTAC).

## 7 NEEDS

This section identifies any new needs in the Toronto Region, and reaffirms and provides an update on the near, medium, and long-term needs already identified in the previous RIP.

Needs that were identified in the previous RP cycle with associated projects recently completed or currently underway were reaffirmed and are briefly described below with relevant updates. These are not further discussed in later sections of this report.

- Second DESN at Horner TS and refurbishment projects at Runnymede TS (T3/T4), Sheppard TS (T3/T4), and Strachan TS (T12) were completed in 2021-2022.
- Copeland MTS phase 2 is expected to be in-service in 2024 to address the station capacity need.
- Bridgman TS transformer replacement (T11/T12/T13/T14) is expected to be completed in 2024.
- Fairbank TS transformer replacement (T1/T2/T3/T4) is expected to be completed in 2024.
- Main TS transformer replacement (T3/T4) is expected to be completed in 2024.
- John TS transformer replacement (T5/T6) is expected to be completed in 2025. Transformer T1, T2 and T4 were replaced in 2019-2021. Based on asset condition assessment, transformer T3 and the 115 kV breakers are not recommended for replacement in the near/medium term.
- Circuits C5E/C7E underground cable replacement between Esplanade TS and Terauley TS is underway and expected to be completed in 2026. A 2.5 km tunnel between Esplanade TS and Terauley TS is to be built.

The planned in-service year for the above underway projects is tentative and is subject to change.

All the other near/medium-term needs and long-term needs are summarized in Table 2 and Table 3 respectively. The load restoration need was also reviewed and is discussed in Section 7.4.

**Table 2: Near/Medium Term Needs Identified in Previous RIP <sup>(1)</sup> and/or this NA**

Type of Needs	Near/Medium-Term Needs	NA Section	Timing	Recommended Plan / Status	RIP Report Section
Line Capacity	Richview TS to Manby TS 230 kV Corridor	7.2.1	2026	Project in estimate phase.	7.5
	Manby TS to Riverside Jct 115 kV Corridor	7.2.2	2028 <sup>(3)</sup>	Timing is advanced to 2026.	7.9.5
Asset Renewal Needs (Stations) <sup>(2)</sup>	Strachan TS: Transformers T14 & T13/T15	7.1.1	2025 2031	<ul style="list-style-type: none"> <li>T14 requires replacement with higher rated unit.</li> <li>T13/T15 need replacement with higher rated unit in medium term.</li> </ul>	NEW
	Charles TS: Transformer T3/T4	7.1.2	2026	T3/T4 require replacement with higher rated units.	2 <sup>nd</sup> cycle NA
	Duplex TS: Transformers T1/T2 & T3/T4	7.1.3	2026 2031	<ul style="list-style-type: none"> <li>T1/T2 require replacement with higher rated units.</li> <li>T3/T4 need replacement with higher rated unit in medium term.</li> </ul>	2 <sup>nd</sup> cycle NA NEW
	Basin TS: Transformers T3/T5	7.1.4	2027	T3/T5 require replacement with higher rated units.	NEW / 7.9.4
	Scarboro TS: Transformer T23	7.1.5	2027	T23 requires replacement with like-for-like unit.	NEW
	Fairchild TS: Transformer T1 & T3/T4	7.1.6	2028	T1 and T3/T4 require replacement with like-for-like units.	2 <sup>nd</sup> cycle NA (T1), NEW (T3/T4)
	Bermondsey TS: Transformers T3/T4	7.1.7	2029	T3/T4 require replacement with like-for-like units.	7.7
	Malvern TS: Transformer T3	7.1.8	2029	T3 requires replacement with like-for-like unit.	NEW
	Manby TS: Autotransformers (T7, T9, T12), Step-down transformer (T13/T14)	7.1.9	2029 2030	<ul style="list-style-type: none"> <li>T13/T14 need replacement with similar unit per current standard.</li> <li>T7/T9/T12 need replacement with similar unit per current standard.</li> <li>230 kV breakers are in fair condition; will not be replaced in the near term.</li> </ul>	7.6, NEW (T14)
	Leslie TS: Transformer T1	7.1.10	2030	T1 requires replacement with similar unit per current standard.	2 <sup>nd</sup> cycle NA
Asset Renewal Needs (Lines) <sup>(2)</sup>	H1L/H3L/H6LC/H8LC: Leaside Jct. to Bloor St. Jct. overhead section	7.1.11	2025	Development and estimate work to initiate in 2023.	7.2
	L9C/L12C: Leaside TS to Balfour Jct. overhead section	7.1.12	2027	Development and estimate work to initiate in 2023.	7.3

(1) Includes needs identified in the previous RIP that do not have projects in execution yet.

(2) The replacement/refurbishment scope, timing, and prioritization are based on the best available information at the time, and are subject to change.

(3) Earliest in-service of reconductoring the overhead line K13J/K14J is expected to be around 2028 if the development and estimate work is to be initiated in 2023.

**Table 3: Long-Term Needs Identified in Previous RIP and/or this NA**

Type of Needs	Long-Term Needs	NA Section	Timing (2 <sup>nd</sup> Cycle RIP)	Description / Update	RIP Report Section
Station Capacity	Fairbank TS	7.3.1	2030-2035	New Runnymede DESN and the underway transformers replacement at Fairbank TS will provide relief.	7.9.1
	Sheppard TS	7.3.2	2030-2035	Consideration may be given to utilizing the idle winding on transformers T1/T2.	7.9.2
	Strachan TS	7.3.3	2030-2035	Transformer T12 has been replaced with a 60/100 MVA unit. Station capacity will increase after T14 is replaced by 2025 and T13/T15 are replaced in the medium term.	7.9.3
	Basin TS	7.3.4	2030-2035	Station capacity will increase when transformers T3/T5 will be replaced with 60/100 MVA units by 2027.	7.9.4
	Glengrove TS	7.3.5	Beyond 2031	Glengrove TS is almost at capacity in 2031. The transformer replacement with higher rated units at Duplex TS will provide relief.	NEW
	Finch TS / Bathurst TS	7.3.6	Beyond 2031	Total load at Finch TS and Bathurst TS is almost reaching the combined station capacity in 2031. To be managed by load transfer between DESNs and nearby stations at distribution level in the near/medium term.	NEW
	Warden TS	7.3.7	Beyond 2031	Load demand near Warden TS exceeds its capacity from 2024. To be managed by load transfer to Scarborough TS at distribution level in the near/medium term.	NEW
Transformation Capacity	Manby W TS Autotransformers (T12)	7.3.8	2030-2035	Restricted by the lowest rated autotransformer unit T12. This unit is planned to be replaced by 2030 and will provide relief to this constraint.	7.9.6
	Leaside TS Autotransformers (T16)	7.3.9	2035-2040	Autotransformer T16 is potentially overloaded following circuit C14L, C15L, or C17L contingency, assuming that two of the three units at Portlands Energy Centre GS are out-of-service, and total plant generation is 160 MW. Post-contingency control action is currently available to resolve this issue by transferring Dufferin TS to Manby supply if needed.	7.9.8
Line Capacity	230 kV Parkway TS to Richview TS Corridor	7.3.10	Beyond 2031	Some sections of the 230 kV circuits P21R and P22R near the Parkway TS end are approaching limit by 2031. The baseline forecast does not reflect several customers that show interest in connecting new load near the Steeles / Hwy 404 area. This need may arise sooner.	NEW
	115 kV Leaside TS to Wiltshire TS Corridor		2035-2040	The Bayview Jct. x Balfour Jct. underground section of the 115 kV circuit L15 is potentially overloaded in the long term.	7.9.7

## 7.1 Asset Renewal Needs for Major HV Transmission Equipment

In addition to the previously identified asset renewal needs from the second RP cycle, Hydro One and the TWG have identified some new major HV equipment replacement needs over the next 10 years in the Toronto Region, as shown in Table 4 below. These needs are determined by asset condition assessment, which is based on a range of considerations such as equipment deterioration; technical obsolescence due to outdated design; lack of spare parts availability or manufacturer support; and/or potential health and safety hazards, etc. The scope, timing, and prioritization of these replacement needs are based on the current available information and are subject to change.

The major HV transmission equipment considered in this assessment includes the following:

- 230 / 115 kV autotransformers;
- 230 kV and 115 kV load serving step-down transformers;
- 230 kV and 115 kV breakers where:
  - Replacement of six breakers or more than 50% of station breakers, the lesser of the two; and
- 230 kV and 115 kV transmission lines requiring refurbishment where:
  - Leave to Construct (i.e., Section 92) approval is required for any alternatives to like-for-like.

The asset renewal assessment considers options for “right-sizing” the equipment such as:

1. Maintaining the status quo;
2. Replacing equipment with similar equipment with lower ratings and built to current standards;
3. Replacing equipment with similar equipment with lower ratings and built to current standards by transferring some load to other existing facilities;
4. Eliminating equipment by transferring all the load to other existing facilities;
5. Replacing equipment with similar equipment and built to current standards (i.e., “like-for-like” replacement); and
6. Replacing equipment with higher ratings and built to current standards.

**Table 4: New Major HV Transmission Equipment Replacement Needs Identified in this NA**

Station	Timing	Need Description
Strachan TS: Transformers T14 & T13/T15	2025* 2031	T14 requires replacement in the medium term with higher rated unit. T13/T15 need replacement in the medium term with higher rated units.
Basin TS: Transformers T3/T5	2027	T3/T5 require replacement in the near term with higher rated units.
Scarboro TS: Transformer T23	2027	T23 requires replacement in the near term with like-for-like unit.
Fairchild TS: Transformer T3/T4	2028	T3 requires replacement in the medium term with like-for-like unit.
Malvern TS: Transformer T3	2029	T3 requires replacement in the medium term with like-for-like unit.
Manby TS: Transformer T14	2029	T14 need replacement in the medium term with similar unit per current standard.
Duplex TS: Transformers T3/T4	2031	T3/T4 require replacement in the medium term with higher rated units.

\* Need date is advanced to support planned work at the other DESN in Strachan TS.



The newly identified major HV transmission equipment replacement need in this NA will be discussed in detail in the following subsections. The previously identified asset renewal needs from the last RP cycle, for which project execution has not yet been initiated, will also be reviewed and discussed in the following. The TWG recommends continuation of addressing all the identified needs for the Toronto Region as per the recommended plan described in each subsection. THESL has also confirmed that there is no plan to replace any major HV transmission equipment under its under ownership over the study period.

For the 115-13.8 kV 45/75 MVA step-down transformers where replacement is required, and upsizing is recommended, the largest standard size (60/100MVA) units for this voltage class will be used. The 115-13.8 kV 60/100 MVA transformer has two secondary windings and each winding has an LTR of 72 MVA which matches the 3000 A or 72 MVA metal clad switchgear that THESL has standardized on and used at 13.8 kV. Even if a larger custom size transformer is procured, no additional station capacity will be provided as it is limited by the metal clad switchgear. The estimated incremental cost of upsizing a 45/75 MVA unit to a 60/100 MVA unit is approximately \$300k based on current dollars.

### **7.1.1 Strachan TS**

Strachan TS comprises two DESN units, T12/T14 (T12 replaced in 2022: 60/100 MVA; T14: 45/75 MVA) and T13/T15 (45/75 MVA), having a summer 10-Day LTR of 171 MW. The station's 2021 actual non-coincident summer peak load was about 135 MW and is forecasted to be approximately 140 MW (net adjusted for extreme weather) in 2031.

Transformer T14 is currently about 47 years old and requires replacement in the medium term based on asset condition assessment. It is planned to replace it with a 60/100MVA unit as the companion transformer T12 was recently replaced with a 60/100 MVA unit thereby increasing the station capacity. Transformers T13 and T15 are currently about 40 years old and will also require replacement in the medium term based on their condition. The station capacity will be further increased after they are replaced with 60/100 MVA units. This will provide the additional capacity required to support the transformers and switchgear replacement work planned for Strachan TS in the medium term and accommodate the long-term growth and development need anticipated in the area subsequent to the Ontario Line subway project. Replacing the transformers with similar size equipment is not recommended since upgrading later within the lifetime of the transformer due to eventual load growth will be significantly more costly. It should also be noted that increasing capacity, as opposed to maintaining it, is a more resilient option as it provides additional flexibility during emergency conditions or any planned outages through load transfers. With new T12 installed this year, replacing the remaining three transformers with 60/100 MVA units will provide an additional station capacity of approximately 98 MVA at Strachan TS.

Based on the above, the TWG recommends that transformers T14, T13 and T15 be replaced with 60/100MVA units. Hydro One and THESL will coordinate the replacement plan for these transformers. The planned in-service date is 2025 for T14 and 2031 for T13 and T15.

### 7.1.2 Charles TS

Charles TS comprises two DESN units, T1/T2 (60/100 MVA) and T3/T4 (45/75 MVA), having a summer 10-Day LTR of 211 MW. The station's 2021 actual non-coincident summer peak load was about 127 MW and is forecasted to be approximately 165 MW (net adjusted for extreme weather) in 2031. Transformers T3 and T4 are currently about 55 years old and require replacement based on asset condition assessment.

The load at Charles TS is forecasted to be almost 80% of its LTR in the medium term. The load at three of the closest stations, Bridgman TS, Cecil TS and Terauley TS, is also forecasted to be about 80%, 65%, and 80% in the medium term.

As discussed in the 2<sup>nd</sup> cycle NA, the TWG recommends that transformer T3 and T4 be replaced with 60/100MVA units because this is the most cost-effective option that addresses the replacement need and maintains reliable long-term supply to the existing and potential customers in the area. Hydro One and THESL are coordinating this replacement work and the planned in-service date is 2026.

### 7.1.3 Duplex TS

Duplex TS comprises two DESN units, T1/T2 (45/75 MVA) and T3/T4 (45/75 MVA), having a summer 10-Day LTR of 128 MW. The station's 2021 actual non-coincident summer peak load was about 88 MW and is forecasted to be approximately 112 MW (net adjusted for extreme weather) in 2031.

Transformers T1 and T2 are currently about 54 years old and require replacement in the near term based on asset condition assessment. As discussed in the second cycle NA, replacing T1/T2 with 60/100 MVA units is recommended to allow for effective planning for long-term electricity needs, reliability and system resiliency. The forecast developed in this NA reaffirms this recommendation as the load at Duplex TS and its nearby stations Bridgman TS and Glengrove TS are to be over 85%, 80% and 95% of their station LTR respectively in 2031.

Transformer T3 and T4 are currently about 46-48 years old and require replacement in the medium term based on asset condition assessment. With the same reasons discussed above and the growing demand in the area, the TWG recommends that these transformers be replaced with 60/100 MVA units.

Hydro One and THESL will coordinate the replacement plan for transformers T1/T2 and T3/T4. The current planned in-service dates are 2026 and 2031 respectively.

### 7.1.4 Basin TS

Basin TS comprises one DESN unit, T3/T5 (45/75 MVA), having a summer 10-Day LTR of 88 MW. The station's 2021 actual non-coincident summer peak load was about 57 MW and is forecasted to be approximately 85 MW (net adjusted for extreme weather) in 2031.

Transformers T3 and T5 are currently about 39 years old and require replacement in the near term based on asset condition assessment. The load at Basin TS is forecasted to be over 95% of its station LTR in 2031.

The load at its nearby stations Carlaw TS, Gerrard TS and Esplanade TS is also forecasted to be over 70-85% of their station LTR by 2031.

The City of Toronto is planning to re-develop the East Harbour land which is located in the Lakeshore and Don Roadway area in the near and medium term, as well as the Port Lands area in the longer term. These areas may see additional load in the longer term, beyond what is currently forecast in this NA. The scale and timing of additional load will depend upon the City's plan. However, the City's current re-development plans may impact the continued operation of Basin TS and several high voltage lines in their current locations in the Port Lands area. If implemented, this would significantly impact both Hydro One infrastructure and THESL infrastructure within and outside of Basin TS. No potential sites for a replacement transformer station or high voltage line routes have been identified by the City at this time. Hydro One and THESL have requested the City to revise its plans to avoid the conflicts with Basin TS and high voltage lines, and joined others in a legal appeal of the City's land plans. In December 2020, the appeal was settled provided that all parties will continue to reassess different options with and without the relocation or reconfiguration of the electricity infrastructure in the Port Lands area. There is no update or change in status at this time, but Hydro One and THESL will provide updates to the TWG as information becomes available.

Based on asset condition assessment of the existing transformers at Basin TS, the TWG recommends that transformers T3/T5 be replaced with 60/100 MVA units to address the replacement need and avoid any extended forced outages due to potential failure of these existing transformers. This will also provide an additional station capacity of approximately 46 MVA at Basin TS to help accommodate expected load growth in this area. Hydro One and THESL coordinate the replacement work.

The TWG also recommends that the long-term supply need in the Basin / Port Lands area be reviewed as part of the next phase in the RP process because of the uncertainty associated with the long-term growth plans as well as the potential impacts on the electricity infrastructure in this area resulting from the City's redevelopment plans. This is consistent with the finding and the recommendation from the previous RP cycle and as discussed in Section 7.3.4 of this report.

### **7.1.5 Scarborough TS**

Scarboro TS comprises two DESN units, T21/T22 (75/125 MVA) and T23/T24 (75/125 MVA), having a summer 10-Day LTR of 340 MW. The station's 2021 actual non-coincident summer peak load was about 217 MW and is forecasted to be approximately 257 MW (net adjusted for extreme weather) in 2031.

Transformer T23 is currently about 48 years old and require replacement in the near term based on asset condition assessment. The load at Scarboro TS is forecasted to be over 75% of its station LTR in 2031. Its nearby stations Warden TS is forecasted to exceed its station capacity in the near term and need relief by transferring load to Scarboro TS. The load at other closest stations Bermondsey TS and Ellesmere TS is also forecasted to be about 80% and 85% of their station LTR by 2031.

Downsizing capacity today and then later upgrading within the lifetime of the transformer due to eventual load growth will be significantly costlier. It should also be noted that maintaining capacity, as opposed to

downsizing, is a more resilient option as it provides additional flexibility during emergency conditions or any planned outages through load transfers. Therefore, downsizing T23 is not a viable option. Upgrading the transformer is also not an option since it is already at the maximum standard size.

The TWG has recommended that transformer T23 be replaced with the same type and size unit (75/125 MVA). Hydro One and THESL will coordinate the replacement plan for the transformer and the planned in-service date is 2027.

### **7.1.6 Fairchild TS**

Fairchild TS comprises two DESN units, T1/T2 (75/125 MVA) and T3/T4 (75/125 MVA), having a summer 10-Day LTR of 346 MW. The station's 2021 actual non-coincident summer peak load was about 216 MW and is forecasted to be approximately 243 MW (net adjusted for extreme weather) in 2031. Transformers T1 is 52 years old but was rebuilt 36 years ago. The companion DESN transformer T2 failed and was replaced under emergency in 2017 with a similar 75/125 MVA unit. Transformers T3 and T4 in the other DESN are 39 years old. Transformers T1, T3 and T4 require replacement in the medium term based on asset condition assessment.

The load at Fairchild TS is forecasted to be over 70% of its LTR in the medium term. The load at the two closest stations, Bathurst TS and Leslie TS, is also forecasted to be about 95% and 90% of their respective LTR's in the medium term. Downsizing capacity today and then later upgrading within the lifetime of the transformer due to eventual load growth will be significantly costlier. It should also be noted that maintaining capacity, as opposed to downsizing, is a more resilient option as it provides additional flexibility during emergency conditions or any planned outages through load transfers. Therefore, downsizing the transformers at Fairchild TS and consolidating load within the station and/or with area stations is not a viable option given medium term load growth at these stations. Upgrading the transformers is also not an option since they are already at the maximum standard size.

Based on the above, the TWG recommends that transformers T1, T3 and T4 be replaced like-for-like. Hydro One and THESL will coordinate the replacement plan for these transformers. The planned in-service date is 2028.

### **7.1.7 Bermondsey TS**

Bermondsey TS comprises two DESN units, T1/T2 (75/125MVA) and T3/T4 (75/125 MVA), having a summer 10-Day LTR of 348 MW. The station's 2021 actual non-coincident summer peak load was about 153 MW and is forecasted to increase significantly in the near term due to new load customers in the area. The load is forecasted to be approximately 275 MW (net adjusted for extreme weather) in 2031. Transformers T3 and T4 are currently about 57 years old and require replacement in the near term based on asset condition assessment.

The load at Bermondsey TS is forecasted to be almost 80% of its LTR in the medium term. The load at the three closest stations, Scarborough TS, Warden TS, and Leaside TS is forecasted to be over 75%, 100%<sup>1</sup>, and 67% respectively of their LTR's in the medium term.

As evaluated in the 2<sup>nd</sup> cycle RIP and reaffirmed in this NA, transformer T3 and T4 are to be replaced with similar type and size equipment as per current standard because this is the most cost effective option that addresses the replacement need and maintains reliable long-term supply to the customers in the area. The planned in-service date of this refurbishment work is 2029.

### **7.1.8 Malvern TS**

Malvern TS comprises one DESN unit, T3/T4 (75/125 MVA), having a summer 10-Day LTR of 176 MW. The station's 2021 actual non-coincident summer peak load was about 110 MW and is forecasted to be approximately 119 MW (net adjusted for extreme weather) in 2031. Transformers T3 is currently 36 years old and requires replacement in the medium term based on asset condition assessment.

The load at Malvern TS is forecasted to be almost 70% of its LTR in the medium term. The load at the three closest stations, Agincourt TS, Cavanagh MTS, and Sheppard TS is forecasted to be over 60%, 90%, and 90% respectively of their LTR's in the medium term. Downsizing capacity today and then later upgrading within the lifetime of the transformer due to eventual load growth will be significantly costlier. It should also be noted that maintaining capacity, as opposed to downsizing, is a more resilient option as it provides additional flexibility during emergency conditions or any planned outages through load transfers. Therefore, downsizing the transformer at Malvern TS and consolidating load within the station and/or with area stations is not a viable option given medium term load growth at these stations.

Based on the above, the TWG recommends that transformer T3 be replaced with the same type and size unit (75/125 MVA). Hydro One and THESL will coordinate the replacement plan for this transformer. The planned in-service date is 2029.

### **7.1.9 Manby TS**

Manby TS is a major bulk electric switching and autotransformer station in the Toronto region. Station facilities include the Manby West and Manby East 230 kV and 115 kV switchyards, six 230/115 kV autotransformers (T1, T2, T7, T8, T9, T12), and six 230/27.6 kV step-down transformers supplying three DESNs (T3/T4, T5/T6, T13/T14).

Three of the autotransformers, T7, T9, and T12, and two of the step-down transformers, T13 and T14, are close to 55 years old and require replacement in the medium term based on asset condition assessment. It is to be noted that T14 was not identified as a candidate for replacement in the previous RP cycle. The autotransformers continue to be critical to the load supply to the downtown and west Toronto area and will

---

<sup>1</sup> The net demand at Warden TS exceeds its station LTR by 2024. THESL will manage the station overload by transferring some load to Scarborough TS in the near/medium term.

be replaced with similar 250 MVA units, consistent with recommendations from previous RP cycle. The expected in-service date for the autotransformer replacement is 2030.

The total summer 10-Day LTR of the six step-down transformers is 226 MW. The station's 2021 actual non-coincident summer peak load was about 237 MW which exceeds the station capacity and will be relieved in the near and medium term by transferring load to the second DESN at Horner TS recently built. The total DESN load at Manby TS, after the load transfer, is forecasted to be approximately 204 MW (net adjusted for extreme weather) in 2031, i.e. over 90% of its LTR in the medium term. Therefore, the TWG recommends transformers T13 and T14 (56/93 MVA units, non-standard size) be replaced with the current standard size units (75/125 MVA units) to address the replacement need and maintain reliable long-term supply to the customers in the area. This will potentially increase the station LTR by approximately 60 MVA. Hydro One and THESL will coordinate the replacement plan for these transformers. The planned in-service date of this refurbishment work is 2029.

Previously, the 230 kV oil breakers were considered as candidates for replacement. Since then, the condition of these breakers has been reviewed and based on this assessment, they are not required for replacement in the near or medium term. Hydro One will continue to monitor the condition of these breakers and coordinate the future replacement plan with the phase 2 work of the Richview TS x Manby TS 230 kV Corridor Upgrade project as described in Section 7.2.1 of this report. Updates will be provided to the TWG in the next RP cycle as required.

#### **7.1.10 Leslie TS**

Leslie TS comprises two DESN units, T1/T2 (75/125 MVA) and T3/T4 (75/125 MVA), having a summer 10-Day LTR of 323 MW. The station's 2021 actual non-coincident summer peak load was about 221 MW and is forecasted to be approximately 249 MW (net adjusted for extreme weather) in 2031. Transformer T1 is currently about 59 years old and require replacement based on asset condition assessment. The companion DESN transformer T2 is currently 25 years old and does not require replacement in the near or medium term.

It should be noted that transformers T1 and T2 are non-standard units with dual LV voltages (230-27.6-13.8 kV 75/125 MVA units). The 13.8 kV load that are currently supplied from Leslie TS will be diminished and the 13.8 kV supply will not be needed from Leslie TS. Excluding the capacity for the 13.8kV winding, the total station LTR for the 27.6kV load is about 280 MW. The 27.6kV load at Leslie TS will be at almost 90% of its LTR in the medium term. The load at the three closest stations, Fairchild TS, Cavanagh MTS, and Agincourt TS, is also forecasted to be over 70%, 90%, and 60% respectively of their LTR's in the medium term. THESL is also anticipating additional new load connection in the longer term at Leslie TS and Agincourt TS.

Based on the above and consistent with the recommendation from the last NA, the TWG recommends that transformer T1 be replaced with a standard unit of same size without dual LV voltages (i.e. a 230-27.6-27.6 kV 75/125 MVA unit). Hydro One and THESL will coordinate the replacement plan for this transformer. When more capacity is required at Leslie TS, the companion transformer T2 can be replaced with the same

230-27.6-27.6 kV 75/125 MVA unit to provide an increase of approximately 70 MVA for the 27.6 kV supply capacity. The planned in-service date for transformer T1 is 2030.

### **7.1.11 Overhead Transmission Line H1L/H3L/H6LC/H8LC**

The 115 kV circuits H1L/H3L/H6LC/H8LC provide connections between Leaside TS, Hearn SS, and Cecil TS, and supply transformer stations in the eastern part of central Toronto including Gerrard TS, Carlaw TS, and Basin TS. Based on their asset condition, conductors along the overhead section between Leaside 34 Jct. and Bloor St. Jct. (about 2 route km) are required to be replaced in the near term.

As recommended by the TWG from the previous RIP, the conductor in this overhead section will be replaced with largest size possible conductor while retaining existing tower structures. The expected in-service date for this line replacement work is around 2025.

### **7.1.12 Overhead Transmission Line L9C/L12C**

The 115 kV circuits L9C/L12C provide connections between Leaside TS and Cecil TS, and supply to central downtown area including Charles TS and Cecil TS. The overhead section of this 115 kV double-circuit line between Leaside TS and Balfour Jct. (about 3.6 route km) is over 90 years old and require replacement in the near term.

As recommended by the TWG from the previous RIP, the conductor in this overhead section will be replaced with largest size possible conductor while retaining existing tower structures. The expected in-service date for this line replacement work is around 2027.

## **7.2 Station and Transmission Capacity Needs in the Near / Medium Term**

The Station and Transmission supply capacities have been reviewed. No near or medium-term station capacity need has been identified in the Toronto region. However, two transmission line capacity needs are identified below during the study period of 2022 to 2031.

### **7.2.1 Richview TS x Manby TS 230 kV Corridor – Line Capacity**

The 230 kV transmission corridor between Richview TS and Manby TS is the main supply path for the Western Sector of Central Toronto. Along this corridor there are two double-circuit 230 kV lines R1K/R2K and R13K/R15K. Together with circuit R24C between Richview TS and Cooksville TS, this corridor also supplies the load in the southern Mississauga and Oakville areas via Manby TS. The need and options to increase transfer capability of this transmission corridor to support the continuous load growth in these areas has been identified and discussed in the past RP cycles. This need was also reaffirmed in an IRRP addendum done in 2021.<sup>2</sup>

---

<sup>2</sup> The IRRP addendum for the Richview TS x Manby TS Circuit Upgrade need has not been published or shared outside of the TWG yet. However, since it was just reviewed last year, this need is not to be re-evaluated in this NA.

As previously documented, the recommendation is to proceed with:

Phase 1: Rebuilding the existing idle 115 kV overhead line on the transmission corridor between Richview TS and Manby TS to 230 kV standards. The new line will operate in parallel with the existing four 230 kV circuits from Richview TS to Manby TS, which will initially be reconfigured to create two “supercircuits” R2K and R15K. This configuration avoids the need to build new terminations and new breakers at Manby TS. This project is currently in estimate and public consultation phase. The planned in-service date is 2026.

Phase 2: Unbundling the “supercircuits” with one new circuit connected to Manby West and one to Manby East with new termination installed at Manby TS. At Richview TS, the new circuits will be tapped to existing 230 kV circuits V73R and V79R from Claireville TS. This configuration allows Richview TS to be bypassed and permits continued supply to Manby TS should there be an emergency at Richview TS. The timing of Phase 2 will be planned to coincide with Manby TS 230kV breakers replacement work when the time comes. As discussed in Section 7.1.9 of this report, the 230 kV breakers at Manby TS are currently in good condition and not planned to be replaced in the coming 10 years. Their condition will be monitored and this phase 2 work will be coordinated with the replacement work. Updates will be provided to the TWG in the next RP cycle as required.

## **7.2.2 Manby TS x Riverside Junction 115 kV Corridor – Line Capacity**

The 115 kV transmission corridor between Manby TS and John TS comprises four circuits K13J, K14J, K6J and H2JK, and provides supply to Downtown Toronto via three transformer stations John TS, Strachan TS and Copeland MTS. The 2021 actual total coincident summer peak load of these stations was about 370 MW and is forecasted to be approximately 513 MW and 500 MW (net adjusted for extreme weather) in 2026 and 2031 respectively. This corridor also provides backup supply to other stations that are normally connected to the Leaside / Hearn subsystem, such as Esplanade TS and Terauley TS.


The 7 km overhead section of the circuits K13J/K14J between Manby TS and Riverside Jct., as shown in Figure 3, is potentially overloaded under the contingency of the loss of the other circuits on this corridor. This need was identified as a long-term need (2030-2035) in the previous RIP. However, the new forecast in this NA has reflected the load demand increase from the Ontario Line subway and other residential and commercial development projects expected in the near term at Copeland MTS and John TS, and therefore this need is advanced to 2026.

The companion overhead line K6J/H2JK was upgraded in 2000 and currently has a higher ampacity rating than the K13J/K14J line. The capacity of this corridor could potentially be increased by approximately 100 MVA if the overhead section of the circuits K13J/K14J between Manby TS and Riverside Jct. is upgraded. A line upgrade project of this scope may take over 5-6 years to carry out the required work before it is in-service which includes, but not limited to, the development and estimate work, public consultation, environmental assessment, internal and external approvals, construction, outage planning and commissioning work. The earliest in-service date of the reconductoring work could be in 2028 if the development and estimate work is to begin in 2023. It is also to be noted that extended outages may be required to reductor the line. As a result of limited load transfer capability between the Manby West



and Leaside / Hearn subsystems, obtaining the said outages to complete this work could be very challenging, and worsen further as the load increases in these areas.

Considering the long timeline of the corridor upgrade and that more load could potentially be affected during construction, the TWG recommends Hydro One proceed on the development work for reconductoring the circuits K13J/K14J to higher ampacity conductors without replacing the existing towers. This need will continue to be reviewed as part of the next phase of this RP cycle.



**Figure 3: 115 kV Corridor between Manby TS and John TS (overhead section is circled)**

### 7.3 Long-Term Capacity Needs

This section describes the long-term capacity needs identified from the previous RIP as well as the potential ones that are observed from this NA review.

This NA focuses on assessing and identifying the needs in the Toronto Region within the 10-year timeframe (up to 2031). It is observed that there are some transformer stations and 230 kV circuits that are approaching their limits by 2031 as listed in Table 5 below. This finding is consistent with the information shared by the TWG that the Toronto Region is about to embark on a period of growth over the short and medium term driven by electrification, and that the large-scale development and customer connection projects are expected in several areas within the Toronto Region in the coming years.

**Table 5: Potential Long-Term Capacity Needs to be Further Assessed**

Station / Circuit	Need Description
Glengrave TS	Total net demand is forecasted to be about 98% of station LTR by 2031.
Finch TS / Bathurst TS	Total net demand at Finch TS and Bathurst TS is forecasted to be about 100% and 97% of station LTR respectively by 2031.
Warden TS	The net demand at Warden TS exceeds its station LTR by 2024. THESL will manage the station overload by load transfer to Scarboro TS in the near/medium term.
Parkway TS to Richview TS 230 kV Corridor (P21R/P22R)	Markham #1 Jct. x Leaside Jct. section of the overhead 230 kV circuits P21R and P22R, connecting Parkway TS and Richview TS, is approaching limit by 2031.

These potential long-term capacity needs will be further reviewed in the next phases of this RP cycle.

### **7.3.1 Fairbank TS – Station Capacity**

The long-term capacity need at Fairbank TS was identified in the previous RIP. The load at Fairbank TS was expected to exceed LTR within the 2030-2035 time period.

Fairbank TS comprises two DESN units, T1/T3 and T2/T4 (all 115/27.6 kV 50/83 MVA units), having a summer 10-Day LTR of 182 MW. The station's 2021 actual non-coincident summer peak load was about 197 MW. The excess load is planned to be transferred to Runnymede TS where a new DESN was built in 2019 and the old DESN was rebuilt in 2021. The Fairbank TS load is forecasted to be approximately 170 MW (net adjusted for extreme weather) or 93% of its station LTR in 2031. The transformer replacement work at Fairbank TS (T1/T2/T3/T4) is also underway with planned in-service date of 2024. The station LTR at Fairbank TS is expected to increase after the transformer replacement and provide some additional capacity. Together with the new and refurbished DESNs recently built at Runnymede TS, it is expected that the existing facilities will be adequate to supply the long-term growth in the area. The TWG recommends the loading be monitored and reviewed in the next RP cycle.

### **7.3.2 Sheppard TS – Station Capacity**

The long-term capacity need at Sheppard TS was identified in the previous RIP. The load at Sheppard TS was expected to exceed LTR within the 2030-2035 time period.

Sheppard TS comprises two DESN units, T1/T2 (75/125 MVA units with idle winding) and T5/T6 (50/83 MVA units), having a summer 10-Day LTR of 204 MW. The station's 2021 actual non-coincident summer peak load was about 167 MW, and is forecasted to be approximately 187 MW (net adjusted for extreme weather) or 92% of its station LTR in 2031. Consideration may be given to utilizing the idle winding on transformers T1/T2. The TWG recommends the Sheppard TS loading be monitored and reviewed in the next phases of this RP cycle.

### **7.3.3 Strachan TS – Station Capacity**

The long-term capacity need at Strachan TS was identified in the previous RIP. The load at Strachan TS was expected to exceed LTR within the 2030-2035 time period.

As discussed in Section 7.1.1, the transformer T12 at Strachan TS has been replaced recently with a 60/100 MVA unit. The station capacity at Strachan TS will increase after the transformer T14, and T13/T15 are also replaced with 60/100MVA units. This will provide adequate capacity to accommodate the long-term growth. The TWG recommends the loading be monitored and reviewed in the next RP cycle.

### **7.3.4 Basin TS – Station Capacity**

The long-term capacity need at Basin TS was identified in the previous RIP. The load at Basin TS was expected to exceed LTR within the 2030-2035 time period.

As discussed in Section 7.1.4, the load at Basin TS is forecasted to be over 95% in 2031 and expected to increase further in the longer term due to the development plan in the Port Lands area as well as the East Harbor area. The transformers T13/T15 (45/75 MVA units) require replacement in the near term based on asset condition assessment. The TWG recommends that Hydro One and THESL coordinate and initiate the development work for replacing the transformers T3/T5 with 60/100 MVA units, and that the long-term supply need in the Basin / Port Lands area be reviewed as part of the next phase in the RP process. This will include consideration of the uncertainty associated with the long-term growth plans as well as the potential impacts on the electricity infrastructure in this area resulting from the City's redevelopment plans. This is consistent with the finding and the recommendation from the previous RP cycle.

### **7.3.5 Glengrove TS – Station Capacity**

Glengrove TS comprises two DESN units, T1/T3 and T2/T4 (all 25/42 MVA units), having a summer 10-Day LTR of 88 MW. The station's 2021 actual non-coincident summer peak load was about 47 MW and is forecasted to be approximately 86 MW (net adjusted for extreme weather) or 98% of its LTR in 2031.

As discussed in Section 7.1.3, its closet station Duplex TS also has two DESN units, T1/T2 (45/75 MVA) and T3/T4 (45/75 MVA), having a summer 10-Day LTR of 128 MW. The load at Duplex TS is forecasted to be approximately 112 MW (net adjusted for extreme weather) or 88% of its LTR in 2031. The transformers T1/T2 and T3/T4 require replacement in the near and medium term. The TWG has recommended that these transformers be replaced with 60/100 MVA units to provide additional capacity in this area, and that the Glengrove TS and Duplex TS loading be monitored and reviewed in the next phases of this RP cycle.

### **7.3.6 Finch TS / Bathurst TS – Station Capacity**

THESL has identified an emerging load growth in the Northwest Toronto area near Finch TS and Bathurst TS due to re-development plan in the Downsview area located in the Keele and Sheppard area.

Finch TS comprises two DESN units, T1/T2 and T3/T4 (all 75/125 MVA units), having a summer 10-Day LTR of 366 MW. The station's 2021 actual non-coincident summer peak load was about 253 MW and is forecasted to be approximately 367 MW (net adjusted for extreme weather) in 2031.

Bathurst TS also comprises two DESN units, T1/T2 and T3/T4 (all 75/125 MVA units), having a summer 10-Day LTR of 361 MW. The station's 2021 actual non-coincident summer peak load was about 241 MW and is forecasted to be approximately 350 MW (net adjusted for extreme weather) or 97% of its LTR in 2031. The TWG recommends this need be reviewed in the next phases of this RP cycle.

### **7.3.7 Warden TS – Station Capacity**

Warden TS comprises one DESN unit, T3/T4 (75/125 MVA), having a summer 10-Day LTR of 182 MW. The station's 2021 actual non-coincident summer peak load was about 150 MW and is forecasted to be approximately 195 MW and 185 MW (net adjusted for extreme weather) in 2024 and 2031.

The demand at Warden TS exceeds its station LTR in 2024 due to new large customer connection request in the south Toronto. THESL will manage it in the near/medium term by transferring load to its closest station Scarboro TS as discussed in Section 7.1.5. The TWG recommends this need be reviewed in the next phases of this RP cycle.

### **7.3.8 Manby W TS Autotransformers – Transformation Capacity**

The long-term transformation capacity need at Manby West TS was identified in the previous RIP. Manby West TS 230/115 kV autotransformers were found to be restricted by the lowest rated unit T12 in the fleet, and is potentially overloaded within the 2030-2035 time period, following T1 or T2 contingency. This NA also affirms this transformation capacity need and the autotransformer replacement plan for T12 that is expected to provide relief to this constraint as discussed in Section 7.1.9. The current planned in-service date of the T12 autotransformer replacement is around 2030. The TWG recommends that the long-term supply need in this area be reviewed as part of the next phase of this RP cycle.

### **7.3.9 Leaside TS Autotransformers – Transformation Capacity**

The long-term transformation capacity need at Leaside TS was identified in the previous RIP. Leaside TS 230/115 kV autotransformers were found to be restricted by the lowest rated unit T16 in the fleet, and is potentially overloaded within the 2035-2040 time period, following T15 or T17 contingency, assuming that two of the three units at Portlands Energy Centre GS are out-of-service, and total plant generation is 160 MW. Post-contingency control action is currently available to resolve this issue by transferring Dufferin TS to Manby supply. The TWG recommends this need be monitored and reviewed in the next phases of this RP cycle.

### **7.3.10 Parkway TS to Richview TS 230 kV Corridor – Line Capacity**

The 230 kV circuits P21R/P22R provide the transmission network connection between Parkway TS and Richview TS. These circuits also supply two transformer stations in the City of Markham as well as three transformer stations in the Northwest Toronto area (Leslie TS, Bathurst TS, and Finch TS) together with the other 230 kV circuits on the “Finch Corridor” between Cherrywood TS and Richview TS.

With the increasing demand forecasted on this corridor, some sections of the circuits P21R/P22R<sup>3</sup> are over 90% of their ratings under certain contingencies in the medium term and are potentially overloaded in the long term. Consideration may be given to reconductoring part of the circuits close to the Parkway TS end. It is to be noted that the baseline NA forecast does not reflect a number of customers that show interest in connecting new load near the Steeles / Hwy 404 area. The need for this corridor upgrade may become sooner. The TWG recommends this need be monitored and reviewed in the next phase of this RP cycle.

---

<sup>3</sup> The line section between Markham #1 Jct. and CTS Jct. of the circuits P21R/P22R is found to be the most restrictive in this NA review; however, the scope and timing of the preferred plan for this need will be reviewed and determined in the next phases of this RP cycle when a more certain and longer term load forecast will become available and considered.

### 7.3.11 Leaside TS to Wiltshire TS 115 kV Corridor – Line Capacity

The 115 kV transmission corridor between Leaside TS and Wiltshire TS comprises four circuits L13W, L14W, L18W and L15. It provides supply to Midtown Toronto area via two transformer stations Bridgman TS and Dufferin TS. The 2021 actual total coincident summer peak load of these stations was about 257 MW and is forecasted to be approximately 280 MW (net adjusted for extreme weather) in 2031. This corridor also provides backup supply to other stations that are normally connected to the Manby East subsystem such as Wiltshire TS, Fairbank TS and/or Runnymede TS.

The line capacity need on this corridor was identified as a long-term need (2035-2040) in the previous RIP, that the 1.8 km underground section of the circuit L15 between Bayview Jct. and Balfour Jct. is potentially overloaded in the long term. In this NA review, the contingency flow on this line section is about 80% of its limited time emergency rating in 2031. The TWG recommends the loading and the line capacity need on this Leaside TS x Wiltshire TS corridor be monitored and reviewed in the next phase of this RP cycle.

## 7.4 Load Restoration Analysis

The contingencies from the previous load restoration analysis in the 2<sup>nd</sup> cycle IRRP are reviewed along with this new NA forecast. The potential load interrupted by configuration for the following contingencies is significantly higher than the amount from the 2<sup>nd</sup> cycle IRRP.

For the loss of 230kV circuits C14L and C17L<sup>4</sup> (stations connected are Warden TS and Bermondsey TS), a total load of 379 MW in 2031 will be interrupted by configuration and 129 MW of it will need to be restored within 30 minutes based on the load restoration criteria in the ORTAC.

For the loss of 230kV circuits C18R and P22R<sup>5</sup> (Bathurst TS), a total load of 350 MW in 2031 will be interrupted by configuration and 100 MW of it will need to be restored within 30 minutes based on the load restoration criteria in the ORTAC.

THESL has indicated that the current distribution feeder configuration and spare capacity from the nearby stations will not be adequate to resupply all of the aforementioned amount of load in excess of 250 MW within 30 minutes and recommends that these load restoration scenarios and options be reviewed in the next phase of this RP cycle.

## 8 SENSITIVITY ANALYSIS

The objective of a sensitivity analysis is to capture uncertainty in the load forecast as well as variability of electric demand drivers to identify any emerging needs and/or advancement or deferment of recommended

---

<sup>4</sup> The circuits C14L and C17L only share the same towers along a 4 km overhead line tap supplying Warden TS.

<sup>5</sup> The circuits C18R and P22R only share the same towers along a 2 km overhead line tap supplying Bathurst TS.

investments. The TWG has determined that the key electric demand driver in the Toronto Region to be considered in this sensitivity analysis is electric vehicle (EV) penetration and electrified heating.<sup>6</sup>

A high demand growth forecast was developed by applying + 5% on the extreme summer corrected Normal Growth net load forecast. The TWG has also considered a slower EV and electrified heating change and developed a low demand growth forecast by applying - 2.5% on the extreme summer corrected Normal Growth net load forecast.

The impact of sensitivity analysis for the high and low growth scenarios on the capacity needs identified in Section 7 is summarized in Table 6.

**Table 6: Impact of Sensitivity Analysis on the Identified Capacity Needs**

Need	Normal Growth Scenario	High Growth Scenario	Low Growth Scenario <sup>(1)</sup>
Manby TS to Riverside Jct 115 kV Corridor	2026	2026	2026
Fairbank TS	Beyond 2031	Beyond 2031	-
Sheppard TS	Beyond 2031	Beyond 2031	-
Strachan TS	Beyond 2031	Beyond 2031	-
Basin TS	Beyond 2031	2031	-
Glengrove TS	Beyond 2031	2031	-
Finch TS / Bathurst TS	Beyond 2031	2028	-
Warden TS	Beyond 2031	TBD <sup>(2)</sup>	-
Manby W TS Autotransformers (T12)	Beyond 2031	Beyond 2031	-
Leaside TS Autotransformers (T16)	Beyond 2031	2031	-
230 kV Parkway TS to Richview TS Corridor	Beyond 2031	Beyond 2031 <sup>(3)</sup>	-
115 kV Leaside TS to Wiltshire TS Corridor	Beyond 2031	Beyond 2031	-

- (1) The objective of a low growth scenario analysis is to identify any deferment in the timing of needs identified in this NA. Therefore, the long-term needs will not be looked at in the low growth scenario analysis.
- (2) Forecasted load demand at Warden TS exceeds its capacity from 2024 but THESL plans to manage it by transferring the excess load to Scarboro TS. A higher load growth scenario will certainly advance the need to relieve Warden TS and further assessment will be carried out during the next phases of this Regional Planning cycle.
- (3) Like the normal growth scenario, the high growth scenario does not reflect several customers that show interest in connecting new load near the Steeles / Hwy 404 area. The need for this corridor upgrade may be advanced to the medium term. The TWG recommends this need be monitored and reviewed in the next phases of this RP cycle.

In the high growth scenario, the timing of some of the long-term station capacity needs (Basin TS, Glengrove TS, Finch TS / Bathurst TS, and potentially Warden TS as well) is advanced to the medium-term timeframe. The timing of the long-term transformation capacity needs at Leaside TS is also advanced to 2031. The TWG recommends these needs be assessed during the next phases of this RP cycle.

The timing of the near-term capacity need on the 115 kV corridor between Manby TS and Riverside Jct. does not change in the sensitivity analysis. As discussed in Section 7.2.2, the TWG recommends Hydro One proceed on the development work for reconductoring the circuits K13J/K14J to higher ampacity conductors without replacing the existing towers and this need be reviewed as part of the next phase of this RP cycle.

<sup>6</sup> The sensitivity analysis does not consider the impact from the IESO's "Pathways to Decarbonization" report published on December 15, 2022. The electricity demand and new infrastructure need in the longer term could be substantially higher than anticipated in this report, and will be assessed in the next phase of this RP cycle.

## 9 RECOMMENDATIONS

The TWG’s recommendations to address the needs identified are as follows:

- a) No further regional coordination is required for the following need:
  - Asset renewal needs for replacing the major HV equipment as listed in Table 7 below. These needs will be addressed directly by Hydro One and THESL to develop a preferred replacement plan giving consideration to “right-sizing”;
- b) Further assessment and regional coordination is required in the next phases of the RP cycle to review and/or develop a preferred plan for the follow needs:
  - The line capacity need for the 115 kV corridor between Manby TS and Riverside Jct. Hydro One will initiate the development work for reconductoring the overhead line section; and
  - The load restoration and long-term needs as listed in the following table.

Table 7 summarizes the above recommendations.

**Table 7: Summary of Recommendations**

Further Regional Coordination Not Required	Further Regional Coordination Required
<p><b>Asset Renewal Needs (Stations):</b></p> <ul style="list-style-type: none"> <li>• Strachan T14 &amp; T13/T15</li> <li>• Charles TS: T3/T4</li> <li>• Duplex TS: T1/T2 &amp; T3/T4</li> <li>• Basin TS: T3/T5</li> <li>• Scarboro TS: T23</li> <li>• Fairchild TS: T1 &amp; T3/T4</li> <li>• Bermondsey TS: T3/T4</li> <li>• Malvern TS: T3</li> <li>• Manby TS: T7, T9, T12 autotransformers, T13/T14 step-down transformer</li> <li>• Leslie TS: T1</li> </ul> <p><b>Asset Renewal Needs (Lines):</b></p> <ul style="list-style-type: none"> <li>• 115 kV H1L/H3L/H6LC/H8LC: Leaside Jct. to Bloor St. Jct. overhead section</li> <li>• 115 kV L9C/L12C: Leaside TS to Balfour Jct. overhead section</li> </ul> <p><b>Line Capacity Need:</b></p> <ul style="list-style-type: none"> <li>• 230 kV Richview TS to Manby TS Corridor</li> </ul> <p><b>Station Capacity Need:</b></p> <ul style="list-style-type: none"> <li>• Fairbank TS</li> <li>• Strachan TS</li> </ul>	<p><b>Line Capacity Need:</b></p> <ul style="list-style-type: none"> <li>• 115 kV Manby TS to Riverside Jct. Corridor</li> </ul> <p><b>Load Restoration:</b></p> <ul style="list-style-type: none"> <li>• Loss of C14L/C17L</li> <li>• Loss of C18R/P22R</li> </ul>

This NA assessment was performed before the publication of the IESO’s “Pathways to Decarbonization” report on December 15, 2022, and does not include its impact on the need and/or the timing for additional electrical supply facilities in the Toronto Region. The TWG recommends that the “Pathways to Decarbonization” and its subsequent impact be considered and assessed in the next phase of this RP cycle.



## 10 REFERENCES

- [1]. Hydro One, “Toronto Regional Infrastructure Plan”, March 6, 2020.  
[https://www.hydroone.com/abouthydroone/CorporateInformation/regionalplans/metrotoronto/Documents/Toronto%20Regional%20Infrastructure%20Plan\\_Mar6%202020.pdf](https://www.hydroone.com/abouthydroone/CorporateInformation/regionalplans/metrotoronto/Documents/Toronto%20Regional%20Infrastructure%20Plan_Mar6%202020.pdf)
- [2]. Hydro One, “Needs Assessment Report, Toronto Region”, October 18, 2017.  
<https://www.hydroone.com/abouthydroone/CorporateInformation/regionalplans/metrotoronto/Documents/Needs%20Assessment%20-%20Toronto%20Region%20-%20Final.pdf>
- [3]. IESO, “Toronto Region: Integrated Regional Resource Plan”, August 9, 2019.  
<https://www.hydroone.com/abouthydroone/CorporateInformation/regionalplans/toronto/Documents/Toronto-IRRP-20190809-Report.pdf>
- [4]. Planning Process Working Group Report to the Board, 17 May 2013.  
[http://www.ontarioenergyboard.ca/OEB/Documents/EB-2011-0043/PPTECHNICAL\\_STUDY\\_TEAM\\_Regional\\_Planning\\_Report\\_to\\_the\\_Board\\_App.pdf](http://www.ontarioenergyboard.ca/OEB/Documents/EB-2011-0043/PPTECHNICAL_STUDY_TEAM_Regional_Planning_Report_to_the_Board_App.pdf)
- [5]. IESO, Ontario Resource and Transmission Assessment Criteria (ORTAC) – Issue 5.0, August 22, 2007  
<https://www.ieso.ca/-/media/Files/IESO/Document-Library/Market-Rules-and-Manuals-Library/market-manuals/connecting/IMO-REQ-0041-TransmissionAssessmentCriteria.ashx>

### Appendix A-1: Non-Coincident Summer Peak Net Load Forecast (2022 to 2031)

STATIONS	DESN ID	Summer LTR (MW)	2021 (Actuals)	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
<b>NORTH 230kV</b>		<b>1902</b>	<b>1249</b>	<b>1317</b>	<b>1388</b>	<b>1459</b>	<b>1483</b>	<b>1513</b>	<b>1525</b>	<b>1553</b>	<b>1573</b>	<b>1575</b>	<b>1577</b>
Agincourt TS	T5/T6	174	88	89	91	98	102	105	106	106	108	108	108
Bathurst TS	T1/T2	183	131	120	123	125	142	160	178	176	175	174	172
	T3/T4	178	110	135	131	146	148	146	146	163	181	179	178
Cavanagh MTS	T1/T2	157	120	117	118	121	121	127	130	141	141	141	142
Fairchild TS	T1/T2	174	108	119	131	134	134	134	134	133	132	132	132
	T3/T4	172	108	118	117	116	114	114	113	112	112	112	112
Finch TS	T1/T2	180	129	144	167	176	178	181	182	182	183	184	185
	T3/T4	186	124	132	156	179	178	178	178	177	179	181	182
Leslie TS	T1/T2 13.8	43	9	13	14	13	10	11	0	0	0	0	0
	T1/T2 27.6	96	85	86	92	100	102	88	91	91	92	93	93
	T3/T4 27.6	184	127	139	141	141	143	157	157	158	157	157	156
Malvern TS	T3/T4	176	110	106	108	108	109	112	112	113	114	115	119
<b>EAST 230kV</b>		<b>1475</b>	<b>962</b>	<b>1018</b>	<b>1059</b>	<b>1154</b>	<b>1156</b>	<b>1158</b>	<b>1186</b>	<b>1207</b>	<b>1209</b>	<b>1212</b>	<b>1213</b>
Bermondsey TS	T1/T2	186	60	75	103	109	109	127	143	142	142	141	140
	T3/T4	162	93	120	124	129	132	113	131	130	129	132	135
Ellesmere TS	T3/T4	189	124	123	131	152	157	157	156	165	165	164	163
Leaside TS	T19/T20/T21 13.8	100	67	70	70	69	70	71	71	71	71	71	71
	T19/T20/T21 27.6	110	83	81	80	78	78	77	76	75	75	74	74
Scarboro TS	T21/T22	189	109	113	111	137	139	138	136	150	150	151	150
	T23/T24	151	108	112	111	112	109	108	108	108	108	108	107
Sheppard TS	T1/T2	95	76	69	70	70	70	70	70	70	81	81	82
	T5/T6 (was T3/T4)	109	91	98	100	103	105	106	108	109	103	104	105
Warden TS	T3/T4	182	150	156	160	195	187	191	188	186	186	186	185
<b>WEST 230kV</b>		<b>1239</b>	<b>768</b>	<b>752</b>	<b>796</b>	<b>837</b>	<b>810</b>	<b>828</b>	<b>864</b>	<b>862</b>	<b>870</b>	<b>879</b>	<b>889</b>
Horner TS	T1/T2	184	0	30	31	39	40	96	95	95	95	95	95
	T3/T4	182	147	126	147	145	145	117	115	115	114	114	113
Manby TS	T13/T14	106	85	81	82	98	98	83	83	84	84	86	86
	T3/T4	60	73	58	58	59	60	53	53	53	55	56	58
	T5/T6	60	79	64	66	65	53	55	56	57	59	59	61
Rexdale TS	T1/T2	187	102	104	108	108	93	93	140	144	148	154	160
Richview TS	T1/T2	159	111	114	112	111	109	108	106	105	104	103	102
	T5/T6	188	103	104	121	142	141	150	140	132	132	132	133
	T7/T8	113	68	70	71	71	72	74	76	77	79	80	81
<b>LEASIDE 115kV</b>		<b>1779</b>	<b>1141</b>	<b>1265</b>	<b>1318</b>	<b>1339</b>	<b>1365</b>	<b>1365</b>	<b>1369</b>	<b>1382</b>	<b>1389</b>	<b>1403</b>	<b>1416</b>
Basin TS	T3/T5	88	57	74	59	67	69	72	77	81	82	82	85
Bridgman TS	T11/T12/T13/T14/T15	189	133	145	146	148	147	147	147	147	147	148	150
Carlaw TS	T1/T2	73	63	43	43	42	47	49	50	51	52	53	53
Cecil TS	T1/T2	85	55	61	60	59	58	57	55	54	55	57	57
	T3/T4	130	92	91	89	89	87	86	84	82	81	81	82
Charles TS	T1/T2	130	70	86	91	95	93	98	97	98	97	96	95
	T3/T4	81	57	62	64	60	71	71	72	71	70	70	70
Dufferin TS	T1/T3	94	46	53	64	59	63	65	66	66	67	67	67
	T2/T4	86	80	71	70	68	69	68	66	66	65	65	65
Duplex TS	T1/T2	81	55	66	68	70	70	72	73	73	75	76	78
	T3/T4	47	35	36	33	32	32	33	33	33	33	33	34
Esplanade TS	T11/T12/T13	187	125	145	150	155	157	156	155	157	158	158	158
Gerrard TS	T1/T2	128	30	55	78	80	79	80	80	84	88	91	91
Glengrove TS	T1/T3	44	17	31	33	35	35	35	35	36	36	37	37
	T2/T4	44	30	32	36	39	39	41	42	44	46	47	49
Main TS	T3/T4	77	56	60	62	62	63	63	64	64	65	66	67
Terauley TS	T1/T4	108	53	61	91	95	99	85	85	87	87	88	89
	T2/T3	108	88	92	81	86	86	88	88	88	88	88	89
<b>MANBY E 115kV</b>		<b>579</b>	<b>362</b>	<b>374</b>	<b>399</b>	<b>421</b>	<b>428</b>	<b>430</b>	<b>428</b>	<b>429</b>	<b>430</b>	<b>432</b>	<b>436</b>
Fairbank TS	T2/T4	90	90	96	86	89	90	91	88	89	89	90	91
	T1/T3 (to be T5/T6)	92	107	89	81	74	74	75	75	76	77	78	79
Runnymede TS	T1/T2	108	78	80	95	108	110	106	105	104	103	103	102
	T5/T6 (was T3/T4)	111	32	28	44	49	53	57	59	60	61	62	65
Wiltshire TS	T1/T6	48	25	34	34	34	34	35	35	35	35	36	36
	T7X/T2X	129	30	47	59	67	67	66	65	65	64	64	64
<b>MANBY W 115kV</b>		<b>611</b>	<b>374</b>	<b>375</b>	<b>380</b>	<b>423</b>	<b>425</b>	<b>518</b>	<b>516</b>	<b>511</b>	<b>508</b>	<b>506</b>	<b>505</b>
Copeland MTS	T1/T3	130	80	104	114	120	121	182	179	177	175	174	173
John TS	T1/T2/T3/T4	187	83	39	37	61	59	98	99	143	142	141	140
	T5/T6	123	75	92	92	99	99	101	101	54	53	53	52
Strachan TS	T12/T14	74	52	59	56	57	57	87	86	86	86	86	87
	T13/T15	97	84	81	81	86	89	50	50	51	52	52	53
<b>TOTAL REGIONAL LOAD</b>		<b>7586</b>	<b>4856</b>	<b>5100</b>	<b>5341</b>	<b>5633</b>	<b>5667</b>	<b>5812</b>	<b>5887</b>	<b>5944</b>	<b>5979</b>	<b>6008</b>	<b>6036</b>

## Appendix A-2: Coincident Summer Peak Net Load Forecast (2022 to 2031)

STATIONS	DESN ID	Summer LTR (MW)	2021 (Actuals)	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
<b>NORTH 230kV</b>		<b>1902</b>	<b>1173</b>	<b>1240</b>	<b>1309</b>	<b>1376</b>	<b>1401</b>	<b>1430</b>	<b>1444</b>	<b>1470</b>	<b>1490</b>	<b>1492</b>	<b>1493</b>
Agincourt TS	T5/T6	174	72	73	74	80	83	86	86	87	88	89	88
Bathurst TS	T1/T2	183	127	116	119	121	138	156	173	171	170	169	168
	T3/T4	178	110	135	131	146	148	146	145	163	180	179	178
Cavanagh MTS	T1/T2	157	96	93	94	97	97	101	104	113	113	113	113
Fairchild TS	T1/T2	174	106	117	129	132	132	132	131	131	130	130	129
	T3/T4	172	108	118	117	116	114	114	113	112	112	112	112
Finch TS	T1/T2	180	128	143	166	175	177	180	180	181	181	182	183
	T3/T4	186	124	133	156	179	178	178	178	177	179	181	182
Leslie TS	T1/T2 13.8	43	5	7	8	7	6	6	0	0	0	0	0
	T1/T2 27.6	96	74	75	80	87	89	76	79	80	80	81	81
	T3/T4 27.6	184	127	139	141	141	143	157	157	158	157	157	156
Malvern TS	T3/T4	176	96	92	94	94	95	97	98	98	99	100	104
<b>EAST 230kV</b>		<b>1475</b>	<b>865</b>	<b>915</b>	<b>950</b>	<b>1029</b>	<b>1033</b>	<b>1031</b>	<b>1056</b>	<b>1075</b>	<b>1076</b>	<b>1079</b>	<b>1080</b>
Bermondsey TS	T1/T2	186	48	60	82	87	87	101	114	113	113	113	112
	T3/T4	162	88	114	117	122	125	107	124	123	122	125	128
Ellesmere TS	T3/T4	189	116	115	122	141	147	146	145	154	154	153	152
Leaside TS	T19/T20/T21 13.8	100	66	69	69	68	69	70	70	70	70	70	70
	T19/T20/T21 27.6	110	79	77	76	74	74	73	72	72	71	71	70
Scarboro TS	T21/T22	189	94	97	96	118	119	118	117	129	129	129	129
	T23/T24	151	107	111	110	111	109	108	107	108	107	107	107
Sheppard TS	T1/T2	95	65	60	60	60	60	60	60	60	69	70	70
	T5/T6 (was T3/T4)	109	89	96	97	100	102	104	105	106	101	102	103
Warden TS	T3/T4	182	113	118	120	147	141	144	141	140	140	140	140
<b>WEST 230kV</b>		<b>1239</b>	<b>648</b>	<b>640</b>	<b>680</b>	<b>711</b>	<b>685</b>	<b>710</b>	<b>745</b>	<b>743</b>	<b>749</b>	<b>756</b>	<b>764</b>
Horner TS	T1/T2	184	0	30	31	39	40	96	95	95	95	95	95
	T3/T4	182	144	123	144	142	142	115	112	112	112	111	111
Manby TS	T13/T14	106	58	55	56	67	67	57	57	57	57	59	58
	T3/T4	60	36	29	29	29	30	26	26	26	27	28	29
	T5/T6	60	75	60	62	62	50	52	53	54	56	55	57
Rexdale TS	T1/T2	187	97	99	103	102	89	88	133	137	141	147	152
Richview TS	T1/T2	159	109	112	110	108	107	106	104	103	102	101	100
	T5/T6	188	83	84	98	114	114	121	113	106	106	107	107
	T7/T8	113	46	47	48	48	49	50	51	53	54	54	55
<b>LEASIDE 115kV</b>		<b>1779</b>	<b>1131</b>	<b>1253</b>	<b>1305</b>	<b>1326</b>	<b>1352</b>	<b>1351</b>	<b>1355</b>	<b>1368</b>	<b>1375</b>	<b>1389</b>	<b>1401</b>
Basin TS	T3/T5	88	57	74	59	67	69	72	77	81	82	82	85
Bridgman TS	T11/T12/T13/T14/T15	189	133	145	146	148	148	147	147	147	147	149	151
Carlaw TS	T1/T2	73	62	43	42	41	46	49	49	50	51	52	52
Cecil TS	T1/T2	85	55	61	61	59	58	57	56	54	55	57	57
	T3/T4	130	92	91	89	89	87	86	84	82	80	81	82
Charles TS	T1/T2	130	70	86	91	94	93	97	97	97	96	95	94
	T3/T4	81	57	61	64	60	70	71	71	70	70	70	70
Dufferin TS	T1/T3	94	46	53	63	58	63	64	65	66	66	66	66
	T2/T4	86	78	69	68	66	67	66	65	64	64	63	63
Duplex TS	T1/T2	81	55	67	68	70	71	72	73	74	75	76	78
	T3/T4	47	34	35	33	31	31	32	32	32	32	33	33
Esplanade TS	T11/T12/T13	187	125	145	150	155	156	156	155	157	157	157	158
Gerrard TS	T1/T2	128	29	53	76	77	77	77	77	81	85	88	88
Glengrove TS	T1/T3	44	16	30	32	34	34	34	34	34	35	35	36
	T2/T4	44	29	31	35	37	38	40	41	43	44	45	47
Main TS	T3/T4	77	54	58	60	61	61	62	62	62	63	64	65
Terauley TS	T1/T4	108	52	60	89	94	97	83	84	85	86	87	88
	T2/T3	108	87	91	80	85	85	87	87	87	87	88	88
<b>MANBY E 115kV</b>		<b>579</b>	<b>293</b>	<b>336</b>	<b>362</b>	<b>384</b>	<b>390</b>	<b>392</b>	<b>390</b>	<b>391</b>	<b>392</b>	<b>394</b>	<b>398</b>
Fairbank TS	T2/T4	90	79	84	75	78	79	80	77	78	78	79	80
	T1/T3 (to be T5/T6)	92	91	75	69	62	63	63	64	64	65	66	67
Runnymede TS	T1/T2	108	69	71	83	95	97	94	93	92	91	90	90
	T5/T6 (was T3/T4)	111	1	28	44	49	53	57	59	60	61	62	65
Wiltshire TS	T1/T6	48	23	32	32	32	32	33	33	33	33	34	34
	T7X/T2X	129	30	46	59	66	66	65	65	64	64	64	63
<b>MANBY W 115kV</b>		<b>611</b>	<b>370</b>	<b>371</b>	<b>376</b>	<b>418</b>	<b>420</b>	<b>512</b>	<b>510</b>	<b>506</b>	<b>503</b>	<b>501</b>	<b>500</b>
Copeland MTS	T1/T3	130	79	102	112	119	119	180	177	175	173	171	170
John TS	T1/T2/T3/T4	187	83	39	37	61	59	98	99	143	142	140	140
	T5/T6	123	74	91	91	98	98	100	99	53	53	52	52
Strachan TS	T12/T14	74	51	58	56	56	56	85	85	85	85	85	85
	T13/T15	97	83	80	80	85	88	49	50	50	51	52	53
<b>TOTAL REGIONAL LOAD</b>		<b>7586</b>	<b>4480</b>	<b>4756</b>	<b>4982</b>	<b>5245</b>	<b>5281</b>	<b>5426</b>	<b>5500</b>	<b>5553</b>	<b>5585</b>	<b>5611</b>	<b>5636</b>

**Appendix B: Lists of Step-Down Transformer Stations (Current)**

Station (DESN)	Voltage (kV)	Supply Circuits
Agincourt TS T5/T6	230/27.6	C4R/C10A
Basin TS T3/T5	115/13.8	H3L/H1L
Bathurst TS T1/T2	230/27.6	P22R/C18R
Bathurst TS T3/T4	230/27.6	P22R/C18R
Bermondsey TS T1/T2	230/27.6	C17L/C14L
Bermondsey TS T3/T4	230/27.6	C17L/C14L
Bridgman TS T11/T12/T13/T14/T15	115/13.8	L14W/L15/L18W
Carlaw TS T1/T2	115/13.8	H1L/H3L
Cavanagh MTS T1/T2	230/27.6	C20R/C10A
Cecil TS T1/T2	115/13.8	Cecil Buses H & P
Cecil TS T3/T4	115/13.8	Cecil Buses P & H
Charles TS T1/T2	115/13.8	L4C/L9C
Charles TS T3/T4	115/13.8	L12C/L4C
Copeland MTS T1/T3	115/13.8	D11J/D12J
Dufferin TS T1/T3	115/13.8	L13W/L18W
Dufferin TS T2/T4	115/13.8	L13W/L18W
Duplex TS T1/T2	115/13.8	L16D/L5D
Duplex TS T3/T4	115/13.8	L5D/L16D
Ellesmere TS T3/T4	230/27.6	C2L/C3L
Esplanade TS T11/T12/T13	115/13.8	H2JK/H10DE(C5E)/H9DE(C7E)
Fairbank TS T1/T3 (to be T5/T6)	115/27.6	K3W/K1W
Fairbank TS T2/T4	115/27.6	K3W/K1W

<b>Station (DESN)</b>	<b>Voltage (kV)</b>	<b>Supply Circuits</b>
Fairchild TS T1/T2	230/27.6	C18R/C20R
Fairchild TS T3/T4	230/27.6	C18R/C20R
Finch TS T1/T2	230/27.6	C20R/P22R
Finch TS T3/T4	230/27.6	P21R/C4R
Gerrard TS T1/T2	115/13.8	H3L/H1L
Glengrove TS T1/T3	115/13.8	D6Y/L2Y
Glengrove TS T2/T4	115/13.8	D6Y/L2Y
Horner TS T3/T4	230/27.6	R13K/R2K
Horner TS T1/T2	230/27.6	R13K/R2K
John TS T1/T2/T3/T4	115/13.8	John Buses K1 & K2 & K3 & K4
John TS T5/T6	115/13.8	John Buses K1 & K4
Leaside TS T19/T20/T21 13.8	230/13.8	Leaside Buses HL2, HL3, HL16
Leaside TS T19/T20/T21 27.6	230/27.6	Leaside Buses HL2, HL3, HL16
Leslie TS T1/T2 13.8	230/13.8	P21R/C5R
Leslie TS T1/T2 27.6	230/27.6	P21R/C5R
Leslie TS T3/T4 27.6	230/27.6	P21R/C5R
Main TS T3/T4	115/13.8	H7L/H11L
Malvern TS T3/T4	230/27.6	C4R/C5R
Manby TS T13/T14	230/27.6	Manby W Buses A1 & H1
Manby TS T3/T4	230/27.6	Manby W Buses A1 & H1
Manby TS T5/T6	230/27.6	Manby E Buses H2 & A2
Rexdale TS T1/T2	230/27.6	V74R/V76R
Richview TS T1/T2	230/27.6	Richview Buses H1 & A1

<b>Station (DESN)</b>	<b>Voltage (kV)</b>	<b>Supply Circuits</b>
Richview TS T5/T6	230/27.6	V74R/V72R
Richview TS T7/T8	230/27.6	Richview Buses H2 & A2
Runnymede TS T1/T2	115/27.6	K12W/K11W
Runnymede TS T5/T6 (was T3/T4)	115/27.6	K12W/K11W
Scarboro TS T21/T22	230/27.6	C14L/C2L
Scarboro TS T23/T24	230/27.6	C15L/C3L
Sheppard TS T1/T2	230/27.6	C16L/C15L
Sheppard TS T5/T6 (was T3/T4)	230/27.6	C15L/C16L
Strachan TS T12/T14	115/13.8	H2JK/K6J
Strachan TS T13/T15	115/13.8	K6J/H2JK
Terauley TS T1/T4	115/13.8	C7E/C5E
Terauley TS T2/T3	115/13.8	C7E/C5E
Warden TS T3/T4	230/27.6	C14L/C17L
Wiltshire TS T1/T6	115/13.8	K1W/K3W (Wiltshire Buses H1 & H3)
Wiltshire TS T7X/T2X	115/13.8	K1W/K3W (Wiltshire Buses H1 & H3)

## Appendix C: Lists of Transmission Circuits

Location	Circuit Designations	Voltage (kV)
Richview x Manby	R1K, R2K, R13K, R15K	230
Richview x Cooksville	R24C	230
Manby x Cooksville	K21C, K23C	230
Cherrywood x Leaside	C2L, C3L, C14L, C15L, C16L, C17L	230
Cherrywood x Richview	C4R, C5R, C18R, C20R	230
Cherrywood x Agincourt	C10A	230
Parkway x Richview	P21R, P22R	230
Claireville x Richview	V72R, V73R, V74R, V76R, V77R, V79R	230
Manby East x Wiltshire	K1W, K3W, K11W, K12W	115
Manby West x John	K6J, K13J, K14J	115
Manby West x John x Hearn	H2JK	115
John x Esplanade x Hearn	D11J, D12J, H9DE, H10DE	115
Esplanade x Cecil	C5E, C7E	115
Hearn x Cecil x Leaside	H6LC, H8LC	115
Hearn x Leaside	H1L, H3L, H7L, H11L	115
Leaside x Bridgman x Wiltshire	L13W, L14W, L15, L18W	115
Leaside x Charles	L4C	115
Leaside x Cecil	L9C, L12C	115
Leaside x Duplex	L5D, L16D	115
Leaside x Glengrove	L2Y	115
Duplex x Glengrove	D6Y	115

## Appendix D: Acronyms

Acronym	Description
A	Ampere
BES	Bulk Electric System
BPS	Bulk Power System
CDM	Conservation and Demand Management
CEP	Community Energy Plan
CIA	Customer Impact Assessment
CGS	Customer Generating Station
CSS	Customer Switching Station
CTS	Customer Transformer Station
DCF	Discounted Cash Flow
DESN	Dual Element Spot Network
DG	Distributed Generation
DSC	Distribution System Code
GS	Generating Station
GTA	Greater Toronto Area
HV	High Voltage
IESO	Independent Electricity System Operator
IRRP	Integrated Regional Resource Plan
kV	Kilovolt
LDC	Local Distribution Company
LP	Local Plan
LTE	Long Term Emergency
LTR	Limited Time Rating
LV	Low Voltage
MEP	Municipal Energy Plan
MTS	Municipal Transformer Station
MW	Megawatt
MVA	Mega Volt-Ampere
MVAR	Mega Volt-Ampere Reactive
NA	Needs Assessment
NERC	North American Electric Reliability Corporation
NGS	Nuclear Generating Station
NPCC	Northeast Power Coordinating Council Inc.
NUG	Non-Utility Generator
OEB	Ontario Energy Board
OPA	Ontario Power Authority
ORTAC	Ontario Resource and Transmission Assessment Criteria
PEC	Portland Energy Centre
PF	Power Factor
PPWG	Planning Process Working Group
RIP	Regional Infrastructure Plan
RP	Regional Planning
ROW	Right-of-Way
SA	Scoping Assessment
SIA	System Impact Assessment
SPS	Special Protection Scheme
SS	Switching Station
STG	Steam Turbine Generator
TPS	Traction Power Station
TS	Transformer Station
TSC	Transmission System Code
UFLS	Under Frequency Load Shedding
ULTC	Under Load Tap Changer
UVLS	Under Voltage Load Rejection Scheme